

Barry R. McBee, *Chairman*
R. B. "Ralph" Marquez, *Commissioner*
John M. Baker, *Commissioner*
Dan Pearson, *Executive Director*



RECEIVED

MAY 27 1997

COUNTY ROAD DEPT.

TEXAS NATURAL RESOURCE CONSERVATION COMMISSION

Protecting Texas by Reducing and Preventing Pollution

May 23, 1997

Mr. Curt D. Brockmann
City Public Service of San Antonio
P.O. Box 1771
San Antonio, Texas 78296

Re: EDWARDS AQUIFER, Comal County
Project: CPS Green Mountain Substation, Located at 19356 Marbach Lane, Garden Ridge, Texas
Type: Addendum to Exception to Aboveground Storage Tank (AST) and Water Pollution Abatement Plan (WPAP) for Facility Construction Plans and Specifications, 30 Texas Administrative Code (TAC), §213.9

Dear Mr. Brockmann:

The Texas Natural Resource Conservation Commission (TNRCC) has completed its review of the changes requested to the December 20, 1996, letter responding to the request for exception for the referenced project. The request for changes was submitted by Mr. Curt D. Brockmann on behalf of City Public Service of San Antonio to the San Antonio Regional Office on February 19, 1997. Final review of the request for changes was completed after additional material was received on April 21, 1997, May 21, 1997, and May 22, 1997. The changes to the December 20, 1997, letter are as follows:

Page 1, Project Description

A 15' x 20' x 6' containment vessel will be constructed and will consist of steel reinforced concrete.

Page 2, Pollution Abatement Measures, After Construction

A six inch asphalt curb will be installed along the upgradient side of the transformer area of the site to prevent pollution of stormwater originating off-site or upgradient from the project site by controlling the flow onto the transformer area.

REPLY TO: REGION 13 • 140 HEIMER RD., SUITE 360 • SAN ANTONIO, TEXAS 78232-5042 • AREA CODE 210/490-3096

P.O. Box 13087 • Austin, Texas 78711-3087 • 512/239-1000

printed on recycled paper using soy-based ink

Mr. Curt D. Brockmann
May 23, 1997
Page 2

Page 3, Exception Justification, Item 7


Provide monthly site inspections for substation maintenance by CPS maintenance personnel with training mentioned in Item #6 above.

Page 5, Standard Conditions for Exception, Item 12

...Additionally, City Public Service of San Antonio, applicant, shall remain responsible for the provisions and special conditions of this approval until such responsibility is legally transferred to another person or entity, upon which that person or entity shall assume responsibility for all provisions and specific conditions of this approval.

If you have any questions or require additional information, please contact a representative of the Edwards Aquifer Protection Program at the Commission's San Antonio Regional Office (210) 490-3096.

Sincerely,



Dan Pearson
Executive Director

DP/LB/eg

Enclosure: Deed Recordation Form

cc: Rebecca Cedillo, San Antonio Water System
Renee Green, Bexar County Public Works
Tom Hornseth, Comal County
Greg Ellis, Edwards Aquifer Authority
Steve Music, TNRCC Groundwater Section
TNRCC Field Operations, Austin