



# COMAL COUNTY

## ENGINEER'S OFFICE

### License to Operate On-Site Sewage Treatment and Disposal Facility

Issued This Date: 06/28/2022

Permit Number: 114288

Location Description: 1522 CIRCOLARE  
NEW BRAUNFELS, TX 78132

Subdivision: Vintage Oaks at the Vineyard  
Unit: 16  
Lot: 1589  
Block: n/a  
Acreage: 1.0000

Type of System: Aerobic  
Surface Irrigation

Issued to: Ryan Klebba & Mallory Klebba

This license is authorization for the owner to operate and maintain a private facility at the location described in accordance to the rules and regulations for on-site sewerage facilities of Comal County, Texas, and the Texas Commission on Environmental Quality.

The license grants permission to operate the facility. It does not guarantee successful operation. It is the responsibility of the owner to maintain and operate the facility in a satisfactory manner.

Alterations to this permit including, but not limited to:

- Increase in the square feet of living area
- Increase in the number of bedrooms
- A change of use (i.e. residential to commercial)
- Relocation of system components (including the relocation of spray heads)
- Installation of landscaping
- Adding new structures to the system

may require a new permit. **It is the responsibility of the owner to apply for a new permit, if applicable.**

Inspection and licensing of a facility indicates only that the facility meets certain minimum requirements. It does not impede any governmental entity in taking the proper steps to prevent or control pollution, to abate nuisance, or to protect the public health.

This license to operate is valid for an indefinite period. The holder may transfer it to a succeeding owner, provided the facility has not been remodeled and is functioning properly.

Licensing Authority  
Comal County Environmental Health

OS0037176

OS0037176

ENVIRONMENTAL HEALTH INSPECTOR

ENVIRONMENTAL HEALTH COORDINATOR

OS0007722

# Comal County Environmental Health

## OSSF Inspection Sheet

Installer Name: \_\_\_\_\_

OSSF Installer #: \_\_\_\_\_

1st Inspection Date: \_\_\_\_\_

2nd Inspection Date: \_\_\_\_\_

3rd Inspection Date: \_\_\_\_\_

Inspector Name: \_\_\_\_\_

Inspector Name: \_\_\_\_\_

Inspector Name: \_\_\_\_\_

Permit#:

Address:

No.	Description	Answer	Citations	Notes	1st Insp.	2nd Insp.	3rd Insp.
1	SITE AND SOIL CONDITIONS & SETBACK DISTANCES Site and Soil Conditions Consistent with Submitted Planning Materials		285.31(a) 285.30(b)(1)(A)(iv) 285.30(b)(1)(A)(v) 285.30(b)(1)(A)(iii) 285.30(b)(1)(A)(ii) 285.30(b)(1)(A)(i)				
2	SITE AND SOIL CONDITIONS & SETBACK DISTANCES Setback Distances Meet Minimum Standards		285.91(10) 285.30(b)(4) 285.31(d)				
3	SEWER PIPE Proper Type Pipe from Structure to Disposal System (Cast Iron, Ductile Iron, Sch. 40, SDR 26)		285.32(a)(1)				
4	SEWER PIPE Slope from the Sewer to the Tank at least 1/8 Inch Per Foot		285.32(a)(3)				
5	SEWER PIPE Two Way Sanitary - Type Cleanout Properly Installed (Add. C/O Every 100' &/or 90 degree bends)		285.32(a)(5)				
6	PRETREATMENT Installed (if required) TCEQ Approved List PRETREATMENT Septic Tank(s) Meet Minimum Requirements		285.32(b)(1)(G) 285.32(b)(1)(E)(iii) 285.32(b)(1)(E)(iv) 285.32(b)(1)(F) 285.32(b)(1)(B) 285.32(b)(1)(C)(i) 285.32(b)(1)(C)(ii) 285.32(b)(1)(D) 285.32(b)(1)(E) 285.32(b)(1)(A) 285.32(b)(1)(E)(ii)(II) 285.32(b)(1)(E)(i) 285.32(b)(1)(E)(ii)(I)				
7	PRETREATMENT Grease Interceptors if required for commercial		285.34(d)				

Inspector Notes:

**Comal County Environmental Health  
OSSF Inspection Sheet**

No.	Description	Answer	Citations	Notes	1st Insp.	2nd Insp.	3rd Insp.
8	SEPTIC TANK Tank(s) Clearly Marked SEPTIC TANK If Single Tank, 2 Compartments Provided with Baffle SEPTIC TANK Inlet Flowline Greater than 3" and " T " Provided on Inlet and Outlet SEPTIC TANK Septic Tank(s) Meet Minimum Requirements		285.32(b)(1) (E) 285.91(2) 285.32(b)(1) (F) 285.32(b)(1)(E) (iii) 285.32(b)(1)(E)(ii) (II) 285.32(b)(1)(E)(ii) (I) 285.32(b)(1)(E) (i) 285.32(b)(1) (D) 285.32(b)(1)(C) (ii) 285.32(b)(1)(C) (i) 285.32(b)(1) (B) 285.32(b)(1) (A) 285.32(b)(1)(E)(iv)				
9	ALL TANKS Installed on 4" Sand Cushion/ Proper Backfill Used		285.32(b)(1)(F) 285.32(b)(1)(G) 285.34(b)				
10	SEPTIC TANK Inspection / Clean Out Port & Risers Provided on Tanks Buried Greater than 12" Sealed and Capped		285.38(d)				
11	SEPTIC TANK Secondary restraint system provided SEPTIC TANK Riser permanently fastened to lid or cast into tank SEPTIC TANK Riser cap protected against unauthorized intrusions		285.38(d) 285.38(e)				
12	SEPTIC TANK Tank Volume Installed						
13	PUMP TANK Volume Installed						
14	AEROBIC TREATMENT UNIT Size Installed						
15	AEROBIC TREATMENT UNIT Manufacturer AEROBIC TREATMENT UNIT Model Number						
16	DISPOSAL SYSTEM Absorptive		285.33(a)(4) 285.33(a)(1) 285.33(a)(2) 285.33(a)(3)				
17	DISPOSAL SYSTEM Leaching Chamber		285.33(a)(1) 285.33(a)(3) 285.33(a)(4) 285.33(a)(2)				
18	DISPOSAL SYSTEM Evapo-transpirative		285.33(a)(3) 285.33(a)(4) 285.33(a)(1) 285.33(a)(2)				

**Comal County Environmental Health  
OSSF Inspection Sheet**

No.	Description	Answer	Citations	Notes	1st Insp.	2nd Insp.	3rd Insp.
19	DISPOSAL SYSTEM Drip Irrigation		285.33(c)(3)(A)-(F)				
20	DISPOSAL SYSTEM Soil Substitution		285.33(d)(4)				
21	DISPOSAL SYSTEM Pumped Effluent		285.33(a)(4) 285.33(a)(3) 285.33(a)(1) 285.33(a)(2)				
22	DISPOSAL SYSTEM Gravelless Pipe		285.33(a)(3) 285.33(a)(2) 285.33(a)(4) 285.33(a)(1)				
23	DISPOSAL SYSTEM Mound		285.33(a)(3) 285.33(a)(1) 285.33(a)(2) 285.33(a)(4)				
24	DISPOSAL SYSTEM Other (describe) (Approved Design)		285.33(d)(6) 285.33(c)(4)				
25	DRAINFIELD Absorptive Drainline 3" PVC or 4" PVC						
26	DRAINFIELD Area Installed						
27	DRAINFIELD Level to within 1 inch per 25 feet and within 3 inches over entire excavation		285.33(b)(1)(A)(v)				
28	DRAINFIELD Excavation Width DRAINFIELD Excavation Depth DRAINFIELD Excavation Separation DRAINFIELD Depth of Porous Media DRAINFIELD Type of Porous Media						
29	DRAINFIELD Pipe and Gravel - Geotextile Fabric in Place		285.33(b)(1)(E)				
30	DRAINFIELD Leaching Chambers DRAINFIELD Chambers - Open End Plates w/Splash Plate, Inspection Port & Closed End Plates in Place (per manufacturers spec.)		285.33(c)(2)				
31	LOW PRESSURE DISPOSAL SYSTEM Adequate Trench Length & Width, and Adequate Separation Distance between Trenches		285.33(d)(1)(C)(i)				

**Comal County Environmental Health  
OSSF Inspection Sheet**

No.	Description	Answer	Citations	Notes	1st Insp.	2nd Insp.	3rd Insp.
32	EFFLUENT DISPOSAL SYSTEM Utilized Only by Single Family Dwelling EFFLUENT DISPOSAL SYSTEM Topographic Slopes < 2.0% EFFLUENT DISPOSAL SYSTEM Adequate Length of Drain Field ( 1000 Linear ft. for 2 bedrooms or Less & an additional 400 ft. for each additional bedroom ) EFFLUENT DISPOSAL SYSTEM Lateral Depth of 18 inches to 3 ft. & Vertical Separation of 1ft on bottom and 2 ft. to restrictive horizon and ground water respectfully EFFLUENT DISPOSAL SYSTEM Lateral Drain Pipe (1.25 - 1.5" dia.) & Pipe Holes ( 3/16 - 1/4" dia. Hole Size ) 5 ft. Apart		285.33(b)(3)(A) 285.33(b)(3)(A) 285.33(b)(3)(B)285.91(13) 285.33(b)(3)(D) 285.33(b)(3)(F)				
33	AEROBIC TREATMENT UNIT Is Aerobic Unit Installed According to Approved Guidelines.		285.32(c)(1)				
34	AEROBIC TREATMENT UNIT Inspection/Clean Out Port & Risers Provided AEROBIC TREATMENT UNIT Secondary restraint system provided AEROBIC TREATMENT UNIT Riser permanently fastened to lid or cast into tank AEROBIC TREATMENT UNIT Riser cap protected against unauthorized intrusions						
35	AEROBIC TREATMENT UNIT Chlorinator Properly Installed with Chlorine Tablets in Place.						
36	PUMP TANK Is the Pump Tank an approved concrete tank or other acceptable materials & construction PUMP TANK Sampling Port Provided in the Treated Effluent Line PUMP TANK Check Valve and/or Anti- Siphon Device Present When Required PUMP TANK Audible and Visual High Water Alarm Installed on Separate Circuit From Pump						
37	PUMP TANK Inspection/Clean Out Port & Risers Provided PUMP TANK Secondary restraint system provided PUMP TANK Riser permanently fastened to lid or cast into tank PUMP TANK Riser cap protected against unauthorized intrusions						
38	PUMP TANK Secondary restraint system provided						
39	PUMP TANK Electrical Connections in Approved Junction Boxes / Wiring Buried						

**Comal County Environmental Health  
OSSF Inspection Sheet**

No.	Description	Answer	Citations	Notes	1st Insp.	2nd Insp.	3rd Insp.
40	APPLICATION AREA Distribution Pipe, Fitting, Sprinkler Heads & Valve Covers Color Coded Purple?		285.33(d)(2)(G)(iii)(II) 285.33(d)(2)(G)(iii)(III) 285.33(d)(2)(G)(v) 285.33(d)(2)(G)(iii) 285.33(d)(2)(G)(iv) 285.33(d)(2)(G)(i) 285.33(d)(2)(G)(ii) 285.33(d)(2)(G)(iii)(I)				
41	APPLICATION AREA Low Angle Nozzles Used / Pressure is as required APPLICATION AREA Acceptable Area, nothing within 10 ft of sprinkler heads? APPLICATION AREA The Landscape Plan is as Designed		285.33(d)(2)(G) (i)285.33(d)(2) (A)285.33(d)(2)(F)				
42	APPLICATION AREA Area Installed						
43	PUMP TANK Meets Minimum Reserve Capacity Requirements						
44	PUMP TANK Material Type & Manufacturer						
45	PUMP TANK Type/Size of Pump Installed						



# COMAL COUNTY

---

## ENGINEER'S OFFICE

### **Permit of Authorization to Construct an On-Site Sewage Facility Permit Valid For One Year From Date Issued**

Permit Number: 114288  
Issued This Date: 04/12/2022  
This permit is hereby given to: Ryan Klebba & Mallory Klebba

To start construction of a private, on-site sewage facility located at:

1522 CIRCOLARE  
NEW BRAUNFELS, TX 78132

Subdivision: Vintage Oaks at the Vineyard  
Unit: 16  
Lot: 1589  
Block: n/a  
Acreage: 1.0000

#### APPROVED MINIMUM SIZES AS PER ATTACHED DESIGN

Type of System: Aerobic  
Surface Irrigation

This permit gives permission for the construction of the above referenced on-site facility to commence. Installation must be completed by an installer holding a valid registration card from the Texas Commission on Environmental Quality (TCEQ). Installation and inspection must comply with current TCEQ and Comal County requirements.

Call (830) 608-2090 to schedule inspections.

## COUNTY OF COMAL

## COUNTY ENGINEER'S OFFICE

## OSSF DEVELOPMENT APPLICATION CHECKLIST

Staff will complete shaded

items Date Received	Initials

114288
Permit Number

## Instructions:

Place a check mark next to all items that apply. For items that do not apply, place "N/A". This OSSF Development Application Checklist **must** accompany the completed application.

## OSSF Permit

- ☒ Completed Application for Permit for Authorization to Construct an On-Site Sewage Facility and License to Operate
- ☒ Site/Soil Evaluation Completed by a Certified Site Evaluator or a Professional Engineer
- ☒ Planning Materials of the OSSF as Required by the TCEQ Rules for OSSF Chapter 285. Planning Materials shall consist of a scaled design and all system specifications.
- ☒ Required Permit Fee
- ☒ Copy of Recorded Deed
- ☒ Surface Application/Aerobic Treatment System
  - ☒ Recorded Certification of OSSF Requiring Maintenance/Affidavit to the Public
  - ☒ Signed Maintenance Contract with Effective Date as Issuance of License to Operate

I affirm that I have provided all information required for my OSSF Development Application and that this application constitutes a completed OSSF Development Application.

  
\_\_\_\_\_  
Signature of Applicant

  
\_\_\_\_\_  
Date

☐ COMPLETE APPLICATION

Check No. \_\_\_\_\_ Receipt No. \_\_\_\_\_

☐ INCOMPLETE APPLICATION

(Missing Items Circled, Application Refused)



\*\*\* COMAL COUNTY OFFICE OF ENVIRONMENTAL HEALTH \*\*\*  
APPLICATION FOR PERMIT FOR AUTHORIZATION TO CONSTRUCT AN  
ON-SITE SEWAGE FACILITY AND LICENSE TO OPERATE

114288

Date \_\_\_\_\_ Permit # \_\_\_\_\_

Owner Name RYAN KLEBBA & MALLORY KLEBBA Agent Name GREG W. JOHNSON, P.E.  
Mailing Address c/o 23011 FM 306 Agent Address 170 Hollow Oak  
City, State, Zip Canyon Lake, TX 78133 City, State, Zip New Braunfels, TX 78132  
Phone # 830-935-4936 Phone # 830-905-2778  
Email katelyn@paulswoyerseptic.com Email gregjohnsonpe@yahoo.com

All correspondence should be sent to: ☐ Owner ☐ Agent ☒ Both Method: ☐ Mail ☒ Email

Subdivision Name VINTAGE OAKS AT THE VINEYARD Unit 16 Lot 1589 Block \_\_\_\_\_

Acreage/Legal \_\_\_\_\_

Street Name/Address 1522 CIRCOLARE City NEW BRAUNFELS Zip 78132

Type of Development:

☒ Single Family Residential

Type of Construction (House, Mobile, RV, Etc.) HOUSE+ DETACHED LIVING

Number of Bedrooms 6+1

Indicate Sq Ft of Living Area 3152 + 723

☐ Non-Single Family Residential

(Planning materials must show adequate land area for doubling the required land needed for treatment units and disposal area)

Type of Facility \_\_\_\_\_

Offices, Factories, Churches, Schools, Parks, Etc. - Indicate Number Of Occupants \_\_\_\_\_

Restaurants, Lounges, Theaters - Indicate Number of Seats \_\_\_\_\_

Hotel, Motel, Hospital, Nursing Home - Indicate Number of Beds \_\_\_\_\_

Travel Trailer/RV Parks - Indicate Number of Spaces \_\_\_\_\_

Miscellaneous \_\_\_\_\_

Estimated Cost of Construction: \$ 800,000 (Structure Only)

Is any portion of the proposed OSSF located in the United States Army Corps of Engineers (USACE) flowage easement?

☐ Yes ☒ No (If yes, owner must provide approval from USACE for proposed OSSF improvements within the USACE flowage easement)

Source of Water ☒ Public ☐ Private Well

Are Water Saving Devices Being Utilized Within the Residence? ☒ Yes ☐ No

By signing this application, I certify that:

- The completed application and all additional information submitted does not contain any false information and does not conceal any material facts. I certify that I am the property owner or I possess the appropriate land rights necessary to make the permitted improvements on said property.
- Authorization is hereby given to the permitting authority and designated agents to enter upon the above described property for the purpose of site/soil evaluation and inspection of private sewage facilities..
- I understand that a permit of authorization to construct will not be issued until the Floodplain Administrator has performed the reviews required by the Comal County Flood Damage Prevention Order.
- I affirmatively consent to the online posting/public release of my e-mail address associated with this permit application, as applicable.

[Signature]  
Signature of Owner

04/01/22  
Date

Page 1 of 2

## \* \* \* COMAL COUNTY OFFICE OF ENVIRONMENTAL HEALTH \* \* \*

APPLICATION FOR PERMIT FOR AUTHORIZATION TO CONSTRUCT AN  
ON-SITE SEWAGE FACILITY AND LICENSE TO OPERATEPlanning Materials & Site Evaluation as Required Completed By GREG W. JOHNSON, P.E.System Description PROPRIETARY; AEROBIC TREATMENT AND SURFACE IRRIGATION

Size of Septic System Required Based on Planning Materials &amp; Soil Evaluation

Tank Size(s) (Gallons) MAXX AIR M1000 & 1000 PUMP TANK Absorption/Application Area (Sq Ft) 8032Gallons Per Day (As Per TCEQ Table III) 480

(Sites generating more than 5000 gallons per day are required to obtain a permit through TCEQ)

RECEIVED

JAN 25 2021

Is the property located over the Edwards Recharge Zone? ☒ Yes ☐ No

(If yes, the planning materials must be completed by a Registered Sanitarian (R.S.) or Professional Engineer (P.E.) COUNTY ENGINEER

Is there an existing TCEQ approved WPAP for the property? ☒ Yes ☐ No

(if yes, the R. S. or P. E. shall certify that the OSSF design complies with all provisions of the existing WPAP.)

If there is no existing WPAP, does the proposed development activity require a TCEQ approved WPAP? ☐ Yes ☐ No

(If yes, the R.S. or P. E. shall certify that the OSSF design will comply with all provisions of the proposed WPAP. A Permit to Construct will not be issued for the proposed OSSF until the proposed WPAP has been approved by the appropriate regional office.)

Is the property located over the Edwards Contributing Zone? ☐ Yes ☒ NoIs there an existing TCEQ approval CZP for the property? ☐ Yes ☒ No

(if yes, the P.E. or R.S. shall certify that the OSSF design complies with all provisions of the existing CZP)

If there is no existing CZP, does the proposed development activity require a TCEQ approved CZP? ☐ Yes ☐ No

(if yes, the P.E. or R.S. shall certify that the OSSF design will comply with all provisions of the proposed CZP. A Permit to construct will not be issued for the proposed OSSF until the CZP has been approved by the appropriate regional office.)

Is this property within an incorporated city? ☐ Yes ☒ No

If yes, indicate the city: \_\_\_\_\_



FIRM #2585

By signing this application, I certify that:

- The information provided above is true and correct to the best of my knowledge.
- I affirmatively consent to the online posting/public release of my e-mail address associated with this permit application, as applicable

Signature of Designer 

Date

January 20, 2021

**AFFIDAVIT**THE COUNTY OF COMAL  
STATE OF TEXAS**CERTIFICATION OF OSSF REQUIRING MAINTENANCE**

According to Texas Commission on Environmental Quality Rules for On-Site Sewage Facilities (OSSFs), this document is filed in the Deed Records of Comal County, Texas.

I

The Texas Health and Safety Code, Chapter 366 authorizes the Texas Commission on Environmental Quality (TCEQ) to regulate on-site sewage facilities (OSSFs). Additionally, the Texas Water Code (TWC), § 5.012 and § 5.013, gives the commission primary responsibility for implementing the laws of the State of Texas relating to water and adopting rules necessary to carry out its powers and duties under the TWC. The commission, under the authority of the TWC and the Texas Health and Safety code, requires owner's to provide notice to the public that certain types of OSSFs are located on specific pieces of property. To achieve this notice, the commission requires a recorded affidavit. Additionally, the owner must provide proof of the recording to the OSSF permitting authority. This recorded affidavit is not a representation or warranty by the commission of the suitability of this OSSF, nor does it constitute any guarantee by the commission that the appropriate OSSF was installed.

RECEIVED

JAN 25 2021

COUNTY ENGINEER

II

An OSSF requiring a maintenance contract, according to 30 Texas Administrative Code §285.91(12) will be installed on the property described as (insert legal description):

16 UNIT/PHASE/SECTION BLOCK 1589 LOT VINTAGE OAKS AT THE VINEYARD SUBDIVISION

IF NOT IN SUBDIVISION: ACREAGE SURVEY

The property is owned by (insert owner's full name): RYAN KLEBBA & MALLORY KLEBBA

This OSSF must be covered by a continuous maintenance contract for the first two years. After the initial two-year service policy, the owner of an aerobic treatment system for a single family residence shall either obtain a maintenance contract within 30 days or maintain the system personally.

Upon sale or transfer of the above-described property, the permit for the OSSF shall be transferred to the buyer or new owner. A copy of the planning materials for the OSSF can be obtained from the Comal County Engineer's Office.

WITNESS BY HAND(S) ON THIS 8<sup>th</sup> DAY OF January, 2021

[Signature]  
Owner(s) Signature(s)

RYAN KLEBBA


MALLORY KLEBBA

Owner(s) Printed name(s)

RYAN KLEBBA &amp; MALLORY KLEBBA

January, 2021

[Signature]  
Notary Public Signature

SWORN TO AND SUBSCRIBED BEFORE ME ON THIS 8<sup>th</sup> DAY OF

THIS AREA FOR COMAL COUNTY CLERK RECORDING PURPOSES ONLY

Filed and Recorded  
Official Public Records  
Bobbie Koepp, County Clerk  
Comal County, Texas  
01/22/2021 10:48:22 AM  
LAURA 1 Pages(s)  
202106004097



Bobbie Koepp



PAUL SWOYER SEPTIC SUPPLY &  
SERVICE  
23011 FM 306  
CANYON LAKE, TX 78133

MP#0001708

CHRISTOPHER RYAN SEIDENSTICKER

**PROPERTY LEGAL DESCRIPTION:**

VINTAGE OAKS AT THE VINEYARD 16 LOT 1589

RECEIVED

JAN 25 2021

COUNTY ENGINEER

Customer: RYAN KLEBBA & MALLORY KLEBBA

Site Address: 1522 CIRCOLARE

City/State: NEW BRAUNFELS, TX

Zip: 78132

County: COMAL

Permit#: \_\_\_\_\_

Phone Number: \_\_\_\_\_

E-mail: \_\_\_\_\_

**I. General:** This On-Site Sewage Facility Service Agreement (hereinafter referred to as "Agreement") is entered into by and between RYAN KLEBBA & MALLORY KLEBBA (hereinafter referred to as "Client") and PS Supply & Service LLC (hereinafter referred to as "Contractor"). By this agreement, Contractor agrees to render services, as described herein (the "Services"), and the client agrees to fulfill his/her/their responsibilities under this agreement herein.

**II. Effective Dates:** This agreement commences on the date of License to Operate is issued for Three (3) years.

Date of License to Operate: LTO Last Date of Service: 3 yrs from LTO

**III. Services by Contractor:** Contractor will provide the following Services:

1. Inspect and perform routine maintenance on the On-Site Sewage Facility ("OSSF") in compliance with the code, regulations, and/or rules of the Texas Commission on Environmental Quality ("TCEQ") and county in which the OSSF is located (the "County") and the manufacturer's requirements, at a frequency of approximately once every four (4) months.
2. Report to the appropriate regulatory authority and to Client, as required by the State of Texas' on-site rules and, if required, TCEQ or County rules. All findings must be reported to the appropriate regulatory authority within 14 days.
3. Notify Client and repair any components of the OSSF that are found to be in need of repair during the inspection. If warranty, you just do it. If not, Client will be responsible. Repairs will be made so brought up to compliance and bill forward.
4. Visit site in response to Client's request for unscheduled service within two business days from the date of Contractor's actual receipt of Client's request. Unscheduled service visits are not included in the fee agreement herein and will be billed to the client in addition to fees under this Agreement.
5. Provide notification of arrival to site to the Client or to site personnel. Additionally, Contractor will leave written notification of the visit at the site or with site personnel upon completion of inspection, and forward such notice to the appropriate regulatory authority within fourteen (14) days.

**IV. Payment(s):** Client shall pay to Contractor included w/ septic for the Services describe herein (the "Inspection and Routine Maintenance Fee"), excepting those described in Section III (4), or Section IX, herein. The Fee does not include equipment, parts or labor supplied for anything beyond routine inspection and routine maintenance. Payments for such additional services are due at the time services are provided or rendered. Payments not received within thirty (30) days from the due date will be subject the greater of a \$20.00 late penalty or 1.5% carrying charge on the original balance for each month or portion thereof a balance in past due. If for any reason such charges are found to be usurious by a court of competent jurisdiction, such charges shall be reduced to the maximum allowable by law. By signing this contract, Client authorizes Contractor to remove any parts installed, but not paid in full at the end of the thirty (30) days. Client agrees to pay for any labor cost associated with the installation and the reasonable cost of removal of said parts.

Client: [Signature]

Contractor: [Signature]

RECEIVED

JAN 25 2021

**V. Client's Responsibilities:** Client is responsible for each and all of the following:

COUNTY ENGINEER

1. To maintain chlorinator and provide proper chlorine supply, if OSSF is so equipped.
2. To provide all necessary yard or lawn maintenance and removal of obstacles as needed to allow the OSSF to function properly, and to allow Contractor ready access to all parts of the OSSF.
3. To maintain a current license to operate, and abide by the conditions and limitations of that license and all requirements for on-site sewage facilities from the State and local regulatory agency.
4. To maintain the OSSF in accordance with manufacturer's recommendations.
5. To immediately notify Contractor and Agency of any and all problems with, the OSSF, including failure thereof.
6. Upon receipt of any written notification of required services from Contractor, to contact Contractor and authorize the required service. If Client elects a different contractor to perform the required service, Client is responsible for ensuring the substitute contractor holds the proper license (Installer II) and is certified by the manufacturer. Additionally, Client shall be responsible for ensuring proper notification is given to the appropriate regulatory authority, as required by the State and/or local regulatory authority rules.
7. To provide Contractor with water usage records, upon request, for evaluation by Contractor of the OSSF performance.
8. To pay required sampling charges for samples collected for testing (e.g. Biological Oxygen Demand/Total Suspended Solids ("BOD/TSS")) that may be required on the OSSF.
9. To prevent backwash from water treatment or water conditioning equipment to enter the OSSF.
10. To provide, at Client's expense, for pumping of tanks as needed.
11. To maintain site drainage sufficient to prevent adverse effects on the OSSF.
12. To promptly and fully pay Contractor's bills, fees, or invoices as described herein.

**VI. Access by Contractor:** Client agrees to allow Contractor, or personnel authorized by the Contractor, to enter the property at reasonable times without prior notice for the purpose of performing the Services described herein. Such entry shall include access to the OSSF electrical and physical components, including tanks, by means of manways or risers for the purpose of evaluations required by the manufacturer, and/or regulatory authority rules. If such manways or risers are not in place, Client shall allow and be responsible for payment of required excavation, including labor and materials, necessary to allow access to the OSSF or any required components. Such excavation shall be billed at the rate of \$75.00 per hour for labor, plus materials billed at list price. Contractor shall make only those efforts reasonable under the circumstances to replace excavated soil.

**VII. Application or Transfer of Payment:** The fees paid for this agreement may transfer to any subsequent owner(s) of the property on which the OSSF is located. The subsequent owner(s) must sign a similar agreement authorizing Contractor to perform the above-described Services, and accepting Client's responsibilities. The replacement Agreement must be signed and received within 30 days of transfer of ownership. Contractor will apply all funds received from Client first to any past due obligations arising from this Agreement including late charges, return check charges, and charges for repairs or services not paid within 30 days of invoicing. The consumption of the payment in this manner may lead to termination of the agreement by Contractor.

**VIII. Termination of Agreement:** This agreement may be terminated by either party with 30 days written notice. If this agreement is so terminated by Client, Contractor shall be paid at the rate of \$75.00 per hour for any work performed or required, but not yet paid. If terminated by Contractor, all amounts outstanding shall be due within thirty days of termination. The party terminating will immediately notify the other party, the equipment manufacturer, and the regulatory agency of the termination.

**IX. Limitation of Liability:** In no event shall Contractor be liable for indirect, consequential, incidental or punitive damages, whether in contract, tort, or any other theory of liability. In no event shall the Contractor's liability for direct damages exceed payments by the Client under this Agreement.

**X. Severability and Reformation:** If any provision in this Agreement shall be held to be invalid or unenforceable for any reason, it shall be reformed to the minimum extent necessary to effect the intent of the Parties. If any provision is such that it cannot reasonably be reformed, it shall be struck from this Agreement and the remaining provisions shall continue to be valid and enforceable.

**XI. Performance of Agreement:** Commencement of performance by Contractor under this agreement is contingent on the following conditions: (1) Contractor receiving a fully executed original copy of this agreement (2) Contractor receiving payment in full of the fee(s) described herein. If the above conditions are not met, then Contractor is from any obligation to perform any portion of this agreement.

**XII. Modification.** This Agreement may not be changed or modified except by an instrument in writing, signed by both Contractor and Client.

**XIII. Waiver.** Except as otherwise noted in this Agreement, the waiver by other party of a breach of any provision of this Agreement shall not operate or be construed as a continuing waiver or as a consent to or waiver of any subsequent breach hereof.

Client: 

Contractor: 

RECEIVED

JAN 25 2021

XIV. **Headings** The Article and Section headings in this Agreement are for the convenience of reference only and do not constitute a part of this Agreement and shall not be deemed to limit or affect any of the provisions hereof. **COUNTY ENGINEER**

XV. **GOVERNING LAW AND CHOICE OF VENUE.** EACH OF THE PARTIES HERETO HEREBY CONSENTS TO THE EXCLUSIVE JURISDICTION OF THE COURTS OF THE STATE OF TEXAS, COUNTY OF COMAL, AND TO THE UNITED STATES DISTRICT COURT FOR THE WESTERN DISTRICT OF TEXAS - SAN ANTONIO DIVISION, AS WELL AS TO THE JURISDICTION OF ALL COURTS TO WHICH AN APPEAL MAY BE TAKEN FROM SUCH COURTS, FOR THE PURPOSE OF ANY SUIT, ACTION, OR OTHER PROCEEDING ARISING OUT OF, OR IN CONNECTION WITH, THIS AGREEMENT OR ANY OF THE TRANSACTIONS CONTEMPLATED HEREBY, INCLUDING, WITHOUT LIMITATION, ANY PROCEEDING RELATING TO ANCILLARY MEASURES IN AID OF ARBITRATION, PROVISIONAL REMEDIES AND INTERIM RELIEF, OR ANY PROCEEDING TO ENFORCE ANY ARBITRAL DECISION OR AWARD. EACH PARTY HERETO EXPRESSLY WAIVES ANY AND ALL RIGHTS TO BRING ANY SUIT, ACTION, OR OTHER PROCEEDING IN OR BEFORE ANY COURT OR TRIBUNAL OTHER THAN COURTS OF THE STATE OF TEXAS, COUNTY OF COMAL, AND COVENANTS THAT IT SHALL NOT SEEK IN ANY MANNER TO PROSECUTE OR DEFEND ANY DISPUTE OTHER THAN AS SET FORTH IN THIS ARTICLE XVI OR TO CHALLENGE OR SET ASIDE ANY DECISION, AWARD, OR JUDGMENT OBTAINED IN ACCORDANCE WITH THE PROVISIONS HEREOF. EACH OF THE PARTIES HERETO HEREBY EXPRESSLY WAIVES ANY AND ALL OBJECTIONS IT MAY HAVE TO VENUE, INCLUDING, WITHOUT LIMITATION, THE INCONVENIENCE OF SUCH FORUM, IN ANY OF SUCH COURTS.

XVI. **JURY TRIAL WAIVER. THE PARTIES HEREBY UNCONDITIONALLY WAIVE THEIR RIGHT TO A JURY TRIAL OF ANY AND ALL CLAIMS OR CAUSES OF ACTION ARISING FROM OR RELATING TO THEIR RELATIONSHIP. THE PARTIES ACKNOWLEDGE THAT A RIGHT TO A JURY IS A CONSTITUTIONAL RIGHT. THAT THEY HAVE HAD AN OPPORTUNITY TO CONSULT WITH INDEPENDENT COUNSEL, AND THAT THIS JURY WAIVER HAS BEEN ENTERED INTO KNOWINGLY AND VOLUNTARILY BY ALL PARTIES TO THIS AGREEMENT. IN THE EVENT OF LITIGATION, THIS AGREEMENT MAY BE FILED AS A WRITTEN CONSENT TO A TRIAL BY THE COURT.**

Approved by Contractor:

MP#0001708

CHRISTOPHER RYAN SEIDENSTICKER

Approved by Client:

XVII. **Reservation of Rights** Contractor reserves all rights not specifically granted herein.

XVIII. **Counterparts.** This Agreement may be executed in one or more counterparts, each of which shall be deemed to be an original but all of which together will constitute one and the same instrument.

XIX. **Counsel.** Contractor has previously recommended that Client engage counsel to assist him/her/it in reviewing this Agreement and all other matters relating to it. Contractor and Client shall each bear his/her/its own costs and expenses in connection with the negotiation and documentation of this Agreement.

XX. **Entire Agreement:** This agreement contains the entire agreement of the parties, and there are no promises or conditions in any other agreement, oral or written. The Parties expressly disclaim reliance on any prior statements, oral or written, by either party not expressly provided for herein.

Client:

Contractor:

THE COUNTY OF COMAL  
STATE OF TEXAS

RECEIVED

JAN 25 2021

CERTIFICATION OF SINGLE FAMILY DWELLING

According to Texas Commission of Environmental Quality Rules for On-Site Sewage Facilities, the County Engineer of the Deed Records of COMAL COUNTY, TEXAS.

I

Before me this day appeared RYAN KLEBBA & MALLORY KLEBBA, being the owners of the referenced property at 1522 CIRCOLARE. They further state that the Residence and any additional living space on this property will be occupied only by a single family.

An OSSF requiring a Certification of Single Family Dwelling, will be installed on the property described as:

16 UNIT        BLOCK 1589 LOT VINTAGE OAKS AT THE VINEYARD SUBDIVISION

IF NOT IN SUBDIVISION:        ACREAGE        SURVEY

The property is owned by RYAN KLEBBA & MALLORY KLEBBA

WITNESS MY HAND ON THIS 8<sup>th</sup> OF DAY OF January, 2021.

[Signature]  
OWNER (SIGNATURE)


[Signature]  
OWNER (SIGNATURE)

SWORN TO AND SUBSCRIBED BEFORE ME ON THIS        DAY OF       , 20   BY

Ryan Klebba  
OWNER NAME (PRINTED)

MALLORY KLEBBA  
OWNER NAME (PRINTED)

[Signature]  
Notary Public Signature



Greg W. Johnson, P.E.  
170 Hollow Oak  
New Braunfels, Texas 78132  
830/905-2778

January 23, 2021

Comal County Office of Environmental Health  
195 David Jonas Drive  
New Braunfels, Texas 78132-3760

RE- SEPTIC DESIGN  
1522 CIRCOLARE  
VINTAGE OAKS AT THE VINEYARD, UNIT 16, LOT 1589  
NEW BRAUNFELS, TX 78132  
KLEBBA RESIDENCE

RECEIVED

JAN 25 2021


COUNTY ENGINEER

Ms. Brenda Ritzen/Sandra Hernandez,

The referenced property is located within the Edwards Aquifer Recharge Zone. This OSSF design will comply with requirements in the WPAP.

Temporary erosion and sedimentation controls should be utilized as necessary prior to construction. If any sensitive feature (caves, solution cavities, sink holes, etc.) is discovered during construction, activities must be suspended immediately and the applicant or his agent must immediately notify the TCEQ Regional Office. After that operations can only proceed after the Executive Director approves required additional engineered impact plans.

Designed in accordance with Chapter 285, Subchapter D, §285.40, 285.41, & 285.42, Texas Commission on Environmental Quality (Effective December 29, 2016).

 01/23/2021

Greg W. Johnson, P.E. No. 67587 / F#2585  
170 Hollow Oak  
New Braunfels, Texas 78132 - 830/905-2778





# ON-SITE SEWERAGE FACILITY SOIL EVALUATION REPORT INFORMATION

Date Soil Survey Performed: January 13, 2021

Site Location: VINTAGE OAKS at the VINEYARD, UNIT 16, LOT 1589

**RECEIVED**

Proposed Excavation Depth: N/A

**JAN 25 2021**

**Requirements:**


At least two soil excavations must be performed on the site, at opposite ends of the proposed disposal area. Locations of soil boring or dug pits must be shown on the site drawing. For subsurface disposal, soil evaluations must be performed to a depth of at least two feet below the proposed excavation depth. For surface disposal, the surface horizon must be evaluated. Describe each soil horizon and identify any restrictive features on the form. Indicate depths where features appear.

**COUNTY ENGINEER**

SOIL BORING NUMBER <u>          </u> SURFACE EVALUATION						
Depth (Feet)	Texture Class	Soil Texture	Gravel Analysis	Drainage (Mottles/ Water Table)	Restrictive Horizon	Observations
0	IV	CLAY	N/A	NONE OBSERVED	LIMESTONE @ 4"	BROWN
1						
2						
3						
4						
5						

SOIL BORING NUMBER <u>          </u> SURFACE EVALUATION						
Depth (Feet)	Texture Class	Soil Texture	Gravel Analysis	Drainage (Mottles/ Water Table)	Restrictive Horizon	Observations
0	SAME		AS		ABOVE	
1						
2						
3						
4						
5						

I certify that the findings of this report are based on my field observations and are accurate to the best of my ability.

  
Greg W. Johnson, P.E. 67587-F2585, S.E. 11561

01/13/2021  
Date

**RECEIVED**

By Brandon Olvera at 10:33 am, May 16, 2022

**Greg W. Johnson, P.E.**

170 Hollow Oak  
New Braunfels, Texas 78132  
830/905-2778

April 20, 2022

Comal County Office of Environmental Health  
195 David Jonas Drive  
New Braunfels, Texas 78132-3760


RE- Septic Design #111967  
1522 CIRCOLARE  
VINTAGE OAKS AT THE VINEYARD, UNIT 16, 1589  
NEW BRAUNFELS, TX 78132  
KLEBBA RESIDENCE

Brandon/Brenda,

Due to the lack of available application area it is necessary to have the setback from the property line to the spray at ten feet as required by TCEQ Chapter 285 rules Table X. I hereby request a variance to the twenty foot setback to property lines as required by Comal County Order and equivalent protection will be maintained by including a battery backup to the timer clock to assure sprayers to only spray during the predawn hours. In my professional opinion this variance will not pose a threat to the environment or public health.

If I can be of further assistance please contact me.


Respectfully yours,



Greg W. Johnson, P.E., F#2585

April 20, 2022

Date




10:31 am, May 16, 2022

**FIRM #2585**

**REVISED**

10:32 am, May 16, 2022



OWNER: RYAN & MALLORY KLEBBA		DRAWN BY: EJS III	
STREET ADDRESS: 1522 CIRCOLARE			
LEGAL DESC: VINTAGE OAKS at the VINEYARD		UNIT/SECTION/PHASE: 16	BLOCK: LOT: 1589
PREPARED BY: GREG W. JOHNSON, P.E. F#002585	SCALE: N.T.S.	DATE: 1/14/2021	3rd REVISION: 4/18/2022



**REVISED**

10:32 am, May 16, 2022

SLEEVE WATER LINE WITH 2"-SCH-40  
PVC PIPE WHEN ENTERING CLOSER  
THAN 10' FROM SEPTIC SYSTEM OR  
SEPTIC FIELD WHICH EXCEEDS  
TAC 30 CHAPTER 290.44(e)(B)(i).

DRIVEWAY

6 DRM RES.  
5152sf

POOL

SLEEVE SEPTIC  
LINE WITH  
SCH-40 WITHIN  
5' AND UNDER  
DRIVEWAY

SLEEVE WATER LINE  
WITH 2"-SCH-40  
PVC PIPE WHEN  
ENTERING CLOSER  
THAN 10' FROM  
SEPTIC SYSTEM OR  
SEPTIC FIELD  
WHICH EXCEEDS  
TAC 30 CHAPTER  
290.44(e)(B)(i).

1 BDRM  
DETACHED  
LIVING 723sf

LOT 1589

SPRAY AREA = 8482sf  
X= TEST HOLES


MAXX AIR M-1000  
AEROBIC TREATMENT  
PLANT

1000 GAL.  
PUMP TANK

887.08'



OWNER: RYAN & MALLORY KLEBBA		DRAWN BY: EJS III	
STREET ADDRESS: 1522 CIRCOLARE			
LEGAL DESC: VINTAGE OAKS at the VINEYARD		UNIT/SECTION/PHASE: 16	BLOCK: LOT: 1589
PREPARED BY: GREG W. JOHNSON, P.E. F#002585	SCALE: 1"=50'	DATE: 1/14/2021	3rd REVISION: 4/18/2022



F-2585



01/14/2021

#### GENERAL NOTES:

1. Plant structure material to be precast concrete and steel.
2. Maximum burial depth is 30" from slab top to grade.
3. Weight = 16,600 lbs.
4. Treatment capacity is 1,000 GPD.
5. BOD Loading = 3.00 lbs. per day.
6. 20" Ø access riser w/ lid (Typical 3). Optional extension risers available.
7. Sch. 40 PVC Air Line to Maxx Air M-1000 Air Compressor (Max. 50 Lft from Plant).

#### MINIMUM EXCAVATION DIMENSIONS:

Width: 80"  
Length: 156"



COUNTY ENGINEER

JAN 25 2021

RECEIVED

## MAXX AIR M-1000 Aerobic Treatment Plant (Assembled)

Model: M-1000

NOV, 2015  
By: A.S.

Scale:  
\* All dimensions subject to allowable specification  
variations.

Dwg. #: ADV-M1000-2

**Advantage**  
Wastewater Solutions Inc.

Advantage Wastewater Solutions Inc.  
444 A Old Hwy No 9  
Comfort, TX 78013  
830-995-3189  
fax 830-995-4051

RECEIVED

JAN 25 2021

## TANK NOTES:

Tanks must be set to allow a minimum of  $\frac{1}{8}$ " per foot fall from the residence. COUNTY ENGINEER



Tightlines to the tank shall be SCH-40 PVC.

A two way sanitary tee is required between residence and tank.

A minimum of 4" of sand, sandy loam, clay loam free of rock shall be placed under and around tanks

Tanks must be left uncovered and full of water for inspection by the permitting authority.

ALL WIRING MUST BE IN COMPLIANCE WITH  
THE MOST RECENT NATIONAL ELECTRIC CODE



01/14/2021

**TYPICAL PUMP TANK CONFIGURATION  
1000 GAL TANKS**

**FIRM #2585**





CIRCOLARE

RECEIVED

JAN 25 2021

COUNTY ENGINEER



OWNER: RYAN & MALLORY KLEBBA		DRAWN BY: EJS III	
STREET ADDRESS: 1522 CIRCOLARE			
LEGAL DESC: VINTAGE OAKS at the VINEYARD	UNIT/SECTION/PHASE: 16	BLOCK:	LOT: 1589
PREPARED BY: GREG W. JOHNSON, P.E. F#002585	SCALE: N.T.S.	DATE: 1/14/2021	REVISED: 1/20/2021

DLARE

RECEIVED

JAN 25 2021


COUNTY ENGINEER

**VOID**

LOT 1589



OWNER: RYAN & MALLORY KLEBBA		DRAWN BY: EJS III	
STREET ADDRESS: 1522 CIRCOLARE			
LEGAL DESC: VINTAGE OAKS at the VINEYARD	UNIT/SECTION/PHASE: 16	BLOCK: 16	LOT: 1589
PREPARED BY: GREG W. JOHNSON, P.E. F#002585	SCALE: 1"=50'	DATE: 1/14/2021	REVISED: 1/20/2021





Filed by  
Presidio Title  
2-2004M BD

RE-FILE TO CORRECT GRANTEE'S LAST NAME

202006018759 05/21/2020 12:00:21 PM 1/3  
202006018712 05/21/2020 09:53:40 AM 1/3

**NOTICE OF CONFIDENTIALITY RIGHTS: IF YOU ARE A NATURAL PERSON, YOU MAY REMOVE OR STRIKE ANY OR ALL OF THE FOLLOWING INFORMATION FROM ANY INSTRUMENT THAT TRANSFERS AN INTEREST IN REAL PROPERTY BEFORE IT IS FILED FOR RECORD IN THE PUBLIC RECORDS: YOUR SOCIAL SECURITY NUMBER OR YOUR DRIVER'S LICENSE NUMBER.**

**SPECIAL WARRANTY DEED WITH VENDOR'S LIEN**

THE STATE OF TEXAS

§

KNOW ALL MEN BY THESE PRESENTS

COUNTY OF COMAL

§

§

**GRANTOR: SOUTHSTAR AT VINTAGE OAKS, LLC**  
1118 Vintage Way  
New Braunfels, Texas 78132

**GRANTEE: ~~RYAN KLEBBA~~ and MALLORY KLEBBA**  
7926 Castle Peak Trail  
Austin, Texas 78726

**RYAN KLEBBA**

COUNTY ENGINEER

That Grantor, for and in consideration of the sum of TEN AND NO/100 DOLLARS (\$10.00) cash and other good and valuable consideration to it in hand paid by Grantee the receipt of which is hereby acknowledged and confessed, has GRANTED, SOLD and CONVEYED, and by these presents does hereby GRANT, SELL and CONVEY, unto the said Grantee, the following described property, to-wit:

**Lot 1589, VINTAGE OAKS AT THE VINEYARD, UNIT 16, Comal County, Texas, according to plat thereof recorded in Document #201706026888, Map and Plat Records of Comal County, Texas (hereinafter referred to as the "Property").**

TO HAVE AND TO HOLD the Property, together with all and singular the rights and appurtenances thereto in anyway belonging to Grantor, unto Grantee, its heirs and assigns forever; and Grantor does hereby bind itself, its heirs, successors and assigns, to WARRANT AND FOREVER DEFEND all and singular the Property unto the Grantee, its heirs and assigns, against every person whomsoever lawfully claiming or to claim the same or any part thereof, when the claim is by, through or under Grantor, but not otherwise.

IT IS expressly UNDERSTOOD, ACKNOWLEDGED and AGREED that Grantor hereby RESERVES and EXCEPTS from this conveyance all oil, gas and other minerals of any type or form including all rights to ingress and egress as well as other rights appurtenant to the minerals and the mineral estate owned by Grantor, and does not transfer the minerals and the appurtenant rights thereto to Grantee.

THIS CONVEYANCE IS MADE AND ACCEPTED by Grantee SUBJECT TO (i) taxes for the current year, which have been prorated as of the date of closing, the payment of which Grantee assumes; (ii) all subsequent tax assessments for the current year the payment of which Grantee assumes; (iii) the Declaration of Conditions, Covenants and Restrictions for Vintage Oaks at the Vineyard filed in the Official Real Property Records, Comal County, Texas, all other restrictions, covenants, conditions easements, reservations, leases, mineral severances, and other instruments that affect the Property and as may or may not be shown in the public records of Comal County, Texas; (iv) all zoning laws, regulations and ordinances of municipal and/or other

RECEIVED

governmental authorities that affect the Property and (v) the items listed below as  
Permitted Exceptions:

1. Subject to the Declaration of Conditions, Covenants and Restrictions for Vintage Oaks at the Vineyard, recorded at Clerk's Document #200706000771, annexed by Document #201706027258, amended or supplemented by Document #201106044284, Document #201206032310, Document #201406032083; Document #201406036864; Document #201406037322, Document #201606000890, Document #201506020343; Document #201606034595; Document #201606048482; Document #201706028668; Document #201706028671; Document #201706038551; Document #201706050096, Document #201706050099; Document #201706050104; Document #201706050125; Document #201806013767, and the Assignment of Declarant Rights filed at Document #201206016339, Official Real Property Records, Comal County, Texas.

2. Subject to those items, restrictions, building setback lines, easements and Notes shown on the plat recorded in Document #201706026888, Official Map and Plat Records of Comal County, Texas as well as those setbacks included/described in the Declaration of Conditions, Covenants and Restrictions for Vintage Oaks at the Vineyard and contained in the Architectural and Site Guidelines for Vintage Oaks recorded at Document #201606020343, and as amended in Document #201606034595, and Document #201606008119 and supplemented by Document #201706050104, all in the Official Public Records, Comal County, Texas:

- a. Subject to a 50-foot building setback line from the front and rear property lines.
- b. Subject to a 10-foot side property line building setback except on corner lots wherein the street-side corner shall have a 25-foot setback;
- c. Subject to a 10-foot wide Public Utility and Drainage easement adjacent to all non-street lot lines.
- d. Subject to Public Utility Easement, 20 feet from the front property line and 10 feet from the side and rear property lines.

3. Edwards Aquifer Protection Plan recorded in Document #201406018500 and Document #201506008181, Official Public Records of Comal County, Texas.

When the context requires, singular nouns and pronouns include the plural.

EXECUTED on the 21 day of May, 2020.

SOUTHSTAR AT VINTAGE OAKS, LLC

By:   
Thad Rutherford, Senior Vice President-  
Operations

**ACKNOWLEDGMENT**

STATE OF TEXAS

COUNTY OF

Comal

§  
§  
§

This Special Warranty Deed with Vendor's Lien was acknowledged before me on the 21 day of May, 2020, by Thad Rutherford, Senior Vice President-Operations of SOUTHSTAR AT VINTAGE OAKS, LLC, Grantor in the above instrument on behalf of said entity.



  
NOTARY PUBLIC, STATE OF TEXAS

RECEIVED

JAN 25 2021

COUNTY ENGINEER

Filed and Recorded  
Official Public Records  
Bobbie Koepp, County Clerk  
Comal County, Texas  
05/21/2020 12:00:21 PM  
LAURA 3 Pages(s)  
202006018759



*Bobbie Koepp*

Filed and Recorded  
Official Public Records  
Bobbie Koepp, County Clerk  
Comal County, Texas  
05/21/2020 09:53:40 AM  
LAURA 3 Pages(s)  
202006018712



*Bobbie Koepp*

**PS Septic Supply & Service**  
**23011 FM 306**  
**Canyon Lake, TX 78133**

Phone: (830) 850-0080  
Fax: (830) 935-4932

Printed: 11/2/2022

Insp ID #: 22385

Permit #: **114288**

**To: Ryan & Mallory Klebba**  
**1522 Circolare**  
**New Braunfels, TX 78132**

Main Phone: (512) 289-4469

Work:

Cell Phone:

Alt Cell:

Customer ID: 4745

Contract Dates: 6/28/2022 - 6/28/2025

Scheduled Date: 10/28/2022

Inspection 1 of 9

Installed: 6/28/2022

Warranty End: 6/28/2025

Agency: Comal County

County: Comal County

Mfg / Brand: - MAXX AIR

Sub: Vintage Oaks at the Vineyard

Treatment Type: Aerobic

Disposal: Surface Application

GPS Coordinates: Latitude: 29.80626 Longitude: -98.25341

**Service Type: Scheduled Inspection**

**Visit Date: 10/31/2022**

**Method: Grab**

**Technician: Not Assigned**

**Maint. Provider: Ryan Seidensticker**

☒ This counts as a type of "Scheduled Inspection"

**Entered By: Ashley Spitzenberger**

☒ Copy emailed to Customer

Customer Emailed: 11/2/2022

**Aerators: Operational**

**Filters: Operational**

**Irrigation Pumps: Operational**

**Disinfection Device: Operational**

**Chlorine Supply: Operational**

**Chlorine Residual: .78**

**Sludge Levels**

**For Tank 1: 12**

**For Tank 2: NA**

**Electric Circuits: Operational**

**Distribution System: Operational**

**Sprayfield Veg: Operational**

**Tank Lid / Riser: Secured**

**Insp. Port / Plug: Secured**

**Alarm: Operational**

**Comments**

☒ **Service Completed**

- Scum on pretreatment 1 - Red switch secure - Technician Secured the Tank Lid and/or Riser prior to leaving location. - Inspection Port Plug was noted as Secured prior to leaving. - Copy emailed to the customer on 11/2/2022.

Site: 1522 Circolare, New Braunfels, TX 78132

**Provider: *Christopher Ryan Seidensticker***  
***PS Septic Supply & Service***

License Info: MP0001708 Expires:

**PS Septic Supply & Service**  
**23011 FM 306**  
**Canyon Lake, TX 78133**

Phone: (830) 850-0080  
Fax: (830) 935-4932

Printed: 2/9/2023

Insp ID #: 25415

Permit #: **114288**

**To: Ryan & Mallory Klebba**  
**1522 Circolare**  
**New Braunfels, TX 78132**

Main Phone: (512) 289-4469

Work:

Cell Phone:

Alt Cell:

Customer ID: 4745

Contract Dates: 6/28/2022 - 6/28/2025

Scheduled Date: 2/28/2023

Inspection 2 of 9

Installed: 6/28/2022

Warranty End: 6/28/2025

Agency: Comal County

County: Comal County

Mfg / Brand: - MAXX AIR

Sub: Vintage Oaks at the Vineyard

Treatment Type: Aerobic

Disposal: Surface Application

GPS Coordinates: Latitude: 29.735514 Longitude: -98.261155

**Service Type: Scheduled Inspection**

**Visit Date: 2/8/2023**

**Method: Grab**

**Technician: Not Assigned**

**Maint. Provider: Ryan Seidensticker**

☒ This counts as a type of "Scheduled Inspection"

**Entered By: Ashley Spitzenberger**

☒ Copy emailed to Customer

Customer Emailed: 2/9/2023

**Aerators: Operational**

**Filters: Operational**

**Irrigation Pumps: Operational**

**Disinfection Device: Operational**

**Chlorine Supply: Operational**

**Chlorine Residual: .26**

**Sludge Levels**

**For Tank 1: 4**

**For Tank 2: NA**

**Electric Circuits: Operational**

**Distribution System: Operational**

**Sprayfield Veg: Operational**

**Tank Lid / Riser: Secured**

**Insp. Port / Plug: Secured**

**Alarm: Operational**

**Comments**

☒ **Service Completed**

- Scum on pretreatment 2 - Broke airline on sch for 02/09/23 to repair - Technician Secured the Tank Lid and/or Riser prior to leaving location. - Inspection Port Plug was noted as Secured prior to leaving. - Copy emailed to the customer on 2/9/2023.

Site: 1522 Circolare, New Braunfels, TX 78132

**Provider: *Christopher Ryan Seidensticker***  
***PS Septic Supply & Service***

License Info: MP0001708 Expires:



# Luna Environmental

4222 FM 482

New Braunfels, TX 78132

(830) 312-8776

sherrie@lunaenvironmental.com

Printed:7/8/2023

**Permit: 114288**

Site: 1522 Circolare, New Braunfels, TX 78132

Main Phone: 5122894469

## Ryan & Mallory Klebba

1522 Circolare

New Braunfels, TX 78132

Agency: Comal County

County: Comal County

Subdivision: Vintage Oaks at the Vineyard

---

System Info: MFG: <u>Brand: MAXX AIR</u>	Customer ID: <u>6144</u>
Treatment Type: <u>Aerobic</u>	Disposal Type: <u>Surface Application</u>
Installed: <u>6/28/2022</u>	Warranty Expiration: <u>6/28/2025</u>
Insp ID: <u>29755</u>	

Visit Details

<b>Visit Date: <u>7/7/2023</u></b>	<b>Entered By: Nicole Loria</b>	GPS Lat: 29.735514 GPS Long: -98.261155
Scheduled Date: <u>6/28/2023</u>	Contract Starts: <u>6/28/2022</u>	Customer Emailed: <u>7/8/2023</u>
Entered On: <u>7/8/2023</u>	Contract Ends: <u>6/28/2025</u>	

### Visit Results

#### Service Type: Scheduled Inspection

Count: Inspection 3 of 9

Method: Grab

License #

Expires

Technician: Not Assigned

Provider: Luna Environmental, LLC

☒ Service Completed

---

Aerators: <u>Operational</u>	Sludge Level Tank 1: <u>12</u>
Filters: <u>Operational</u>	Sludge Level Tank 2: <u>N/A</u>
Irrigation Pumps: <u>Operational</u>	
Disinfection Device: <u>Operational</u>	
Chlorine Supply: <u>Operational</u>	
Chlorine Residual: <u>.15</u>	

Electric Circuits: <u>Operational</u>	Tank Lid / Riser: <u>Secured</u>
Distribution System: <u>Operational</u>	Insp. Port / Plug: <u>Secured</u>
Drip/Sprayfield Veg: <u>Operational</u>	

Alarm: Operational

PSI Pressure: 2.1

### Comments

- Scum on pretreatment 1-replaced reservoir tank - Technician Secured the Tank Lid and/or Riser prior to leaving location. - Inspection Port Plug was noted as Secured prior to leaving.ZB - Copy emailed to the customer on 7/8/2023.