staller Name:	OSSF Installer #:	
1st Inspection Date:	2nd Inspection Date:	3rd Inspection Date:
Inspector Name:	Inspector Name:	Inspector Name:

Perm	it#:		Address:				
No.	Description	Answer	Citations	Notes	1st Insp.	2nd Insp.	3rd Insp.
1	SITE AND SOIL CONDITIONS & SETBACK DISTANCES Site and Soil Conditions Consistent with Submitted Planning Materials		285.31(a) 285.30(b)(1)(A)(iv) 285.30(b)(1)(A)(v) 285.30(b)(1)(A)(iii) 285.30(b)(1)(A)(ii) 285.30(b)(1)(A)(i)				
2	SITE AND SOIL CONDITIONS & SETBACK DISTANCES Setback Distances Meet Minimum Standards		285.91(10) 285.30(b)(4) 285.31(d)				
3	SEWER PIPE Proper Type Pipe from Structure to Disposal System (Cast Iron, Ductile Iron, Sch. 40, SDR 26)		285.32(a)(1)				
4	SEWER PIPE Slope from the Sewer to the Tank at least 1/8 Inch Per Foot		285.32(a)(3)				
	SEWER PIPE Two Way Sanitary - Type Cleanout Properly Installed (Add. C/O Every 100' &/or 90 degree bends)		285.32(a)(5)				
5	PRETREATMENT Installed (if required) TCEQ Approved List PRETREATMENT Septic Tank(s) Meet Minimum Requirements		285.32(b)(1)(G) 285.32(b)(1)(E)(iii) 285.32(b)(1)(E)(iv) 285.32(b)(1)(F) 285.32(b)(1)(C)(i) 285.32(b)(1)(C)(ii) 285.32(b)(1)(D) 285.32(b)(1)(E) 285.32(b)(1)(E) 285.32(b)(1)(E) 285.32(b)(1)(E)(ii)(II) 285.32(b)(1)(E)(ii)(II) 285.32(b)(1)(E)(ii)(II) 285.32(b)(1)(E)(ii)(II)				
7	PRETREATMENT Grease Interceptors if required for commercial		285.34(d)				


Inspector Notes:

N-	December 41	A mar	Citotiana	Net	1 at 1	2 m d 1	7 mal 1
No.	Description SEPTIC TANK Tank(s) Clearly	Answer	Citations	Notes	1st Insp.	2nd Insp.	3rd Insp.
8	Marked SEPTIC TANK IsingleTank, 2Compartments Provided withBaffle SEPTIC TANK Inlet Flowline Greater than3" and "T" Provided on Inlet and OutletSEPTIC TANK Septic Tank(s) MeetMinimum Requirements		285.32(b)(1) (E)285.91(2)285.32(b)(1) (F)285.32(b)(1)(E) (iii)285.32(b)(1)(E)(ii) (I)285.32(b)(1)(E) (i)285.32(b)(1)(E) (i)285.32(b)(1)(C) (ii)285.32(b)(1)(C) (ii)285.32(b)(1)(C) (ii)285.32(b)(1) (B)285.32(b)(1) (A)285.32(b)(1)(E)(iv)				
1	ALL TANKS Installed on 4" Sand Cushion/ Proper Backfill Used		285.32(b)(1)(F) 285.32(b)(1)(G) 285.34(b)				
	SEPTIC TANK Inspection / Clean Out Port & Risers Provided on Tanks Buried Greater than 12" Sealed and Capped		285.38(d)				
	SEPTIC TANK Secondary restraint system providedSEPTIC TANK Riser permanently fastened to lid or cast into tank SEPTIC TANK Riser cap protected against unauthorized intrusions		285.38(d) 285.38(e)				
	SEPTIC TANK Tank Volume Installed						
12							
	PUMP TANK Volume Installed						
1	AEROBIC TREATMENT UNIT Size Installed						
14							
	AEROBIC TREATMENT UNIT Manufacturer AEROBIC TREATMENT UNIT Model Number						
15	DISPOSAL SYSTEM Absorptive		285.33(a)(4) 285.33(a)(1) 285.33(a)(2) 285.33(a)(3)				
17	DISPOSAL SYSTEM Leaching Chamber		285.33(a)(1) 285.33(a)(3) 285.33(a)(4) 285.33(a)(2)				
18	DISPOSAL SYSTEM Evapo- transpirative		285.33(a)(3) 285.33(a)(4) 285.33(a)(1) 285.33(a)(2)				
18			203.33(a)(2)				

	O331 inspection sheet						
No.	Description	Answer	Citations	Notes	1st Insp.	2nd Insp.	3rd Insp.
19	DISPOSAL SYSTEM Drip Irrigation		285.33(c)(3)(A)-(F)				
20	DISPOSAL SYSTEM Soil Substitution		285.33(d)(4)				
21	DISPOSAL SYSTEM Pumped Effluent		285.33(a)(4) 285.33(a)(3) 285.33(a)(1) 285.33(a)(2)				
22	DISPOSAL SYSTEM Gravelless Pipe		285.33(a)(3) 285.33(a)(2) 285.33(a)(4) 285.33(a)(1)				
23	DISPOSAL SYSTEM Mound		285.33(a)(3) 285.33(a)(1) 285.33(a)(2) 285.33(a)(4)				
24	DISPOSAL SYSTEM Other (describe) (Approved Design)		285.33(d)(6) 285.33(c)(4)				
	DRAINFIELD Absorptive Drainline 3" PVC or 4" PVC						
26	DRAINFIELD Area Installed						
	DRAINFIELD Level to within 1 inch per 25 feet and within 3 inches over entire excavation		285.33(b)(1)(A)(v)				
	DRAINFIELD Excavation Width DRAINFIELD Excavation Depth DRAINFIELD Excavation Separation DRAINFIELD Depth of Porous Media DRAINFIELD Type of Porous Media						
	DRAINFIELD Pipe and Gravel - Geotextile Fabric in Place		285.33(b)(1)(E)				
	DRAINFIELD Leaching Chambers DRAINFIELD Chambers - Open End Plates w/Splash Plate, Inspection Port & Closed End Plates in Place (per manufacturers spec.)		285.33(c)(2)				
	LOW PRESSURE DISPOSAL SYSTEM Adequate Trench Length & Width, and Adequate Separation Distance between Trenches		285.33(d)(1)(C)(i)				

	I I			- 		I	I
No.	Description	Answer	Citations	Notes	1st Insp.	2nd Insp.	3rd Insp.
32	EFFLUENT DISPOSAL SYSTEM Utilized Only by Single Family Dwelling EFFLUENT DISPOSAL SYSTEM Topographic Slopes < 2.0% EFFLUENT DISPOSAL SYSTEM Adequate Length of Drain Field (1000 Linear ft. for 2 bedrooms or Less & an additional 400 ft. for each additional bedroom) EFFLUENT DISPOSAL SYSTEM Lateral Depth of 18 inches to 3 ft. & Vertical Separation of 1ft on bottom and 2 ft. to restrictive horizon and ground water respectfully EFFLUENT DISPOSAL SYSTEM Lateral Drain Pipe (1.25 - 1.5" dia.) & Pipe Holes (3/16 - 1/4" dia. Hole Size) 5 ft. Apart		285.33(b)(3)(A) 285.33(b)(3)(A) 285.33(b)(3) (B)285.91(13) 285.33(b)(3)(D) 285.33(b)(3)(F)				
	AEROBIC TREATMENT UNIT IS Aerobic Unit Installed According to Approved Guidelines.		285.32(c)(1)				
	AEROBIC TREATMENT UNIT Inspection/Clean Out Port & Risers Provided AEROBIC TREATMENT UNIT Secondary restraint system provided AEROBIC TREATMENT UNIT Riser permanently fastened to lid or cast into tank AEROBIC TREATMENT UNIT Riser cap protected against unauthorized intrusions						
	AEROBIC TREATMENT UNIT Chlorinator Properly Installed with Chlorine Tablets in Place.						
	PUMP TANK Is the Pump Tank an approved concrete tank or other acceptable materials & construction PUMP TANK Sampling Port Provided in the Treated Effluent Line PUMP TANK Check Valve and/or Anti- Siphon Device Present When Required PUMP TANK Audible and Visual High Water Alarm Installed on Separate Circuit From Pump PUMP TANK Inspection/Clean Out						
37	Port & Risers Provided PUMP TANK Secondary restraint system provided PUMP TANK Riser permanently fastened to lid or cast into tank PUMP TANK Riser cap protected against unauthorized intrusions						
38	PUMP TANK Secondary restraint system provided PUMP TANK Electrical						
	Connections in Approved Junction Boxes / Wiring Buried						

	<u> </u>						
No.	Description	Answer	Citations	Notes	1st Insp.	2nd Insp.	3rd Insp.
	APPLICATION AREA Distribution Pipe, Fitting, Sprinkler Heads & Valve Covers Color Coded Purple?		285.33(d)(2)(G)(iii)(II) 285.33(d)(2)(G)(iii)(III) 285.33(d)(2)(G)(v) 285.33(d)(2)(G)(iii) 285.33(d)(2)(G)(iv) 285.33(d)(2)(G)(i) 285.33(d)(2)(G)(iii) 285.33(d)(2)(G)(iii)(I)				
	APPLICATION AREA Low Angle Nozzles Used / Pressure is as required APPLICATION AREA Acceptable Area, nothing within 10 ft of sprinkler heads? APPLICATION AREA The Landscape Plan is as Designed		285.33(d)(2)(G) (i)285.33(d)(2) (A)285.33(d)(2)(F)				
	APPLICATION AREA Area Installed						
	PUMP TANK Meets Minimum Reserve Capacity Requirements						
	PUMP TANK Material Type & Manufacturer						
	PUMP TANK Type/Size of Pump Installed						



Permit of Authorization to Construct an On-Site Sewage Facility Permit Valid For One Year From Date Issued

Permit Number: 118239

Issued This Date: 04/29/2025

This permit is hereby given to: SQR DEVELOPMENT LLC

To start construction of a private, on-site sewage facility located at:

424 VALLEY RDG

CANYON LAKE, TX 78133

Subdivision: Scenic Heights

Unit: 2

Lot: 521

Block: NA

Acreage: 0.1200


APPROVED MINIMUM SIZES AS PER ATTACHED DESIGN

Type of System: Aerobic

Drip Irrigation

This permit gives permission for the construction of the above referenced on-site facility to commence. Installation must be completed by an installer holding a valid registration card from the Texas Commission on Environmental Quality (TCEQ). Installation and inspection must comply with current TCEQ and County requirements.

Call (830) 608-2090 to schedule inspections.





ON-SITE SEWAGE FACILITY APPLICATION

195 DAVID JONAS DR NEW BRAUNFELS, TX 78132 (830) 608-2090 WWW.CCEO.ORG

			Permit Nu	mber1182	239
1. APPLICANT	/ AGENT INFORMATION		Marina kana	- Develonmen	t and Consulting
Owner Name	SQR DEVELOPMENT LLC	Agent Name			
Mailing Address	s 2912 BARBED WIRE ST	Agent Address			
City, State, Zip	Round Rock, TX 78664	City, State, Zip			
Phone #	512-590-3411	Phone #	8306605498		100000000000000000000000000000000000000
Email	chad.f@2x2capitalmanagement.com	Email	bridgewayllo	:1@gmail.com	
2. LOCATION				521	
Subdivision Na	me SCENIC HEIGHTS	ι	Jnit 2	Lot_521	_ Block
Survey Name /	Abstract Number		Jan Bal	Acreage	
Address 424	Valley Ridge	City Canyon La	ake	State TX	Zip <u>78133</u>
3. TYPE OF DE	VELOPMENT				
X Single Fa	mily Residential				
Type of (Construction (House, Mobile, RV, Etc.) House			_	
Number	of Bedrooms3				
Indicate	Sq Ft of Living Area 2200				
Non-Sing	le Family Residential				
(Planning	materials must show adequate land area for doubling	the required land nee	ded for treatme	ent units and disp	osal area)
Type of F	Facility				
Offices, I	Factories, Churches, Schools, Parks, Etc Indica	ate Number Of Occ	upants		
	ants, Lounges, Theaters - Indicate Number of Se				
	otel, Hospital, Nursing Home - Indicate Number of				
	railer/RV Parks - Indicate Number of Spaces				
Miscellar		SCHOOL STREET		Service Life by	
-	4/ 1/				
	ost of Construction: \$ 264,000	(Structure Only)			
Is any portion	n of the proposed OSSF located in the United St	ates Army Corps of	Engineers (U	SACE) flowage	easement?
☐ Yes 🔀	No (If yes, owner must provide approval from USACE f	for proposed OSSF impre	ovements within t	he USACE flowage	e easement)
Source of Wa	ater Nublic Private Well Rainwa	ater			
4. SIGNATURE	OF OWNER				
The completed	oplication, I certify that: application and all additional information submitted do nat I am the property owner or I possess the appropria	pes not contain any fai ate land rights necessa	se information ary to make the	and does not con permitted improv	ceal any material vements on said
Authorization is site/soil evaluation I understand that by the Comal Com	hereby given to the permitting authority and designate ion and inspection of private sewage facilities at a permit of authorization to construct will not be issupported Damage Prevention Order.	ued until the Floodplai	n Administrator	has performed th	ne reviews required
affirmatively co	onsent to the online posting/public release of my e-ma	ail address associated	with this permit	t application, as a	pplicable.
Signature of C	wner	Date	' /		Page 1 of



ON-SITE SEWAGE FACILITY APPLICATION

195 DAVID JONAS DR NEW BRAUNFELS, TX 78132 (830) 608-2090 <u>WWW.CCEO.ORG</u>

Planning Materials & Site Evaluation as Required Completed By Christine Nixon, PE	REVISED
System Description AerobicDrip	12:11 pm, Mar 07, 2025
Size of Septic System Required Based on Planning Materials & Soil Evaluation	
Tank Size(s) (Gallons) 1245 Gal Absorption/Application Area (Sq Ft) 1	200 Sq Ft
Gallons Per Day (As Per TCEQ Table III) 240 gpd (Sites generating more than 5000 gallons per day are required to obtain a permit through TCEQ.)	
Is the property located over the Edwards Recharge Zone? Yes X No (If yes, the planning materials must be completed by a Registered Sanitarian (R.S.) or Professional Engineer (P.E.))	
Is there an existing TCEQ approved WPAP for the property? \square Yes $\boxed{\chi}$ No	
(If yes, the R.S. or P.E. shall certify that the OSSF design complies with all provisions of the existing WPAP.)	
If there is no existing WPAP, does the proposed development activity require a TCEQ approved WPAP? (If yes, the R.S. or P.E. shall certify that the OSSF design will comply with all provisions of the proposed WPAP. A Representation because of the proposed OSSF until the proposed WPAP has been approved by the appropriate regional office.)	
Is the property located over the Edwards Contributing Zone? X Yes No	
Is there an existing TCEQ approval CZP for the property? Yes X No	
(If yes, the P.E. or R.S. shall certify that the OSSF design complies with all provisions of the existing CZP.)	
If there is no existing CZP, does the proposed development activity require a TCEQ approved CZP?	Yes X No
(If yes, the R.S. or P.E. shall certify that the OSSF design will comply with all provisions of the proposed CZP. A Pe issued for the proposed OSSF until the CZP has been approved by the appropriate regional office.)	rmit to Construct will not be
Is this property within an incorporated city? Yes X No	
If yes, indicate the city:	
By signing this application, I certify that:	
- The information provided above is true and correct to the best of my knowledge.	
- I affirmatively consent to the online posting/public release of my e-mail address associated with this permit appli	cation, as applicable.
03/04/ <u>202</u> 5	
Signature of Designer Date	

AFFIDAVIT TO THE PUBLIC

THE COUNTY OF COMAL STATE OF TEXAS

CERTIFICATION OF OSSF REQUIRING MAINTENANCE

According to Texas Commission on Environmental Quality Rules for On-Site Sewage Facilities (OSSF's), this document is filed in the Deed Records of Comal County, Texas.

The Texas Health and Safety Code, Chapter 366 authorizes the Texas Commission on Environmental Quality (commission) to regulate on-site sewage facilities (OSSFs). Additionally, the Texas Water Code (TWC), § 5.012 and § 5.013, gives the commission primary responsibility for implementing the laws of the State of Texas relating to water and adopting rules necessary to carry out its powers and duties under the TWC. The commission, under the authority of the TWC and the Texas Health and Safety code, requires owner's to provide notice to the public that certain types of OSSFs are located on specific pieces of property. To achieve this notice, the commission requires a recorded affidavit. Additionally, the owner must provide proof of the recording to the OSSF permitting authority. This recorded affidavit is not a representation or warranty by the commission of the suitability of this OSSF, nor does it constitute any guarantee by the commission that the appropriate OSSF was installed.

An OSSF requiring a maintenance contract, according §285.91(12) will be installed on the property described		
Scenic Heights 2, Lot 521		
	000.0	
The property is owned by (Insert owner's full name):	SQR Develop	ement LLC
This OSSF must be covered by a continuous maintena the initial two-year service policy, the owner of an aerot residence shall either obtain a maintenance contract wipersonally.	oic treatment sys	tem for a single family
Upon sale or transfer of the above-described property, transferred to the buyer or new owner. A copy of the plobtained from the Comal County Engineer's Office.		
WITHESS BY HAND(S) ON THIS 03 DAY OF	January	, 2025_
Chadwick Fox		
Owner(s) signature(s)		
SWORN TO AND SUBSCRIBED BEFORE ME ON TH	is_3_day	OF
Notary Public, State of Texas		MARISA KANE My Notary ID # 131307209
Filed and Recorded		Expires October 6, 2025
Official Public Records	1	

Bobbie Koepp, County Clerk

Bobbie Koepp

Comal County, Texas 01/03/2025 02:03:15 PM TRACY 1 Pages(s) 202506000246


AFFIDAVIT OF A SINGLE FAMILY RESIDENCE

THE COUNTY OF Coma	
STATE OF TEXAS	
Before me, the undersigned authority, on this day personally appeared— <u>Cha</u>	adwick Fox
, who a	fter being duly sworn, upon
oath states that he/ she is the owner of record of those certain tracts or parcel situated in Comal County, Texas, and being more particularly described as follows:	s of land lying and being
SCENIC HEIGHTS 2, LOT 521	
The undersigned further states the following described structures	
Residential Family House	
on the said residential property are for one family and are routinely used only of that one family. WINESS BY MANDIS) ON THE 1040 DAY OF	
Chadwick Fox	
wner(s) signature(s)	
WORN TO AND SUBSCRIBED BEFORE ME ON THIS	
DAY OF <u>December</u> 20 24	
the form	FAITH SPEKER NOTATE ID 81 216985
otary Signature	My Commission Expl July 15, 2028
tary's Printed Name: <u>Faith Spence</u>	Filed and Re

My Commission Expires: _



ded Official Public Records **Bobbie Koepp, County Clerk** Comal County, Texas 12/26/2024 09:00:23 AM TERRI 1 Pages(s) 202406039086





Red Stag Septic Services LLC

P: 210-364-8562

E: redstagseptic@gmail.com

A: 439 Russian Sage New Braunfels Tx,78130



Septic System Maintenance Contract

Customer Name: SQR Development LLC - Chadwick Fox
Customer Address: Lot 521 - 424 Valley Ridge, Canyon Lake, TX
Customer Number:
Reg Stag Septic Services LLC will operate and maintain the aerobic septic system at the address above for 2 _year(s) beginning at License to Operate and ending at 2 years from License to Operate.
During the period we will provide a total of 8 visual inspections occurring within the months circled below: JAN FEB NAR APR MAY JUN JUL AUG SEP OCT NOV DEC

- These inspections will consist of:
 - Determining if tank needs to be pumped.
 - Inspecting all floats, controls, and electrical components
 - Inspecting pumps and aerators
 - Clean filters

The property owner will be responsible for maintaining the chlorinator. Any additional work that is needed is <u>not</u> included in the service fee and will be completed and billed separately. Due to state regulations, if customer refuses to repair damaged or broken equipment necessary for the system's proper daily function; we will be forced to report customer to the appropriate county or city licensing authorities for noncompliance.

All complaints by the property owner regarding the operations of the system will be responded to within 3 business days at the site location listed above.

Service Fee **\$300.00**

h	Francisco Ruiz MP0002663
Customer Signature	Maintenance Provider
03/12/2025	3/12/2025
Date	Date

COMAL COUNTY ENVIRONMENTAL HEALTH DEPARTMENT OSSF SOIL EVALUATION FORM

Owners Name	2x2 Capital Development		
Physical Address:	Valley Ridge, Canyon Lake, TX 78133		
Name of Site Evaluator_	Christine Nixon		
Date Performed:	March 1, 2022	Proposed Excavation Depth:	36" max

Requirements:

At least two soil excavations must be performed on the site, at opposite ends of the proposed disposal area.

Locations of soil evaluation must be shown on the application site drawing or designer's site drawing

For subsurface disposal, soil evaluations must be performed to a depth of at least two feet below the proposed excavation depth. For surface disposal, the surface horizon must be evaluated.

Please describe each soil horizon and identify any restrictive features in the space provided below. Draw lines at the appropriate depths.

SOIL BORING NUMBER						
Depth (Feet)			Structure (For Class III- blocky, platy or massive Drainage (Mottles/ Water Table)		Restrictive Horizon	Observations
0	1-4" Top Soil 4" – below Rock	<30%	Ty III			No indication of ground water

SOIL BORING NUMBER_							
Depth (Feet)			Structure (For Class III- blocky, platy or massive	Drainage Restrictive (Mottles/ Horizon Water Table)		Observations	
	Top Soil 4" – below Rock 3 4		Ту Ш			No indication of ground water	

FEATURES OF SITE AREA

Presence of 100 year flood zone YES NO	X
Presence of adjacent ponds, streams, water impoundments YES NO	_
Existing or proposed water well in nearby area YES NO	X
Organized sewage available to lot or tract YESNO	X
Recharge features within 150 feet YESNO	X

I certify that the above statements are true and are based on my own field observations.

Signature of Site Evaluator

March 1, 2022

Date



BURRIER NIXON ENGINEERS

Reg. No. F-24967 CHRISTINE NIXON, P.E. 9901 BRODIE LN, STE 160, PMB 195 AUSTIN, TX 78748 (512) 694-0537



April 24, 2025

SITE DESCRIPTION / EVALUATION

The site is located in Comal County, 424 (Lot 521) Valley Ridge, Canyon Lake, TX 78133. The owner is SQR Development, LLC. The site is considered unsuitable for a standard sub-surface septic system (see attached site evaluation). A drip irrigation is being designed. The sizing was determined as specified in the Texas Commission on Environmental Quality On-Site Sewage Facility-Chapter 285.33 © (2) (D). The proper performance of the OSSF cannot be guaranteed even though all provision of the standards have been generally complied with. The on-site sewage facility irrigation area placed on the flattest portion of the site. The site is located outside the regulatory 100 year flood plain. Vegetation at the proposed site consists of natural grasses and no recharge features are located within the area. The system is being designed for a three-bedroom home less than 2500 square feet (Q=240 gpd). Water saving devices will be utilized, and public water is being supplied.

SYSTEM DESCRIPTION

The on-site sewage facility will utilize a proprietary treatment plant with drip irrigation disposal. A timer will be set to dose for 563 seconds (9.4 minutes) every three hours. That will deliver the needed 30 gallons 8 times per day. Additionally, the floats will be adjusted according to the attached pump tank cross section. Wastewater from the residence will flow to a pretreatment/trash tank, then to the treatment plant. After treatment, the effluent will flow to a pump tank for discharge through a drip irrigation pressure emitter system. The surface of the existing soil must be scarified (any large rocks greater than 6" in diameter must be removed during scarification and replaced with suitable soil). Because there is limited suitable soil, the installer will be required to place 12 inches of Type III soil on the natural ground before laying the drip tubing. The drip lines will be placed on the fill and then covered with an additional 8" of soil (Ty III). A spin filter will be installed in the pressure lines that is 140 mesh or greater. A pressure regulator (set at 50 psi) with bypass will be installed in the supply line (see diagram). The drip emitter line must be flushed periodically. This is accomplished by opening the return line from the drip field to the pre-treatment tank. In this process, the velocity of water moving through the tubing must be at least 2 feet per second. To prevent plugging of the emitters, it is recommended that field flushing take place on a regular basis. Field flushing should be done at least several times per year. This will clean out the emitter lines, and will help prevent emitter blockage, slime buildup, and inorganic scale buildup. Gate valves shall be placed on the drip line before it connects to the return line. Each gate valve must be opened separately for flushing through each zone. THE FLUSH RETURN SHOULD RETURN TO THE TRASH TANK. All drip line connections to manifolds should have at least 18" of PVC (see detail). When running dipper lines that take turns, loops or series of loops back to the return flush line before making a connection, make a transition to solid tubing that will resist kinking and will not emit effluent in the turns (see detail).

The installer will provide the owner with an owner's manual containing the maintenance and operation instructions.

CALCULATIONS AND SPECIFICATIONS

1. Required Drip Area (SA) = Q / Ri

where Q = Ri =

daily usage rate effluent loading rate in

gal/sq. ft./day

Therefore:

S.A. = 240 / 0.2

S.A. = 1200 sq. ft

2. Septic Tank Minimum Liquid Cana

Septic Tank Minimum Liquid Capacity

Note: The trash tank and pump tank must comply with the applicable structural requirements from TCEQ OSSF Rules Sect. 285.32 and 285.34 (b)

Since Q = 240 gal / day

Required Septic Tank Volume = 750 gallons Aerobic Treatment Capacity = 360 gpd

System will consist of:

400 gal. Single compartment pretreatment tank 621 gallon per day Pro Flo 500 SLPT2 Aeration Chamber tank

<u>+ 224 gallon per day Pro Flo 500 SLPT2 Clarifier Tank</u> =1245 gal. liquid capacity

Risers 2" above grade on all tank compartments

771 gallon single compartment pump tank; capacity is available for at least 1/3 day's flow above the alarm-on level. The system will operate on demand. See pump tank cross section for float settings. A 155 mesh filter will be installed.

Flow Rates

Emitter spacing---2 ft centers

Emitter line required 1200 sq ft / 2 ft spacing = 600 ft.

Number of emitters = 1260 sq ft / (4 sq ft / emitter) = 315 emitters

Emitter flow rate = 0.6 Gal / Hr

Total flow = 315 emitters \times 0.6 gal / emitter / hr = 189 gal / hr 189 gph / 60 min / hr = 3.2 gpm

It has been established that proper scouring and flushing of any pipe system will require at least 1.6 gallons per minute flow at the outflow end of any pipe. Therefore, we should require a flow of at least 1.6 gallons per minute out of each dipper line connection that has been made to the return flush manifold pipe. The field will have 2 loops, 300 LF each (see site plan).

Flow rates and pump sizing:

2 connections x 1.6 gpm = 3.2 gpm Total flow = 3.2 gpm + 3.2 gpm = 6.4 gpm

Head Calculation

Supply Line Loss-2.2 psi / 100 ft of 1 in. X 75 ft = 1.7 psi

Return Flush Line- 2.2 psi / 100 ft of 1 in. X 75 ft = 1.7 psi

Pressure required at the inlet of the drip tubing: Elevation from the pump to the highest drip tubing inlet: = 15 ft / 2.3psi/ft = Supply line loss 0.4psi/100ft x 100 ft = Return line loss = 100 micron filter	40.0 psi 6.5 psi 1.7 psi 1.7 psi
Amiad 2" T Super filter	<0.28 psi

Total 49.9 psi 49.9 psi x 2.3 ft/psi = 115 ft of head

Pump Requirement = 6.4 gpm @ 115 ft Pump - Sta Rite Model 20DOMO5121 draw down to 5 inches

A Sta Rite Model 20DOMO5121 delivers 3.2 gpm to the field. To deliver the needed 30 gallons 8 times per day, the timer should be set to run for 563 seconds (9.4 minutes) every three hours.

TANKS

The risers to all tanks must be permanently fastened to the tank lid or cast into the tank. The connection between the riser and the tank lid must be water tight and the risers must be fitted with a removable water tight cap and protected against unauthorized intrusions. Acceptable protection measures include a padlock, a cover that can be removed with tools, a cover having a minimum weight of 65 pounds sit into a recess of the tank lid or any other means approve by TCEQ. A secondary provision such as a plug, net or mesh in the riser is also required.

CONSTRUCTION / INSTALLATION

Installer shall follow all manufacturers' instructions for installation of treatment plant, wiring, and aerator. All required setbacks are to be followed by the installer. After tank holes are dug, a minimum of four inches of sand, sandy loam clay, or pea gravel, free of rock shall be placed in the holes. Tanks may them be placed in the holes, which shall be left open until inspection, then backfilled with sand, sandy loam clay, or pea gravel, free of rock.

ELECTRICAL

All electrical wiring shall be in accordance with the most recent edition of the National electric Code. Connections shall be in approved junction boxes and all external power wiring shall be in approved electrical conduit, buried and terminated at a main circuit breaker panel or sub-panel.

LANDSCAPING

The drip irrigation area must be contoured to a uniform slope such that the drip tubing may be placed to avoid any sharp slopes. After contouring, the ground must be scarified and a thin layer of Ty III soil shall be placed over natural ground and then the drip lines may be placed on this Ty III soil. Areas that are bare or have been disturbed must be seeded or sodded with a mix of rye and bermuda grasses prior to system operation. It is highly recommended that a good stand of vegetation be established prior to system operation.

INSPECTION

One open pit inspection will be performed when the system components are in place and operational. Comal County may require more inspections. Installer will give 48 hours notice to the designer for inspections.

MAINTENANCE REQUIREMENTS

Permit approval requires the applicant to furnish to the regulatory authority a valid maintenance contract with a maintenance company. The maintenance company will verify that the system is operating properly and that they will provide on-going maintenance of the installation. The initial maintenance contract must be valid for a minimum of two years. A maintenance contract will authorize the maintenance company to maintain and repair the system as needed. Again, a copy of the signed maintenance contract between the property owner and an approved maintenance company shall be provided to the permitting authority prior to final permit approval.

The owner shall continuously maintain a signed written contract with a valid maintenance company and shall submit a copy of the contract to the permitting authority at least 30 days prior to the date service will cease.

If a maintenance company discontinues business, the property owner shall, within 30 days of the termination date, contract with another approved maintenance company and provide the permitting authority with a copy of the newly signed maintenance contract.

AFFIDAVIT

Prior to issuance of a permit, a certified copy of an affidavit, which has been duly recorded at Comal County Clerk's office and filed in reference to the real property deed on which the aerobic system with drip emitters is to be installed, must be submitted. Such an affidavit shall state that the property shall not be transferred to a new owner without:

- 2. the new owner being advised that the property contains an aerobic treatment system with sub-surface drip emitters for wastewater disposal;
- the permit issued to the previous owner of the property being transferred to the new owner in accordance with Sect. 285.20(5) of the TCEQ OSSF Rules, i.e.; the permit will be issued in the name of the owner of the OSSF. Permits shall be transferred to the new owner automatically upon legal sale of the OSSF. The transfer of an OSSF permit under this section shall occur upon actual transfer of the property on which the OSSF is located unless the ownership of the OSSF has been severed from the property:
- 3. the new owner submitting a valid signed maintenance contract to the permitting authority.


TESTING AND REPORTING

The maintenance company shall inspect each permitted system as directed by the testing and reporting schedule shown in Sect 285.91 (4) of the TCEQ OSSF Rules, or as may be required by Comal County. The maintenance company shall report any responses to homeowner complaints, and the results of its maintenance findings to Comal County within ten days of the specified reporting frequency.

The frequency of testing and type of tests required are shown in Sect. 285.91 (4) of the TCEQ OSSF Rules.

LICENSE TO OPERATE

Contact Comal County for information.



Date 4/28/2025

Drawn by Christine Nixon

Client

SQR Development

Burrier Engineering 424 (Lot 521)Valley Ridge Canyon Lake, TX Comal County

Scale 1"=20'

COMAL COUNTY ENVIRONMENTAL HEALTH DEPARTMENT OSSF SOIL EVALUATION FORM

Owners Name	2x2 Capital Development		
Physical Address:	Valley Ridge, Canyon Lake, TX 78133		
Name of Site Evaluator_	Christine Nixon		
Date Performed:	March 1, 2022	Proposed Excavation Depth:	36" max

Requirements:

At least two soil excavations must be performed on the site, at opposite ends of the proposed disposal area.

Locations of soil evaluation must be shown on the application site drawing or designer's site drawing

For subsurface disposal, soil evaluations must be performed to a depth of at least two feet below the proposed excavation depth. For surface disposal, the surface horizon must be evaluated.

Please describe each soil horizon and identify any restrictive features in the space provided below. Draw lines at the appropriate depths.

SOIL BORING NUMBER						
Depth (Feet)			Structure (For Class III- blocky, platy or massive	Drainage (Mottles/ Water Table)	Restrictive Horizon	Observations
0	1-4" Top Soil 4" – below Rock	<30%	Ty III			No indication of ground water

SOIL BORING NUMBER_							
Depth (Feet)			Structure (For Class III- blocky, platy or massive	(For Class III- blocky, platy or Water Table)		Observations	
	1-4" Top Soil 4" – below Rock	<30%	Ту Ш			No indication of ground water	

FEATURES OF SITE AREA


Presence of 100 year flood zone	YES	NO x
Presence of adjacent ponds, streams, water impoundments	YES	NO x
Existing or proposed water well in nearby area	YES	NO x
Organized sewage available to lot or tract	YES	NO x
Recharge features within 150 feet	YES	NO x

I C	erj	ify	that	the al	99y	e statements	are	true :	and a	re	based	on	my	own	fie	ld	observ	ation	S.
-----	-----	-----	------	--------	-----	--------------	-----	--------	-------	----	-------	----	----	-----	-----	----	--------	-------	----


Signature of Site Evaluator

March 1, 2022

Date



Drip Field Cross Section



Field Box


Date 11/19/2024

Drawn by Christine Nixon

Engineering

Drip Cross
Section

Scale NTS



Valley Ridge Homes at Canyon Lake HOUSE B

424 Valley Ridge, Canyon Lake, TX 78133 - Lot 521

10.30.24

NoackLittle

architecture and interiors

220 Industrial Blvd Suite 101 Austin, Texas 78745 T. 512.851.1900 www.noacklittle.com

Valley Ridge Homes at Canyon Lake PROJECT #:23012.05

PROJECT CONTACTS:

OWNER:
2x2 Captial Management, LLC
129 Valley Ridge Rd
Dripping Springs, TX 78620
512.590.3411
CONTACT: Chadwick Fox
chad.f@2x2capitalmanagement.com


ARCHITECT:
NoackLittle Architecture & Interiors
220 Industrial Blvd., Suite 101
Austin, Texas 78745
T 512.851.1900
CONTACT: Clay Little
clay@noacklittle.com


STRUCTURAL ENGINEER:
TDI Engineering, LLC
5906 Old Fredericksburg Rd, Suite 300
Austin, Texas 78749
T 512.301.3389
CONTACT: Elizabeth Ledy
eledy@tdi-llc.net


DRAWING INDEX B

Note:		
	ing Issue Record indicates the original release of drawings, equent revised and/ or new drawings issued after initial release.	
Sheet No.	Sheet Name	
00 GENERAL	INFORMATION - B	
G.000B	Cover	
G.001B	Project & Drawing General Information	
G.011B	Rendering Perspectives	
01 ARCHITE	CTUDE D	
01 ARCHITEC A.011B	Architectural Site Reference Plan	
A.101B	Construction Plans	
A.201B	Reflected Ceiling Plans	
A.301B	Exterior Elevations	
A.401B	Building Sections	
A.721B	Interior Elevations	
A.801B	Stair Plans, Sections & Details	
02 STRUCTU	IRAL - B	
S1.00B	General Notes	
S1.01B	General Notes	
S2.00B	Foundation Plans - House B	
S3.00B	Framing Plans - House B	
S4.00B	Shear Wall Plans - House B	
S5.00B	Foundation Details	
S5.01B	Retaining Wall Details	
S6.00B	Framing Details	
S6.01B	Framing Details	









PROJECT GENERAL INFORMATION This project falls within the jurisdiction of Caldwell County, Texas and is subject to all developmental regulations adopted for residential improvements. The project consists of a 2,760 SF 3-story wood-framed single-family The project has been designed to comply with the 2021 International Residential dwelling with a carport at the ground level. Unconditioned (SF) Conditioned (SF) Floor Plan A 833 Floor 2 812 Floor 3 2,749 Total 2,008 Unconditioned (SF) Conditioned (SF) Floor Plan B Floor 1 833 Floor 2 Floor 3 2,760 Total 2,015

924

923

902

935


923

902

NoackLittle architecture and interiors 220 Industrial Blvd Austin, Texas 78745 P512.851.1900 www.noacklittle.com

Valley Ridge **Homes at Canyon** Lake

Lot 521 424 Valley Ridge, Canyon Lake, TX 78133



Mark Date	Description
LAI Job #:	23012.05
rawn by:	KK
hecked by:	CL
ate of Issue:	10.30.24

Project & Drawing General Information

G.001B

PHOTOS/ RENDERING NOTES:

- O1 All photographs and renderings are included in these contract documents are for Contractor's reference ONLY unless noted otherwise, and are not part of the contract documents.
- O2 The photographs and renderings are to be used as supplemental information to all contract documents, and all contract documents supersede any information noted or shown on photographs or renderings.
- O3 For existing conditions it is not the Architect's intent to present the entire Scope of Work or all built conditions by the use of photographs or renderings. It is the responsibility of the Contractor to verify the Scope of Work and ALL built conditions in the field prior to Start of Work.




NoackLittle

220 Industrial Blvd Suite 101 Austin, Texas 78745 P512.851.1900 www.noacklittle.com


architecture and interiors




04 INTERIOR RENDER - BEDROOM



02 INTERIOR RENDER - KITCHEN



01 INTERIOR RENDER - LIVING ROOM



03 INTERIOR RENDER - PRIMARY BATH

Valley Ridge
Homes at Canyon
Lake

Lot 521

424 Valley Ridge,
Canyon Lake, TX 78133

10.30.24 100% CD

 NLAI Job #:
 23012.05

 Drawn by:
 KK


 Checked by:
 CL

 Date of Issue:
 10.30.24


Sheet Title:


Rendering Perspectives

Sheet No.: **G.011B**










Lot 521 424 Valley Ridge, Canyon Lake, TX 78133



10.30.24 100% CD

Mark Date Description

 NLAI Job #:
 23012.05

 Drawn by:
 KK

 Checked by:
 CL

 Date of Issue:
 10.30.24


True

rchitectural S

Architectural Site Reference Plan

Sheet No.:

A.011B



DRAWING SHEET NOTES:

- 01 Refer to Index Sheet for typical graphical symbols and abbreviation
- 02 Refer to Mounting Height Sheet for Accessibility Guidelines.
- 03 All new partitions to be Type D2.3 U.N.O. All new furring to be Type F1.3 U.N.O.
- 04 At areas of open ceilings, all new and existing partitons to extend to
- deck. Modify existing partitions as required. Refer to RCP for areas open to deck. 05 In general, all horizontal dimensions are provided on plans, and all

vertical dimensions are provided on elevations and/or sections unless

- otherwise noted. 06 In general, the Overall Plan indicates exterior building dimensions, room numbers and names, door designations, exterior window designations, exterior elevations designations, building section and
- details designations. All other plan information is indicated on referenced area or enlarged plans. 07 In general, Area and/or Enlarged Plans indicate interior building dimensions to face of partition material, room numbers and names, door designations, interior window designations, interior detail
- designations, interior elevations, partition type designations, finish designations, and general building material. 08 When columns and column lines are present, all dimensions are to be tied to a column line. Contractor shall immediately report any omission
- 09 Coordinate all MEP access panels not shown on architectural construction documents with Architect prior to installation.

construction.

10 Provide adequate blocking as required at every location where millwork, wall light fixtures, railings, TV brackets, plumbing fixtures, etc.

are to be mounted. Items are required to resist 250 pound point load.

of dimensions not tied to a column line to the Architect prior to start of

11 There are items shown, i.e. outlets, switches, thermostats, panels, etc. on MEP contract documents that may not be shown on architectural contract documents. Contractor to coordinate all items with current TAS requirements and mounting height sheet unless noted otherwise .

DRAFTING GRAPHICS NOTES:

- 01 All Construction To Remain is shown (drafted) as "light ghost lines" and is typically not noted, scheduled, dimensioned, etc. unless noted otherwise.
- 02 All Demolished lines are shown (drafted) with dashed lines. New Construction is shown (drafted) as "heavy lines" with poche and is typically noted, scheduled, dimensioned, or referenced within legends unless noted otherwise.

unless noted otherwise.						
Plan Leg	<u>end</u>					
SYMBOL	DESCRIPTION					
	AREA NOT IN CONTRACT					
	NEW PARTITION. REFER TO PARTITION SCHEDULE.					
	EXISTING PARTITION TO REMAIN					
====	EXISTING PARTITION TO BE REMOVED.					
	NEW FIRE RATED PARTITION					
(E)	EXISTING DOOR TO REMAIN					
	NEW DOOR. REFER TO NOTES AND/OR SCHEDULE.					
	DOOR, FRAME, AND HARDWARE TO BE REMOVED					

Valley Ridge **Homes at Canyon** Lake

NoackLittle

Suite 101 Austin, Texas 78745

P512.851.1900 www.noacklittle.com

architecture and interiors

Lot 521 424 Valley Ridge, Canyon Lake, TX 78133

GENERAL COMMENTS:


1. NOT ALL SYMBOLS MAY BE USED ON THIS PROJECT. REFER TO PLANS.

10.30.24 100% CD

23012.05 NLAI Job #: Drawn by: Checked by: CL 10.30.24 Date of Issue:

Construction Plans

A.101B



REFLECTED CEILING NOTES:

- O1 Refer to Index Sheet G.001 for Abbreviation Index and A.201 for symbols. Refer to sheet G.151 for mounting height information
- 02 All ceiling to be at X'-X" A.F.F. U.N.O.
- 03 All ceiling furrdowns to be at X'-X" A.F.F. U.N.O.
- 04 In general, all horizontal dimensions are provided on plans, and all vertical dimensions are provided on elevations and/or sections unless otherwise noted.
- O5 Coordinate all MEP access panels not shown on architectural construction documents with Architect prior to installation.
- Of Provide adequate blocking as required at every location where ceiling mounted equipment is to be mounted. Coordinate with all trades to ensure blocking does not interfere with building systems.
- O7 There are items shown, i.e. egress systems, audio systems, security systems, etc., on the MEP drawings or Owner-provided consultants' drawings that are not drawn on the architectural ceiling plans. Contractor to coordinate and mount all items in a uniform and systematic pattern Unless Noted Otherwise. Coordinate with Architect prior to installation.
- 08 Architect has Final Decision on ALL sprinkler system head locations within ceiling. Contractor to submit Sprinkler System Installer's sprinkler head plans to Architect for comment and approval without exception.
- O9 Ceilings and all miscellaneous framing for ceilings shall not interfere or degrade any smoke or fire rated partition or wall without exception.

Contact Architect immediately if conflicts arise prior to installation.

- For all new ceilings that are constructed as part of an existing ceiling, use same construction as existing and patch with same material to match existing. New and existing shall align
- 11 All fixtures to be 3500K / 90 CRI U.N.O.

seamlessly.

SYMBOL & MARK	DESCRIPTION	DESCRIPTION					
A	DESCRIPT: MFR: PRODUCT: FINISH: NOTES:	TYPICAL 6" CAN RECESSED LED TBD TBD, #######-##-# TBD PROVIDE 3500K TEMP					
В	DESCRIPT: MFR: PRODUCT: FINISH: NOTES:	DECORATIVE LED PENDANT TBD TBD, #######-##-##-# TBD PROVIDE 3500K TEMP					
С	DESCRIPT: MFR: PRODUCT: FINISH: NOTES:	TYPICAL CEILING MOUNTED FIXTURE TBD TBD, #######-##-##-# TBD PROVIDE 3500K TEMP					
D	DESCRIPT: MFR: PRODUCT: FINISH: NOTES:	TYPICAL 6" CAN RECESSED LED TBD TBD, #######-##-# TBD PROVIDE 3500K TEMP					
G	DESCRIPT: MFR: PRODUCT: FINISH: NOTES:	TYPICAL LED PENDANT TBD TBD, #######-##-# TBD PROVIDE 3500K TEMP					
Р	DESCRIPT: MFR: PRODUCT: FINISH: NOTES:	WET LISTED LED EXTERIOR SCONCE TBD TBD, #######-##-# TBD PROVIDE 3500K TEMP					
F	DESCRIPT: MFR: PRODUCT: FINISH: NOTES:	FAN WITH LIGHT KIT TBD TBD, #######-##-##-# TBD PROVIDE 3500K TEMP					

GENERAL NOTES:

GENERAL NOTES:

NOT ALL FIXTURES SHOWN IN LEGEND MAY BE USED ON THIS PROJECT

1. REFER TO MEP DRAWINGS AND SPECIFICATIONS FOR ADDITIONAL FIXTURE INFORMATION.

NoackLittle

220 Industrial Blvd Suite 101 Austin, Texas 78745

P512.851.1900 www.noacklittle.com

architecture and interiors

Valley Ridge Homes at Canyon Lake

Lot 521

424 Valley Ridge, Canyon Lake, TX 78133

SYMBOL & MARK

DESCRIPTION

5/8 THICK GYPSUM BOARD SUSPENDED CEILING SYSTEM. TYPICAL.

RECESSED DROP DOWN PROJECTION SCREEN

CEILING MOUNTED SPEAKER, REFER TO AUDIO/VISUAL

CEILING MOUNTED SECURITY CAMERA, REFER TO AUDIO/VISUAL

SPRINKLER HEAD, COORDINATE WITH SPRINKLER INSTALLER

RECESSED SLOT DIFFUSER. REFER TO MEP.

RECESSED MECHANICAL SUPPLY REGISTER. TYPICAL.

RECESSED MECHANICAL RETURN REGISTER.

TYPICAL.

RECESSED MECHANICAL EXHAUST REGISTER.

NOT ALL FIXTURES SHOWN IN LEGEND MAY BE USED ON THIS PROJECT.

REFER TO MEP DRAWINGS AND SPECIFICATIONS FOR SPECIFIC FIXTURE INFORMATION.

10.30.24 100% CD

Mark Date Description

NLAI Job #: 23012.05

CL 10.30.24

Reflected Ceiling Plans

Sheet No.:


Drawn by:

Checked by:

Date of Issue:


A.201B







Lot 521 424 Valley Ridge, Canyon Lake, TX 78133




ark Date	Description
Al lob #:	22242.25
Al Job #:	23012.05
awn by:	KK
ecked by:	CL
te of Issue:	10.30.24

Exterior Elevations


A.301B







Lot 521 424 Valley Ridge, Canyon Lake, TX 78133



 NLAI Job #:
 23012.05

 Drawn by:
 KK

 Checked by:
 CL


 Date of Issue:
 10.30.24

Sheet Title:

Building Sections

A.401B







Lot 521 424 Valley Ridge, Canyon Lake, TX 78133

10.30.24 100% CD

Mark Date Description

NLAI Job #: 23012.

NLAI Job #: 23012.05

Drawn by: KK


Checked by: CL

Date of Issue: 10.30.24


Sheet Title:


Interior Elevations


A.721B



02 B - Stair Plan 2
SCALE: 3/4" = 1'-0"







Valley Ridge Homes at Canyon Lake

Lot 521 424 Valley Ridge, Canyon Lake, TX 78133

10.30.24 100% CD

Mark Date Description

Mark Date Description

ALAI Job #: 23012.

Drawn by:

 NLAI Job #:
 23012.05

 Drawn by:
 KK

 Checked by:
 CL

 Date of Issue:
 10.30.24

Sheet Title:

Stair Plans, Sections & Details

Sheet No.:
A.801B

O1 B - Stair Plan 1 SCALE: 3/4" = 1'-0"

OTHERWISE IN SPECIFICATIONS OR ON DRAWINGS. 2. IT IS THE RESPONSIBILITY OF THE GENERAL CONTRACTOR TO OBTAIN AND DISTRIBUTE ALL CURRENT CONTRACT DOCUMENTS AND ADDENDA TO SUPPLIERS AND SUB-CONTRACTORS FOR THE USE OF SHOP DRAWING PRODUCTION AND FABRICATION PRIOR TO CONSTRUCTION.

IT IS THE RESPONSIBILITY OF THE GENERAL CONTRACTOR TO COMPARE THE ARCHITECTURAL, STRUCTURAL, MECHANICAL, ELECTRICAL, PLUMBING, AND OTHER DRAWINGS, AND REPORT ANY DISCREPANCIES AMONG OR WITHIN THE DRAWING SETS PRIOR TO FABRICATION OR CONSTRUCTION.

4. IT IS THE RESPONSIBILITY OF THE GENERAL CONTRACTOR TO VERIFY ALL DIMENSIONS, FLOOR ELEVATIONS, DROPS, SLOPES, DRAINS, EMBEDDED ITEMS, ETC., PRIOR TO

5. THE DETAILS AND SECTIONS SHOWN ON STRUCTURAL DRAWINGS APPLY GENERALLY TO ALL AREAS OF SIMILAR OR LIKE CONDITIONS THROUGHOUT THE DRAWINGS.

IS THE RESPONSIBILITY OF THE GENERAL CONTRACTOR/SUB-CONTRACTOR TO PREPARE SHOP DRAWINGS DETAILING CONDITIONS IN ACCORDANCE WITH SPECIFIED STANDARDS AND SPECIFIC REQUIREMENTS OF THIS PROJECT AS INDICATED ON DRAWINGS

7. THE USE OF THESE STRUCTURAL DRAWINGS BY ANY CONTRACTOR, SUB-CONTRACTOR, MATERIAL SUPPLIER, FABRICATOR, OR ERECTOR WITHOUT THE PREPARATION OF SHOP DRAWINGS REPRESENTS HIS ACCEPTANCE OF THESE DRAWINGS AS COMPLETE AND CORRECT. AS A RESULT, ANY EXPENSE ACQUIRED AS A RESULT OF ERRORS OCCURRING ON DRAWINGS IS THE RESPONSIBILITY OF THE INDIVIDUAL PARTY.

SHOP DRAWINGS MAY BE SUBMITTED TO ENGINEER FOR REVIEW FOR CORRECTNESS OF STRUCTURAL INTENT. CONTRACTOR, SUB-CONTRACTOR, MATERIAL SUPPLIER, FABRICATOR. OR ERECTOR SHOULD ANTICIPATE A MINIMUM 10 BUSINESS DAY REVIEW PERIOD BY

9. THE DESIGN AND PROVISION FOR ALL TEMPORARY SUPPORTS OR FRAMING IS THE RESPONSIBILITY OF THE GENERAL CONTRACTOR. TEMPORARY SUPPORTS SHALL NOT OVERSTRESS OR CAUSE DAMAGE TO THE PERMANENT STRUCTURAL ELEMENTS.

10. THE DESIGN AND PROVISION FOR SUPPORTS OF ALL NON-STRUCTURAL FRAMING, INCLUDING MECHANICAL EQUIPMENT, PLUMBING, ETC IS THE RESPONSIBILITY OF THE GENERAL CONTRACTOR. SUPPORTS SHALL BE DESIGNED FOR ALL APPLICABLE LOADS IN ACCORDANCE WITH THE GOVERNING BUILDING CODE INCLUDING SEISMIC LOADING. SUPPORTS SHALL NOT OVERSTRESS OR CAUSE DAMAGE TO STRUCTURAL ELEMENTS. REFERENCE ARCHITECTURAL DRAWINGS AND SPECIFICATIONS FOR ALL NON-STRUCTURAL FRAMING REQUIRED.

11. THE STRUCTURAL DRAWINGS AND ITEMS SHOWN HEREIN REPRESENT THE FINISHED STRUCTURE AND DO NOT NECESSARILY REPRESENT THE MEANS OR METHODS OF CONSTRUCTION. THE GENERAL CONTRACTOR SHALL BE SOLELY RESPONSIBLE FOR SUPERVISING THE WORK, AND THE MEANS, METHODS, PROCEDURES, TECHNIQUES, AND SEQUENCES OF CONSTRUCTION.

12. THE STRUCTURE SHOWN HEREIN IS STRUCTURALLY SOUND WHEN ALL HORIZONTAL AND LATERAL PERMANENT BRACING INDICATED ON DRAWINGS IS INSTALLED IN THEIR ENTIRETY. THE GENERAL CONTRACTOR SHALL BE RESPONSIBLE FOR ALL TEMPORARY SUPPORT OF ALL ELEMENTS TO RESIST GRAVITY, EARTH, WIND, SEISMIC, AND CONSTRUCTION LOADS DURING CONSTRUCTION.

13. ALL ELEVATIONS SHOWN ARE FOR STRUCTURAL REFERENCE PURPOSES ONLY. REFER TO CIVIL FOR DATUM ELEVATIONS.

DESIGN CODES/STANDARDS

GOVERNING BUILDING CODE: 2021 INTERNATIONAL BUILDING CODE.

2. DESIGN LOADS: MINIMUM DESIGN LOADS FOR BUILDINGS AND OTHER STRUCTURES, ASCE 7-16.

CONCRETE: BUILDING CODE REQUIREMENTS FOR STRUCTURAL CONCRETE, AMERICAN CONCRETE INSTITUTE, ACI 318-19.

4. STRUCTURAL STEEL: SPECIFICATION FOR STRUCTURAL STEEL BUILDINGS AND STEEL CONSTRUCTION MANUAL, AMERICAN INSTITUTE OF STEEL CONSTRUCTION, AISC 360-16 AND AISC 325-17.

5. WOOD: NATIONAL DESIGN SPECIFICATION FOR WOOD CONSTRUCTION, AMERICAN FOREST 8 PAPER ASSOCIATION, NDS-18.

LOADS AND DESIGN CRITERIA

1.	DE.	AD LOADS	
	A.	FLOOR	15 PS
		TRUSS TOP CHORD	11 PS
		TRUSS BTM CHORD	5 PS
	B.	CORRIDORS/BALCONIES	15 PS
	C.	ROOF	15 PS
		TRUSS TOP CHORD	10 PS
		TRUSS BTM CHORD	10 PS
	D.	STAIRS	35 PS

STAIR LANDINGS 35 PSF TRUSS TOP CHORD 32 PSF 5 PSF TRUSS BTM CHORD 55 PSF W/ 4" CONC OVER MTL DECK LIVE LOADS

60 PSF SERVING PRIVATE SPACES

10 PSF W/ UN-INHABITABLE ATTICS

STORAGE (NON-CONCURRENT)

100 PSF

1.00

5 PSF

108 MPH

29.1 PSF

32.0 PSF

29.1 PSF

39.2 PSF

32.0 PSF

38.2 PSF

38.2 PSF

41.1 PSF

38.2 PSF

48.4 PSF

41.1 PSF

23.2 PSF

0.063 g

0.032 g

0.068 g

0.052 g

10.0 KIP

OR SELECT FILL

0.01

10 SF (0.6 W)

WITHOUT STORAGE (NON-CONCURRENT)

REF S1.01 FOR TYP CONFIGURATIONS

BLDGS 1-4 - 8.5 FT; CLUBHOUSE - 5.0 FT

BLDGS 1-4 - 8.5 FT; CLUBHOUSE - 5.0 FT

100 SF (0.6W + 0.6D)

14.4 PSF NET

14.4 PSF NET

20.8 PSF NET

14.4 PSF NET

24.5 PSF NET

20.8 PSF NET

23.5 PSF NET

23.5 PSF NET

29.9 PSF NET

23.5 PSF NET

33.6 PSF NET

29.9 PSF NET

25 SF (0.6W)

17.8 PSF

21.2 PSF

2,200 PSF @ 12" INTO WEATHERED LIMESTONE

4,800 PSF @ 12" INTO INTACT LIMESTONE

ACTIVE PRESSURE = 48 PCF (IBC PRESUMPTIVE VALUES)

COEFFICIENT OF FRICTION = 0.35 (IBC PRESUMPTIVE VALUES)

LIGHT FRAME WALLS W/ SHEAR PANELS

(WOOD & OTHER MATERIALS)

STATIC LATERAL FORCE

20 PSF W/ UN-INHABITABLE ATTICS W/ LIMITED

CORRIDORS/BALCONIES ROOF D. ROOF TRUSS BTM CHORD

. FLOOR

E. STAIRS & LANDINGS SNOW LOADS

A. IMPORTANCE FACTOR GROUND SNOW LOAD WIND LOADS A. RISK CATEGORY BASIC WIND SPEED

EXPOSURE CATEGORY D. C&C PRESSURES EDGE DISTANCE 'a' EDGE DISTANCE '0.6h' **ROOF EFFECTIVE AREA**

ROOF ZONE 1 ROOF ZONE 2e ROOF ZONE 2n **ROOF ZONE 2r ROOF ZONE 3e** ROOF ZONE 3r **ROOF ZONE 1&1'OH** ROOF ZONE 2eOH ROOF ZONE 2nOH ROOF ZONE 2rOH ROOF ZONE 3eOH

ROOF ZONE 3rOH WALL EFFECTIVE AREA WALL ZONE 4 WALL ZONE 5 SEISMIC LOADS

A. STRUCTURAL SYSTEM B. ANALYSIS PROCEDURE IMPORTANCE FACTOR

SITE CLASS SEISMIC DESIGN CATEGORY MAPPED SRA Ss G. DESIGN SRA Sds H. Cs

I. $Vb = 0.7 \times Cs \times W$ 6. FOUNDATION DESIGN CRITERIA A. ALLOWABLE BEARING

B. RETAINING WALL

SOIL AND SUBSURFACE CONDITIONS

1. IT IS THE RESPONSIBILITY OF THE GENERAL CONTRACTOR TO THOROUGHLY READ, UNDERSTAND THE DESIGN CRITERIA AND FOLLOW THE RELATED BUILDING PAD PREPARATION REQUIREMENTS SET FORTH IN THE GEOTECHNICAL REPORT PREPARED FOR THIS PROJECT.

FOUNDATION DESIGN IS BASED ON GEOTECHNICAL REPORT, PROJECT # 24-6131, PREPARED BY ON TIME GEOTECHNICAL, DATED 09/30/2024.

BUILDING PAD PREPARATION SHALL BE IN ACCORDANCE WITH RECOMMENDATIONS IN GEOTECHNICAL REPORT. REMOVE AND REPLACE 12" OF CLAY MATERIAL W/ WELL COMPACTED SELECT FILL IN ACCORDANCE W/ GEOTECHNICAL REPORT. TREE STUMPS AND ROOTS SHALL BE GRUBBED TO A DEPTH OF 24" BELOW GRADE.

4. ANY FILL WORK WITHIN 10 FT OF BUILDING EXTENTS SHALL BE PROPERLY PLACED AND COMPACTED TO 95% OF MAXIMUM DRY DENSITY AS DEFINED IN ASTM D698 STANDARD

5. POSITIVE DRAINAGE SHALL BE PROVIDED AND MAINTAINED AWAY FROM THE BUILDING DURING CONSTRUCTION AND PERMANENTLY. STORED EXCAVATION MATERIAL AND/OR

CONSTRUCTION MATERIALS SHALL NOT DISRUPT POSITIVE DRAINAGE AWAY FROM BUILDING. STRUCTURAL DRAWINGS INDICATE TYPICAL AND INDIVIDUAL SPECIFIC CONDITIONS ONLY. IT 6. IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO PROVIDE ANY REQUIRED BACK FILLING OF WALLS, PIERS, FOOTINGS, ETC., SUCH THAT SYMMETRICAL LOADING OCCURS. IN THE EVENT THAT CONDITIONS PREVENT SUCH SYMMETRICAL LOADING, TEMPORARY SHORING SHALL BE PROVIDED AND MAINTAINED UNTIL PERMANENT HORIZONTAL AND VERTICAL BRACING ELEMENTS ARE PLACED AND PROPERLY SET.

> 7. IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO MAINTAIN STABILITY OF EXCAVATIONS UNTIL PROPERLY BACK FILLED. EXCAVATIONS SHALL REMAIN FREE OF LOOSE DEBRIS/MATERIAL, AND WATER. EXCAVATIONS SHALL BE DE-WATERED AND ALL WET MATERIAL REMOVED/REPLACED PRIOR TO CONCRETE PLACEMENT.

HEAVY EQUIPMENT NECESSARY FOR SPREADING AND COMPACTING BACK FILL MATERIAL SHALL NOT BE OPERATED CLOSER THAN A DISTANCE EQUAL TO THE HEIGHT OF BACK FILL MATERIAL ABOVE THE WALL, PIER, FOOTING, ETC. HAND TAMPING SHALL BE USED TO COMPACT THE REMAINING AREA.

GEOTECHNICAL ENGINEER. OTHERWISE, PROVIDE SELECT FILL IN ACCORDANCE WITH GEOTECHNICAL REPORT AS BACKFILL MATERIAL.

9. EXCAVATED MATERIAL MAY BE USED AS BACKFILL IF FOUND TO BE ACCEPTABLE TO THE

BUILDING PAD PREPARATION SHALL BE SUCH THAT THE THICKNESS OF FOUNDATION SLAB-ON-GRADE SHALL NOT BE REDUCED BY MORE THAN 5 PERCENT OF DEPTH SHOWN ON

SLAB-ON-GRADE FOUNDATION

LOCATION OF TREES IN CLOSE PROXIMITY CAN EFFECT LONG-TERM PERFORMANCE OF THE FOUNDATION. TREES TO BE REMOVED SHALL BE REMOVED PRIOR TO CONSTRUCTION OF THE FOUNDATION. CONTRACTOR SHALL CONSULT WITH APPROPRIATE JURISDICTIONAL OFFICIALS PRIOR TO REMOVAL OF PROTECTED TREES.

FINAL GRADE SHALL BE MAINTAINED TO PROVIDE POSITIVE DRAINAGE AWAY FROM THE FOUNDATION. FOUNDATION EXPOSURE AND SLOPE AWAY FROM FOUNDATION SHALL CONFORM WITH APPLICABLE CODE PROVISIONS. CONTRACTOR SHALL REFERENCE GRADING PLAN FOR FINISHED GRADE ELEVATIONS.

CONTRACTOR SHALL PROVIDE A 10 MIL POLY VAPOR BARRIER BENEATH ALL SLAB AREAS. BARRIER SHALL EXTEND A MINIMUM OF 12" DOWN BEAMS AND SHALL BE CUT OUT OF BOTTOM OF BEAM EXCAVATIONS TO FACILITATE FOUNDATION INSPECTIONS. CONTRACTOR SHALL PROVIDE A DOUBLE LAYER OF VAPOR BARRIER UNDER ALL CONSTRUCTION JOINTS. EXTENDING MIN 18" EACH SIDE OF THE JOINT. VAPOR BARRIER SHALL BE INSTALLED, LAPPED, AND TAPED IN ACCORDANCE WITH MANUFACTURERS RECOMMENDATIONS OR MIN 6"

MATERIAL FOR CONCRETE EXPANSION JOINTS SHALL BE 1/2" THICK ASPHALT IMPREGNATED MATERIAL x DEPTH OF JOINT, TO SEPARATE CONCRETE PLACEMENTS. PROVIDE ELASTOMERIC 6. HEADED STUD ANCHORS SHALL CONFORM TO ASTM A108 ULTIMATE TENSILE STRENGTH JOINT SEALANT TO TOP OF JOINT WHEN CONCRETE HAS CURED

WHERE SLAB BLOCK-OUTS ENCROACH INTO GRADE BEAMS, BEAM WIDTH SHALL BE INCREASED, TO MAINTAIN SPECIFIED MIN WIDTH EXCLUSIVE OF THE BLOCK-OUT, FOR THE FULL DEPTH OF THE BEAM. THE INCREASED BEAM WIDTH SHALL BE MAINTAINED AT MIN 30" EACH SIDE OF BLOCK-OUT. CONVENTIONAL REINFORCEMENT SHALL BE CONTINUOUS AROUND BLOCK-OUT.

CAST IN PLACE CONCRETE

CONCRETE WORK SHALL CONFORM TO THE FOLLOWING:

ACI 318 - REINFORCED CONCRETE B. ACI 318.1 - PLAIN CONCRETE ACI 306R - COLD WEATHER CONCRETING

ACI 305R - HOT WEATHER CONCRETING ACI 117 - STANDARD SPECIFICATION FOR TOLERANCES

2. CONCRETE USED FOR STRUCTURAL APPLICATIONS AS SHOWN ON DRAWINGS SHALL BE STANDARD WEIGHT, WITH 28-DAY COMPRESSIVE STRENGTH AS NOTED BELOW. COMPRESSIVE STRENGTH TESTING SHALL BE IN ACCORDANCE WITH ASTM C39 "STANDARD TEST METHOD FOR COMPRESSIVE STRENGTH OF CYLINDRICAL CONCRETE SPECIMENS."

CONCRETE SHALL HAVE A MAXIMUM SLUMP AS NOTED BELOW AND SLUMP SHALL BE DETERMINED IN ACCORDANCE WITH ASTM C143 "SLUMP OF PORTLAND CEMENT CONCRETE."

4. AGGREGATES USED FOR NORMAL WEIGHT CONCRETE SHALL HAVE A NOMINAL MAXIMUM COARSE AGGREGATE SIZE AS NOTED BELOW AND SHALL CONFORM TO ASTM C33 "SPECIFICATIONS FOR CONCRETE AGGREGATE."

5. CONCRETE SHALL BE PROPORTIONED TO MEET THE REQUIREMENTS OF ACI 318 CHAPTER 19. CONCRETE SHALL BE DESIGNED FOR EXPOSURE CLASS F0, S0, W0 AND C0 UNO.

6. CONCRETE MIX DESIGNS SHALL BE IN ACCORDANCE WITH THE REQS BELOW:

LOCATION COLUMNS FOOTINGS GRADE BEAMS 4" MIN SLAB ON GRADE RETAINING WALL	AIR ENTRAIN 1 1/2% 1 1/2% 1 1/2% 1 1/2% 1 1/2%	MIN F'c 4000 PSI 3000 PSI 3000 PSI 3000 PSI 3000 PSI	SLUMP 4" +/- 1" 4" +/- 1" 4" +/- 1" 4" +/- 1"	MAX AGG SIZE 1 1/2" 1 1/2" 1 1/2" 1 1/4" 1 1/4"	EXPOSURE CLASS C1, F0 C1, F0 C1, F0 C1, F0 C1, F0	MAX W/CM NA NA NA NA NA
RETAINING WALL	1 1/2%	3000 PSI	4" +/- 1"	1 1/4"	C1, F0	NA

7. FLY ASH CONTENT SHALL BE MAX 25% OF CEMENT REPLACEMENT

8. AIR ENTRAINMENT SHALL BE PROVIDED AS SHOWN IN THE CONCRETE MIX DESIGN REQUIREMENTS WITH A TOLERANCE OF ±1 1/2%. AIR ENTRAINMENT SHALL CONFORM TO ASTM C260 "AIR ENTRAINING ADMIXTURES FOR CONCRETE."

9. CONCRETE TESTING SHALL BE PROVIDED BY AN APPROVED AGENCY, AND IN ACCORDANCE WITH ASTM C31 "MAKING AND CURING CONCRETE TEST SPECIMENS IN THE FIELD." CURING COMPOUNDS AND SURFACE HARDENERS SHALL BE APPROVED BY ENGINEER PRIOR

TO USE. APPLICATION OF CURING COMPOUNDS AND SURFACE HARDENERS SHALL BE IN COMPLIANCE WITH MANUFACTURERS RECOMMENDATIONS. 11. CONCRETE CAST AGAINST AND PERMANENTLY EXPOSED TO EARTH SHALL BE PROTECTED BY

WATERPROOFING AS DETAILED BY ARCHITECTURAL DRAWINGS. 12. IT IS THE RESPONSIBILITY OF THE GENERAL CONTRACTOR TO COORDINATE FOUNDATION

BLOCKOUTS AND EMBEDDED ITEMS NECESSARY FOR ARCHITECTURAL, MEP, CIVIL, ETC. 13. THE CONTRACTOR SHALL PROVIDE A SUBMITTAL OF EMBEDDED CONDUITS, PIPES, AND

SLEEVES WHICH ARE BEYOND THE SCOPE DETAILED IN THE STRUCTURAL DRAWINGS. 14. IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO PLACE AND FINISH CONCRETE SLABS WITH A MINIMUM FLATNESS OF Ff = 35 AND A MINIMUM LEVELNESS OF FL = 25. ANY DEVIATION FROM THIS TOLERANCE THAT REQUIRES CUTTING OR ADDITIONAL FINISHING IS THE SOLE

RESPONSIBILITY OF THE CONTRACTOR. 15. HORIZONTAL CONSTRUCTION JOINTS ARE NOT PERMITTED UNLESS SPECIFICALLY SHOWN AND DETAILED ON STRUCTURAL PLANS. VERTICAL CONSTRUCTION JOINT LOCATIONS, OTHER 9. FRAMING MEMBERS AND LAYOUTS SHOWN ON PLANS ARE INTENDED TO REPRESENT THAN THOSE SHOWN ON PLAN, SHALL BE SUBMITTED TO ARCHITECT/ENGINEER FOR REVIEW. ADDITIONAL DETAILING AND REINFORCING MAY BE REQUIRED AND SPECIFIED BY THE ENGINEER FOR UNSCHEDULED CONSTRUCTION JOINTS, AND IS THE RESPONSIBILITY OF THE CONTRACTOR.

16. WHERE WIDTH AND DEPTH OF GRADE BEAM VARIES AT INTERSECTIONS, EXTEND THE LARGER OF THE BEAMS 3'-0" MIN BEYOND INTERSECTION AND SLOPE REINFORCEMENT OF LARGER BEAM ALONG LAP LENGTH OF SMALLER BEAM.

CONCRETE REINFORCING

1. REINFORCING STEEL SHALL BE GRADE 60 DEFORMED STEEL BARS IN ACCORDANCE WITH ASTM A615.

REINFORCING STEEL DETAILING SHALL BE IN ACCORDANCE WITH THE AMERICAN CONCRETE INSTITUTE DETAILING MANUAL. ALL HOOKS AND BENDS IN REINFORCING STEEL SHALL

CONFORM TO ACI DETAILING STANDARDS, UNLESS NOTED OTHERWISE 3. REINFORCING STEEL SUPPORT DEVICES SHALL BE IN ACCORDANCE WITH THE CRSI MANUAL OF STANDARD PRACTICE.

UNSCHEDULED BEAMS, SLABS, COLUMNS, AND WALLS, SHALL HAVE REINFORCING STEEL DETAILED IN ACCORDANCE WITH THE FOLLOWING

A. MINIMUM LAP SPLICE FOR ALL REINFORCING BARS SHALL BE 48 TIMES THE BAR

DIAMETER, UNLESS NOTED OTHERWISE. B. LAP TOP REINFORCING BARS AT MID SPAN

LAP BOTTOM REINFORCING BARS AT SUPPORTS. LAP VERTICAL BARS IN WALLS AND COLUMNS AT FLOOR LINES ONLY, UNLESS NOTED

PROVIDE CORNER BARS, OF SAME SIZE, FOR ALL HORIZONTAL BARS AT THE INSIDE AND OUTSIDE FACES OF INTERSECTING BEAMS OR WALLS.

PROVIDE MINIMUM (2) #4 x 8'-0" BARS AT 45° AT ALL REENTRANT CORNERS IN SLAB ON GRADE AND ELEVATED SLABS.

6. REINFORCING STEEL INTERRUPTED BY OPENINGS OR EMBEDDED ITEMS IN SLABS OR WALLS, SHALL BE COMPENSATED FOR BY REPLACING AN EQUAL AMOUNT OF REINFORCING BARS AT THE SIDES OF THE OPENING, PARALLEL TO UNINTERRUPTED STEEL. COMPENSATION STEEL SHALL EXTEND BEYOND THE EDGE OF OPENING OR EMBED A MINIMUM OF 48 TIMES THE BAR

7. WELDING OF REINFORCING BARS IS NOT PERMITTED, AND HEAT SHALL NOT BE PERMITTED IN THE FABRICATION OR INSTALLATION OF REINFORCEMENT.

WELDED STEEL WIRE FABRIC USED FOR CONCRETE REINFORCING SHALL BE INSTALLED IN FLAT SHEETS, AND SHALL CONFORM TO ASTM A185.

9. MINIMUM CONCRETE COVERAGE FOR REINFORCING STEEL SHALL CONFORM TO THE A. CONCRETE CAST AGAINST AND PERMANENTLY EXPOSED TO EARTH: 3"

#6 BAR OR LARGER 2' #5 BAR OR SMALLER 1 1/2" C. CONCRETE NOT EXPOSED TO WEATHER OR IN CONTACT W/ GROUND: SLABS, WALLS, JOISTS 3/4" BEAMS, COLUMNS 1 1/2"

CONCRETE ANCHORS

ANCHOR BOLTS AND THREADED ROD SHALL BE ASTM F1554 GRADE 36 FURNISHED WITH STD WASHER AND HEAVY HEX NUT, UNO.

ANCHOR BOLTS SPECIFIED AS ASTM F1554 GRADE 55 SHALL CONFORM TO SUPPLEMENT?

EXPANSION ANCHORS SHALL BE: SIMPSON STRONG-BOLT 2

DEWALT POWER-STUD + SD4/SD6 APPROVED EQUIVALENT

4. ADHESIVE ANCHOR SYSTEM IN CONCRETE SHALL BE

B. CONCRETE EXPOSED TO EARTH OR WEATHER:

A. SIMPSON SET-3G SIMPSON AT-3G

DEWALT AC200+ APPROVED EQUIVALENT

65 KSI. ALL ANCHORS SHALL BE 3/4"Ø NELSON STUD OR EQUAL AND BE FULLY WELDED TO THE 4.

POWDER ACTUATED FASTENERS SHALL BE AS SPECIFIED IN THE CONSTRUCTION DOCUMENTS.

8. POST-INSTALLED ANCHORS SHALL BE INSTALLED PER MFR SPECIFICATIONS.

CONTRACTOR SHALL BE RESPONSIBLE FOR LOCATING ALL REINFORCING AND EMBEDDED ITEMS THROUGH NON-DESTRUCTIVE METHODS PRIOR TO POST-INSTALLED ANCHOR INSTALLATION. NO REINFORCEMENT OR EMBEDDED ITEMS SHALL BE CUT. POST-INSTALLED ANCHOR LOCATIONS SHALL BE RELOCATED WITH ENGINEERS APPROVAL WHERE CONFLICTS

10. POST-INSTALLED ANCHORS EXPOSED TO WEATHER OR PRESSURE TREATED LUMBER SHALL BE GALVANIZED OR STAINLESS STEEL

FILL ABANDONED HOLES WITH EPOXY, FLEXIBLE JOINT SEALER OR GROUT.

12. INSTALLATION OF POST-INSTALLED ANCHORS SHALL BE INSPECTED BY THE TESTING AGENCY IN ACCORDANCE WITH THE GOVERNING BUILDING CODE

13. ADHESIVE ANCHORS INSTALLED IN A HORIZONTAL TO VERTICAL OVERHEAD ORIENTATION TO SUPPORT SUSTAINED TENSION LOADS SHALL BE INSTALLED BY A CERTIFIED ADHESIVE ANCHOR INSTALLER (AAI) AS CERTIFIED THROUGH ACI/CRSI. PROOF OF CURRENT CERTIFICATION SHALL BE SUBMITTED TO THE EOR FOR APPROVAL PRIOR TO COMMENCEMENT 4. OF INSTALLATION.

14. ADHESIVE ANCHORS NOT TO BE INSTALLED IN CONCRETE AGED LESS THAN 21 DAYS. 15. DRILLED HOLES FOR ANCHORS SHALL BE OF SIZE & DEPTH AS RECOMMENDED BY THE ANCHOR MANUFACTURER.

16. MINIMUM EDGE DISTANCE FOR POWDER ACTUATED FASTENERS SHALL BE 3 1/2" INTO

CONCRETE 17. MINIMUM SPACING FOR POWDER ACTUATED FASTENERS SHALL BE 5" OC INTO CONCRETE

1. DIMENSIONAL LUMBER FOR RAFTERS, JOISTS AND BEAMS SHALL BE SYP #2 OR DFL #2, 19% KILN-DRY, WITH THE FOLLOWING DESIGN VALUES:

1100 PSI

1000 PSI 925 PSI 175 PSI 800 PSI 175 PSI 2x12 750 PSI 175 PSI

NOT PERMITTED UNLESS SHOWN ON THE STRUCTURAL DRAWINGS OR OTHERWISE

APPROVED.

ALL NAIL HOLES WITH FASTENERS PER MFG.

3. REF SCHEDULE 4 FOR STUD GRADES. 4. ALL PLATES SHALL BE SYP #2 OR DFL #2. BLOCKING AND MISCELLANEOUS FRAMING MAY BE SPF, DF OR SYP STUD GRADE, #3, OR BETTER

ALL MEMBERS ARE CONTINUOUS UNLESS SPECIFICALLY DETAILED OTHERWISE. SPLICES ARE

ALL MEMBERS SHALL BEAR THE STAMP OF AN APPROVED TESTING AGENCY. 6. ALL MEMBERS IN CONTACT WITH CONCRETE OR EXPOSED TO WEATHER SHALL BE OF

NATURALLY DURABLE OR PRESERVATIVE-TREATED WOOD. FASTENERS FOR ATTACHING NATURALLY DURABLE OR PRESERVATIVE TREATED WOOD SHALL BE HOT-DIPPED GALVANIZED STEEL OR STAINLESS STEEL. DEFLECTION OF MEMBERS DUE TO LIVE LOAD SHALL BE LIMITED TO L/360. DEFLECTION OF

MEMBERS DUE TO LIVE LOAD + DEAD LOAD + CREEP SHALL BE LIMITED TO L/240.

8. CONTRACTOR SHALL ENSURE THAT ALL LOADS TRANSFERRED TO BEAMS AND HEADERS ARE TRANSFERRED TO FOUNDATION.

CONSTRUCTION CONDITIONS, AND ARE NOT INTENDED TO REPRESENT MATERIAL OR COMPONENT QUANTITIES REQUIRED. ALL METAL FRAMING CONNECTORS SHALL BE SIMPSON STRONG-TIE. INSTALL ALL HARDWARE PER MFG SPECS. WHERE OPTIONAL NAIL HOLES ARE PROVIDED ON METAL CONNECTORS, FILL

11. ALL FLUSH BEAM AND JOIST CONNECTIONS SHALL BE MADE WITH HANGER SIZES OF ADEQUATE LOAD CARRYING CAPACITY CONFORMING TO LOADS SPECIFIED BY THE GOVERNING CODE, AND SHALL BE THE MINIMUM AVAILABLE FOR THE SPECIFIED BEAM OR

JOIST, UNLESS NOTED OTHERWISE. 12. PROVIDE STANDARD WASHERS FOR MACHINE BOLTS OR LAG SCREWS WITH HEADS OR NUTS

BEARING ON WOOD. 13. PROVIDE MINIMUM FASTENING OF ALL MEMBERS PER IBC TABLE 2304.10.2 UNO.

14. PORTIONS OF THE STRUCTURE WHICH ARE NOT DETAILED ON THE STRUCTURAL DRAWINGS SHALL FOLLOW THE APPLICABLE CONVENTIONAL FRAMING PROVISIONS OF THE GOVERNING

15. WHERE STRAPS ARE INSTALLED OVER WSP, MIN 2 1/2" NAILS SHALL BE USED.

ENGINEERED LUMBER

ENGINEERED LUMBER PRODUCTS HAVE BEEN SPECIFIED BASED ON THE FOLLOWING MINIMUM DESIGN VALUES:

ENGINEERED LUMBER GLUE-LAMINATED TIMBER 2,400 PSI 200 PSI 1.800 KSI 3,000 PSI 290 PSI 2,100 KSI ANTHONY POWER BEAM MICROLLAM LVL 2,600 PSI 285 PSI 1,900 KSI PARALLAM PSL 2,900 PSI 290 PSI 2,000 KSI

ENGINEERED LUMBER MANUFACTURER SHALL DESIGN GLUED-LAMINATED MEMBERS IN ACCORDANCE WITH STANDARD SPECIFICATIONS FOR STRUCTURAL GLUED LAMINATED TIMBER OF SOFTWOOD SPECIES, AITC-117.

MATERIAL, MANUFACTURE AND QUALITY CONTROL SHALL BE IN ACCORDANCE WITH THE LATEST EDITION ANSI A190.1.

CONTRACTOR SHALL PROVIDE MATERIAL SHAPES AND SIZES AS SPECIFIED ON STRUCTURAL DRAWINGS. FINAL MEMBER SIZES ARE SUBJECT TO THE PRODUCT MANUFACTURER.

ENGINEERED LUMBER SUPPLIER SHALL DESIGN AND PROVIDE STEEL CONNECTORS TO JOIN

ENGINEERED LUMBER PRODUCTS. BUILT-UP MEMBERS SHALL BE CONNECTED PER MANUFACTURERS RECOMMENDATIONS. PRE ENGINEERED WOOD TRUSSES

PRE-ENGINEERED WOOD TRUSSES SHALL BE DESIGNED BY A STATE LICENSED REGISTERED PROFESSIONAL ENGINEER IN ACCORDANCE WITH THE LATEST EDITION OF THE "NATIONAL DESIGN SPECIFICATION FOR WOOD CONSTRUCTION," AS RECOMMENDED BY THE NATIONAL FOREST PRODUCTS ASSOCIATION. PROVIDE UPLIFT FORCE UTILIZING C & C PRESSURES. TRUSSES SHALL BE DESIGNED TO BEAR ON ALL LOAD BEARING WALLS.

3. TRUSS MFG TO DESIGN PARALLEL INTERIOR PARTITION WALLS OVER 8'-0" AS UNIFORM LINE 4. TRUSS MANUFACTURER TO COORDINATE TRUSS LAYOUT AND PROFILES WITH ARCH AND MEP.

5. TRUSS MANUFACTURER SHALL INDICATE ALL TEMPORARY AND PERMANENT BRACING AND BRIDGING REQUIREMENTS ON THE TRUSS ERECTION DRAWINGS. 6. THE CONTRACTOR SHALL REVIEW AND FOLLOW ALL REQUIREMENTS OF THE "GUIDE TO GOOD PRACTICE FOR HANDLING, INSTALLING, RESTRAINING & BRACING OF METAL PLATE CONNECTED WOOD TRUSSES" BY BCSI IN ADDITION TO ALL REQUIREMENTS SET FORTH BY

THE TRUSS MFG. 7. ROOF TRUSSES SHALL BE DESIGNED FOR L/240 TOTAL AND L/360 LIVE.

FLOOR TRUSSES SHALL BE DESIGNED FOR L/240 TOTAL AND L/480 LIVE. 9. DESIGN PARAPET TRUSSES FOR FORCES PER "TRUSS PARAPET DESIGN FORCES" TABLE.

STRUCTURAL STEEL

1. DETAILING, FABRICATION AND ERECTION SHALL BE IN ACCORDANCE WITH THE STEEL CONSTRUCTION MANUAL.

2. STRUCTURAL STEEL SHALL CONFORM TO THE FOLLOWING SPECIFICATIONS: A. W-SHAPES - ASTM A992 B. PLATES, RODS, ANGLES, & CHANNELS - ASTM A572, GR 50 OR ASTM A36

C. STEEL HSS - ASTM A500, GR C, Fy = 50 KSI 3. SPLICING OF STEEL MEMBERS IS PROHIBITED UNLESS LOCATION AND TYPE OF SPLICE IS SUBMITTED TO ENGINEER IN SHOP DRAWINGS. AND APPROVED. ANY MEMBERS FOUND TO BE

SPLICED AND NOT PREVIOUSLY APPROVED WILL BE REJECTED COLUMN BASE PLATES SHALL BE GROUTED WITH A HIGH-STRENGTH, NON-SHRINK,

NON-METALLIC GROUT. CONTRACTOR SHALL VERIFY CORRECTNESS OF FIELD CONDITIONS, INCLUDING FOUNDATION,

ANCHOR PLACEMENT, AND OTHER WORK AFFECTING THE STEEL PRIOR TO ERECTION. 6. ALL STRUCTURAL STEEL SHALL BE PRIME PAINTED WITH 1.0 TO 1.5 MIL. DRY FILM THICKNESS GRAY OXIDE-ZINC CHROMATE PRIMER, EXCEPT WHERE FIRE PROTECTION MATERIALS ARE REQUIRED.

7. ALL EXPOSED STEEL SHALL BE EITHER HOT-DIPPED GALVANIZED OR PAINTED, REFER TO ARCHITECTURE.

STRUCTURAL STEEL CONNECTIONS

PROVIDE ASTM A325-N BOLTS W/ HARDENED WASHERS.

1. WELDING SHALL CONFORM TO AWS D1.1 AND SHALL BE PERFORMED WITH E70XX ELECTRODES.

STRUCTURAL STEEL CONNECTIONS NOT SPECIFICALLY DETAILED ON THE DRAWINGS SHALL BE DESIGNED BY FABRICATOR, UNDER THE DIRECT SUPERVISION OF A STATE LICENSED

REGISTERED PROFESSIONAL ENGINEER, AND SEALED CALCULATIONS FOR ALL CONNECTIONS SHALL BE SUBMITTED FOR REVIEW. DESIGN AND DETAILING OF BEAM CONNECTIONS NOT SPECIFICALLY DETAILED ON

STRUCTURAL DRAWINGS SHALL CONFORM TO THE FOLLOWING: A. CONNECTIONS SHALL BE AISC TYPE 2, SIMPLE FRAMING CONNECTIONS (PR-PARTIALLY RESTRAINED.) NO SHEAR TAB CONNECTIONS WILL BE PERMITTED. B. IN GENERAL, SHOP CONNECTIONS SHALL BE WELDED, AND FIELD CONNECTIONS SHALL

C. CONNECTIONS SHALL BE DESIGNED FOR THE SCHEDULED SHEAR FORCES, THE SHEAR FORCE DENOTED AS "V=", AND THE HORIZONTAL FORCE DENOTED AS "H=" ON THE

STRUCTURAL DRAWINGS. D. CONNECTIONS SHALL BE DESIGNED FOR 55 PERCENT OF THE TOTAL LOAD CAPACITY IN THE AISC 325 BEAM TABLES, UNLESS NOTED OTHERWISE. E. PROVIDE MINIMUM NUMBER OF ROWS OF BOLTS EQUAL TO 1/6 OF THE BEAM DEPTH,

ROUNDING FRACTIONS TO THE NEXT HIGHEST NUMBER. F. BOLTS SHALL BE INSTALLED SNUG TIGHT, UNLESS NOTED OTHERWISE G. SHORT SLOTTED HOLES ARE PERMITTED PROVIDED WASHERS ARE INSTALLED IN ACCORDANCE WITH AISC REQUIREMENTS.

5. WHERE CONNECTIONS ARE NOT SPECIFICALLY ADDRESSED BY THE ABOVE NOTES OR ON STRUCTURAL DRAWINGS, FILLET WELDS SHALL BE PROVIDED AT ALL CONTACT SURFACES SUFFICIENT TO DEVELOP THE TENSILE STRENGTH OF THE SMALLER MEMBER. 6. MINIMUM SIZE OF FILLET WELDS SHALL BE 3/16", OR MINIMUM SIZE REQUIRED BY AISC,

HEADED SHEAR STUDS SHALL CONFORM TO ASTM A108 ULTIMATE TENSILE STRENGTH 65 KSI. ALL ANCHORS SHALL BE 3/4"Ø NELSON STUD OR EQUAL AND BE FULLY WELDED TO THE BASE. METAL USING AN AUTOMATIC ARC WELDING STUD GUN.

POWDER ACTUATED FASTENERS SHALL BE AS SPECIFIED IN THE CONSTRUCTION

MINIMUM EDGE DISTANCE FOR POWDER ACTUATED FASTENERS, SHALL BE 1/2" INTO STEEL. 10. MINIMUM SPACING FOR POWDER ACTUATED FASTENERS, INTO STEEL, SHALL BE 1".

WHICHEVER IS GREATER.

SPECIAL INSPECTIONS 1. THE REGISTERED DESIGN PROFESSIONAL IN RESPONSIBLE CHARGE (RDPIRC) FOR THIS PROJECT IS THE ARCHITECT. SUBMIT ALL INSPECTION REPORTS DIRECTLY TO THE RDPIRC FOR REVIEW. SUBMIT A COPY OF THE STRUCTURAL RELATED SPECIAL INSPECTION REPORTS

TO THE EOR REVIEW. THE RDPIRC AND SPECIAL INSPECTORS MAY NOT BE IN THE EMPLOY OF THE GENERAL CONTRACTOR, SUBCONTRACTORS OR MATERIAL SUPPLIERS. IN THE CASE OF AN OWNER/CONTRACTOR, THE BUILDING OFFICIAL SHALL SPECIFY WHO EMPLOYS THE RDPIRC AND SPECIAL INSPECTORS.

3. ALL SPECIAL INSPECTIONS SHALL BE PERFORMED IN ACCORDANCE WITH SECTIONS 1704 AND 1705 OF THE IBC INCLUDING ADOPTED AMENDMENTS. SPECIAL INSPECTIONS ARE IN ADDITION TO INSPECTIONS REQUIRED BY SECTION 110 OF THE IBC.

FABRICATORS SHALL SUBMIT A CERTIFICATE OF COMPLIANCE TO THE RDPIRC STATING THAT ALL WORK WAS PERFORMED UNDER THE INSPECTION SERVICES OF A SPECIAL INSPECTOR OR UNDER THE INSPECTION SERVICES OF A NATIONALLY RECOGNIZED TRADE ORGANIZATION THAT REQUIRES QUALITY CONTROL INSPECTIONS.

IBC SECTION 1705.11

CODE REFERENCE SOILS IBC TABLE 1705.6 CONCRETE IBC SECTION 1705.3 STRUCTURAL STEEL AISC 360

OPEN WEB WOOD TRUSSES

5. SPECIAL INSPECTIONS SHALL COMPLY WITH THE FOLLOWING:

STAIR, HANDRAIL AND GUARD RAIL NOTES

 ALL STAIR. HANDRAIL AND GUARD RAILS NOT DETAILED ON THESE PLANS AND SHALL BE DESIGNED BY A REGISTERED STRUCTURAL ENGINEER. SUBMIT SEALED DRAWINGS & CALCULATIONS TO EOR FOR REVIEW.

2. STAIR STRINGERS, TREADS AND RISERS SHALL BE DESIGNED TO SUPPORT 100 PSF LIVE LOAD.

3. INDIVIDUAL STAIR TREADS SHALL BE DESIGNED TO SUPPORT A 300 POUND CONCENTRATED LOAD PLACED IN A POSITION THAT WOULD CAUSE MAXIMUM STRESS.

4. PER IBC HANDRAILS SHALL BE DESIGNED TO WITHSTAND A LOAD OF 50 PLF APPLIED IN ANY DIRECTION, OR A 200 POUND CONCENTRATED LOAD APPLIED IN ANY DIRECTION. INTERMEDIATE RAILS, PANEL FILLERS AND THEIR CONNECTIONS SHALL BE DESIGNED TO WITHSTAND A LOAD OF 50 PSF APPLIED HORIZONTALLY AT RIGHT ANGLES OVER THE ENTIRE TRIBUTARY AREA, INCLUDING OPENINGS AND SPACES BETWEEN RAILS.

REQUIRED INSPECTIONS

1. CONTRACTOR SHALL UTILIZE A THIRD-PARTY INSPECTION SERVICE TO PROVIDE INSPECTIONS

FOR THE FOLLOWING ITEMS A. SPECIAL INSPECTIONS AS NOTED IN THE "SPECIAL INSPECTIONS" SECTION OF THE

GENERAL NOTES B. INSPECTIONS REQUIRED BY THE AUTHORITY HAVING JURISDICTION

C. SOIL COMPACTION

PRE-CONCRETE PLACEMENT E. SHEAR WALL NAILING AND HARDWARE

F. ROOF SHEATHING NAILING G. FRAMING, INCLUDING UPLIFT HARDWARE

H. STEEL INSTALLATION (SIZE AND LOCATION), WELDING AND BOLTING CONTRACTOR SHALL PROVIDE COPIES OF THE INSPECTION REPORTS FOR ALL ITEMS ABOVE TO THE EOR FOR REVIEW. FOR ITEMS WITH DEFICIENCIES, FOLLOW UP INSPECTIONS SHALL BE

PERFORMED UPON COMPLETION OF CORRECTIONS. 3. REFER TO GENERAL NOTES FOR REQUIRED TESTING

SUBMITTALS

TWENTY WORKING DAYS PRIOR TO SUBMITTING SHOP DRAWINGS, THE CONTRACTOR SHALL SUBMIT FOR EOR'S REVIEW A SCHEDULE WHICH DETAILS THE ESTIMATED QUANTITY OF SHOP DRAWINGS AND THE DATE THE SHOP DRAWINGS WILL BE RECEIVED BY THE EOR. THE EOR SHALL HAVE THE OPPORTUNITY TO REVIEW THE PROPOSED SCHEDULE AND SUBMIT COMMENTS TO THE CONTRACTOR. THE FINAL SHOP DRAWING SCHEDULE SHALL BE DEVELOPED AND SUBMITTED TO THE EOR. IN ACCORDANCE WITH THE SHOP DRAWING SCHEDULE, THE EOR WILL RETURN THE SHOP DRAWING ITEMS WITHIN 20 WORKING DAYS

AFTER HAVING RECEIVED THE REPRODUCIBLE OR ELECTRONIC SHOP DRAWING. 2. THE CONTRACTOR IS TO REVIEW EACH SUBMITTAL PRIOR TO FORWARDING TO ARCHITECT AND EOR. THE CONTRACTOR IS TO STAMP EACH SUBMITTAL VERIFYING THAT THE FOLLOWING

IS ADDRESSED: THE SHOP DRAWING IS REQUESTED.

B. THE SHOP DRAWING IS BASED ON THE LATEST DESIGN. C. THE ARCHITECT'S AND EOR'S COMMENTS FROM ANY PREVIOUS SUBMITTALS ARE

D. THE WORK IS COORDINATED AMONG ALL CONSTRUCTION TRADES. E. REVISIONS FROM PREVIOUS SUBMITTALS ARE CLEARLY MARKED BY CIRCLING OR

F. SUBMITTAL IS COMPLETE. G. SUBMITTAL DOES NOT INCLUDE SUBSTITUTION REQUEST

SHALL BE STARTED WITHOUT SUCH REVIEW.

SUBMITTAL NUMBER, SPECIFICATION SECTION NUMBER. THE EOR SHALL RETURN, WITHOUT COMMENT, SUBMITTALS WHICH THE CONTRACTOR HAS NOT STAMPED OR WHICH DO NOT MEET THE ABOVE REQUIREMENTS. THE EOR'S REVIEW OF

SUBMITTALS SHALL BE FOR GENERAL CONFORMANCE WITH THE DESIGN INTENT. NO WORK

H. SUBMITTAL SHALL INCLUDE A STAMP INDICATING PROJECT NAME AND LOCATION,

FOR COMPONENTS THAT REQUIRE ENGINEERING BY THE CONTRACTOR, PROVIDE A NOTE ON EACH SHOP DRAWING, WRITTEN AND SIGNED BY THE SUPPLIER'S ENGINEER, INDICATING THAT THE SHOP DRAWING IS IN CONFORMANCE WITH THE CALCULATIONS OF THE CONTRACTOR' S ENGINEER.

4. THE FOLLOWING ITEMS REQUIRE SUBMITTALS FOR STRUCTURAL REVIEW

A. CONCRETE REINFORCING LAYOUT B. CONCRETE MIX DESIGNS

D. STRUCTURAL STEEL CONNECTIONS

C. STRUCTURAL STEEL

E. PRE-ENGINEERED TRUSSES PERFORMANCE ITEMS

THE CONTRACTOR SHALL EMPLOY OR RETAIN A LICENSED STRUCTURAL ENGINEER IN THE

STATE IN WHICH THIS PROJECT IS LOCATED TO DESIGN AND DETAIL PERFORMANCE ITEMS AS

PART OF THE BASE BUILDING STRUCTURE BUT NOT LIMITED TO: A. PRE-FABRICATED TRUSSES

SHEET INDEX

STRUCTURAL DRAWINGS

S1.00 - GENERAL NOTES S1.01 - GENERAL NOTES

S3.00B - FRAMING PLANS - HOUSE B

S2.00B - FOUNDATION PLAN - HOUSE B

S4.00B - SHEAR WALL PLANS - HOUSE B S5.00 - FOUNDATION DETAILS

S5.01 - RETAINING WALL DETAILS S6.00 - FRAMING DETAILS

S6.01 - FRAMING DETAILS

S6.02 - FRAMING DETAILS

S6.03 - FRAMING DETAILS

23012.05 NLAI Job #: GMS / CJB Drawn by: EEL Checked by: Date of Issue: 10.29.24

S1.00

ENGINEERING *THINK DESIGN innovate, integrate, implement...

architecture and interiors

220 Industrial Blvd Suite 101 Austin, Texas 78745

P512.851.1900 www.noacklittle.com

Homes at Canyon Lake Lot 521

Valley Ridge

100% CD

424 Valley Ridge

Canyon Lake, TX 78133




10.29.24 100% CD Description

General Notes

GENERAL NOTES

	MINI				OF AND FL		ASTENER		ALT	FASTEN	ERS
LOCATION	MIN THICK	PANEL GRADE	SPAN RATING	BOND CLASS	BLOCKING	SIZE	EDGE	FIELD	SIZE	EDGE	FIELD
TYP ROOF (ZONE 1)	15/32"	APA RATED SHEATHING	32/16	EXP 1	NONE	8d	6"	12"	10d	6"	12"
ROOF EDGE (ZONE 2)	15/32"	APA RATED SHEATHING	32/16	EXP 1	NONE	8d	6"	11"	10d	6"	12"
ROOF EDGE (ZONE 2 OH)	15/32"	APA RATED SHEATHING	32/16	EXP 1	NONE	8d	6"	8"	10d	6"	12"
ROOF CORNER (ZONE 3)	15/32"	APA RATED SHEATHING	32/16	EXP 1	NONE	8d	6"	9"	10d	6"	12"
ROOF CORNER (ZONE 3 OH)	15/32"	APA RATED SHEATHING	32/16	EXP 1	NONE	8d	6"	7"	10d	6"	10"
TYP FLOOR	23/32"	APA RATED STURD-I-FLOOR	24" OC	EXP 1	NONE	10d	6"	12"	WSNTL SCREW	6"	12"
2. INSTALL PANI 3. FASTENERS \$ 4. NO FASTENE 5. DRIVE FASTE 6. WSP SHALL F 7. FLOOR SHEA	ELS WITH SPECIFIED RS SHALL NERS FLU IAVE AN E THING SH	CKNESS WITH UL L LONG DIMENSION DARE COMMON NA BE CLOSER THAN JSH. DO NOT PENE FFECTIVE G OF 0.5 ALL BE TONGUE & LY BELOW ALL ROO	PERPENDIO AILS, UNO. 3/8" FROM TRATE THE 50 MIN. GROOVE.	CULAR TO PANEL ED SURFACE	GE.	THING.					



0147			0544	DOND	FRM @	JOINTS	FASTENERS			ALT FASTENERS		
SW MARK	MIN THICK	PANEL GRADE	SPAN RATING	BOND CLASS	VEDT	HORZ	SIZE	SPACING		SIZE	SPACING	
vi/ ti ti t		OIVIDE	1011110	02/100	VERT	HUKZ	SIZE	EDGE	FIELD	SIZE	EDGE	FIELD
W	1/2" MIN, REF ARCH FOR 5/8" LOCATIONS	GYPSUM WALL BOARD	-	-	2x	NONE	5d COOLER	8"	12"	1 1/4" x #6 TYPE S OR W SCREWS	8"	12"
W7	1/2" MIN, REF ARCH FOR 5/8" LOCATIONS	GYPSUM WALL BOARD	-	-	2x	NONE	5d COOLER	7"	7"	1 1/2" x 16GA STAPLE	7"	7"
W4	1/2" MIN, REF ARCH FOR 5/8" LOCATIONS	GYPSUM WALL BOARD	-	-	2x	NONE	5d COOLER	4"	4"	1 1/2" x 16GA STAPLE	4"	4"
6	15/32"	APA RATED SHEATHING	32/16	EXP 1	2x	2x	8d BOX	6"	12"	1 1/2" x 16GA STAPLE	3"	12"
4	15/32"	APA RATED SHEATHING	32/16	EXP 1	2x	2x	8d BOX	4"	12"	10d	4"	12"
3	15/32"	APA RATED SHEATHING	32/16	EXP 1	(2) 2x	(2) 2x OR FLAT 2x	8d BOX	3"	12"	10d	4"	12"
2	15/32"	APA RATED SHEATHING	32/16	EXP 1	(2) 2x	(2) 2x OR FLAT 2x	8d BOX	2"	12"	10d	3"	12"

B 3 2x4 2x4 2x6 A HD3B (2) 2x 5/8" 9" 6" 6" 6" - HD3B BACK TO BACK (4) 2x 5/8" 6" - C HD7B (3) 2x 7/8" 12" 9" NP 9" - HD9B (3) 2x 7/8" 12" 9" NP NP - HD9B (3) 2x 7/8" 12" 9" NP NP - HD9B (3) 2x 7/8" 12" 9" NP NP - HD9B (3) 2x 7/8" 12" 9" NP NP - HD9B (3) 2x 7/8" 12" 9" NP NP -		HOLDOWN HD3B HD5B HD3B BACK TO BACK HD7B HD9B	(2) 2x (3) 2x (4) 2x (3) 2x (3) 2x	5/8" 5/8" 7/8"	9" 9" - 12"	AB EMBEDM ADHES INT & 1 1/2" x 5 1/2" LUG 6" 6" - 9" 9"	ENT SIVE ED 2x4 6" NP 6" NP	2x6 6" 6" - 9" NP	- - - -		BUMARK A B C D E F G H	QUANTITY	SIZE 2x4 2x4 2x4 2x4 2x6 2x6 2x6 2x6
11. SCHEDULE A OPTION 2 IS NOT PERMITTED @ SW2. 12. 10d COMMON ARE NOT PERMITTED WITH SCHEDULE A OPTION 2. 13. WHERE WSP ARE USED IN LIEU OF METAL CONNECTORS AT W AND W7 WALLS, SHEATH PER SW6. 14. WSP MAY BE 3/8" MIN WHERE 10d COMMON ARE NOT USED & OPTION 2 IS NOT USED. 15. OSB MAY BE 7/16" MIN WHERE 10d COMMON ARE NOT USED. 16. WHERE SW IS CONTINUOUS ACROSS INTERSECTING WALLS, REF DETAIL 42. 17. WHERE SW IS CONTINUOUS ACROSS WALL FURRING, SHEATHING SHALL BE CONTINUOUS BEHIND WALL FURRING. 19. WSP MAY BE INSTALLED OVER GYPSUM WALL BURNER, SHEATHING SHALL BE CONTINUOUS BEHIND WALL FURRING. 19. WSP MAY BE INSTALLED OVER GYPSUM WALL FURRING, SHEATHING SHALL BE CONTINUOUS BEHIND WALL FURRING. 20. AT W7 AND W4 WALLS IT IS ACCEPTABLE TO USE 1 1/4" x #6 TYPE S OR W SCREWS AT THE INDICATED SPACING OR IN A 4" EDGE AND 12" FIEL SPACING IF HORZ JOINTS ARE BLOCKED. SCHEDULE 3 - HOLDOWN SCHEDULE 3 - HOLDOWN SCHEDULE 6 - BUILT-UP POST MARK QUANTITY SIZE A HD3B (2) 2x 5/8" 9" 6" NP 6" - LUG 2x4 2x4 B 3 3 2x4 C 4 2x4 C 4 2x4 C 4 2x4 C 4 2x4 C 7 7 8" 12" 9" NP 9" - G 7 4 2x6 HD3B BACK TO BACK (4) 2x 5/8" 12" 9" NP NP 9" - HD9B (3) 2x 7/8" 12" 9" NP NP - HD9B (3) 2x 7/8" 12" 9" NP NP -	ВС	HOLDOWN HD3B HD5B HD3B BACK TO BACK HD7B	(2) 2x (3) 2x (4) 2x (3) 2x	5/8" 5/8" 5/8"	9" 9" - 12"	AB EMBEDM ADHES INT & 1 1/2" x 5 1/2" LUG 6" 6" - 9"	ENT SIVE ED 2x4 6" NP 6" NP	2x6 6" 6" -	- - - -		BUMARK A B C D E F G	ULT-UP POS QUANTITY 2 3 4 5 2 3 4	SIZE 2x4 2x4 2x4 2x4 2x4 2x6 2x6 2x6
11. SCHEDULE A OPTION 2 IS NOT PERMITTED @ SW2. 12. 10d COMMON ARE NOT PERMITTED WITH SCHEDULE A OPTION 2. 13. WHERE WSP ARE USED IN LIEU OF METAL CONNECTORS AT W AND W7 WALLS, SHEATH PER SW6. 14. WSP MAY BE 3/8" MIN WHERE 10d COMMON ARE NOT USED & OPTION 2 IS NOT USED. 15. OSB MAY BE 7/16" MIN WHERE 10d COMMON ARE NOT USED. 16. WHERE SW IS CONTINUOUS ACROSS INTERSECTING WALLS, REF DETAIL 42. 17. WHERE SW IS CONTINUOUS ACROSS WALL FURRING, SHEATHING SHALL BE CONTINUOUS BEHIND WALL FURRING. 19. WSP MAY BE INSTALLED OVER GYPSUM WALL BOARD W1 10d @ 8 BOX SPACING. 20. AT W7 AND W4 WALLS IT IS ACCEPTABLE TO USE 1 1/4" x #6 TYPE S OR W SCREWS AT THE INDICATED SPACING OR IN A 4" EDGE AND 12" FIE SPACING IF HORZ JOINTS ARE BLOCKED. SCHEDULE 3 - HOLDOWN AB EMBEDMENT ADHESIVE NOTES HOLDOWN ADHESIVE NOTES A 2 2x4 B 3 2x4 C 4 2x4 C 7 7 2x5 C 7 7 2x6 C 7 7 2x6 C 7 7 2x7 C 7 2x7	요 A B	HOLDOWN HD3B HD5B HD3B BACK TO BACK	SQDLS (2) 2x (3) 2x (4) 2x	5/8" 5/8"	9" 9"	AB EMBEDM ADHES INT & 1 1/2" x 5 1/2" LUG 6" 6"	MENT SIVE ED 2x4 6" NP 6"	2x6 6" 6"	-		BL MARK A B C D E	ULT-UP POS QUANTITY 2 3 4 5 2 3	SIZE 2x4 2x4 2x4 2x4 2x4 2x6 2x6
11. SCHEDULE A OPTION 2 IS NOT PERMITTED @ SW2. 12. 10d COMMON ARE NOT PERMITTED WITH SCHEDULE A OPTION 2. 13. WHERE WSP ARE USED IN LIEU OF METAL CONNECTORS AT W AND W7 WALLS, SHEATH PER SW6. 14. WSP MAY BE 3/8" MIN WHERE 10d COMMON ARE NOT USED & OPTION 2 IS NOT USED. 15. OSB MAY BE 7/16" MIN WHERE 10d COMMON ARE NOT USED. 16. WHERE SW IS CONTINUOUS ACROSS INTERSECTING WALLS, REF DETAIL 42. 17. WHERE SW IS CONTINUOUS ACROSS OPENINGS, REF DETAIL 44. 18. WHERE SW IS CONTINUOUS ACROSS WALL FURRING, SHEATHING SHALL BE CONTINUOUS BEHIND WALL FURRING. 19. WSP MAY BE INSTALLED OVER GYPSUM WALL BOARD W/ 10d @ 8d BOX SPACING. 20. AT W7 AND W4 WALLS IT IS ACCEPTABLE TO USE 1 1/4" x #6 TYPE S OR W SCREWS AT THE INDICATED SPACING OR IN A 4" EDGE AND 12" FIE SPACING IF HORZ JOINTS ARE BLOCKED. SCHEDULE 3 - HOLDOWN ADHESIVE ADHESIVE LUG ADHESIVE LUG ADHESIVE LUG ADHESIVE LUG ADHESIVE LUG ADHESIVE NOTES A 2 2x4 B 3 2x4 C 4 2x4 C 7 2x4 C	구 A	HOLDOWN HD3B HD5B	SGDLS (2) 2x (3) 2x	VERT BOLT Ø	dIO "	AB EMBEDM ADHES INT & 1 1/2" x 5 1/2" LUG 6"	ENT SIVE ED 2x4 6" NP	2x6 6"	-		BL MARK A B C D	ULT-UP POS QUANTITY 2 3 4 5 2	SIZE 2x4 2x4 2x4 2x4 2x4 2x6
11. SCHEDULE A OPTION 2 IS NOT PERMITTED @ SW2. 12. 10d COMMON ARE NOT PERMITTED WITH SCHEDULE A OPTION 2. 13. WHERE WSP ARE USED IN LIEU OF METAL CONNECTORS AT W AND W7 WALLS, SHEATH PER SW6. 14. WSP MAY BE 3/8" MIN WHERE 10d COMMON ARE NOT USED & OPTION 2 IS NOT USED. 15. OSB MAY BE 7/16" MIN WHERE 10d COMMON ARE NOT USED. 16. WHERE SW IS CONTINUOUS ACROSS INTERSECTING WALLS, REF DETAIL 42. 17. WHERE SW IS CONTINUOUS ACROSS OPENINGS, REF DETAIL 44. 18. WHERE SW IS CONTINUOUS ACROSS WALL FURRING, SHEATHING SHALL BE CONTINUOUS BEHIND WALL FURRING. 19. WSP MAY BE INSTALLED OVER GYPSUM WALL BOARD W/ 10d @ 8d BOX SPACING. 20. AT W7 AND W4 WALLS IT IS ACCEPTABLE TO USE 1 1/4" x #6 TYPE S OR W SCREWS AT THE INDICATED SPACING OR IN A 4" EDGE AND 12" FIE SPACING IF HORZ JOINTS ARE BLOCKED. SCHEDULE 3 - HOLDOWN ADHESIVE ADHESIVE NOTES A 2 2x4 B 3 2x4 C 4 2x4 C 7 4 2x4 C 7 4 2x4 C 7 5 2x4 C 7 5 2x4 C 7 5 2x4 C 7 7 5 2x4 C 8 7 5 2x4 C 9 5 5 2x4 C 9 5 5 2x4 C 9 5 5 2x4	구 A	HOLDOWN HD3B	SQUTS (2) 2x	© VERT BOLT Ø	dIO "	AB EMBEDM ADHES INT & 1 1/2" x 5 1/2" LUG 6"	MENT SIVE ED 2x4 6"	2x6 6"	-		BL MARK A B C D	ULT-UP POS QUANTITY 2 3 4 5	SIZE 2x4 2x4 2x4 2x4 2x4
11. SCHEDULE A OPTION 2 IS NOT PERMITTED @ SW2. 12. 10d COMMON ARE NOT PERMITTED WITH SCHEDULE A OPTION 2. 13. WHERE WSP ARE USED IN LIEU OF METAL CONNECTORS AT W AND W7 WALLS, SHEATH PER SW6. 14. WSP MAY BE 3/8" MIN WHERE 10d COMMON ARE NOT USED & OPTION 2 IS NOT USED. 15. OSB MAY BE 7/16" MIN WHERE 10d COMMON ARE NOT USED. 16. WHERE SW IS CONTINUOUS ACROSS INTERSECTING WALLS, REF DETAIL 42. 17. WHERE SW IS CONTINUOUS ACROSS OPENINGS, REF DETAIL 44. 18. WHERE SW IS CONTINUOUS ACROSS WALL FURRING, SHEATHING SHALL BE CONTINUOUS BEHIND WALL FURRING. 19. WSP MAY BE INSTALLED OVER GYPSUM WALL BOARD W/ 10d @ 8d BOX SPACING. 20. AT W7 AND W4 WALLS IT IS ACCEPTABLE TO USE 1 1/4" x #6 TYPE S OR W SCREWS AT THE INDICATED SPACING OR IN A 4" EDGE AND 12" FIE SPACING IF HORZ JOINTS ARE BLOCKED. SCHEDULE 3 - HOLDOWN SCHEDULE 6 - BUILT-UP POST MARK QUANTITY SIZE A 2 2x4 B 3 2x4 C 4 2x4 C 4 2x4	<u> </u>	HOLDOWN	STUDS	VERT BOLT Ø	CIP	AB EMBEDM ADHES INT & 1 1/2" x 5 1/2" LUG	MENT SIVE ED 2x4	2x6	NOTES		MARK A B C	ULT-UP POS QUANTITY 2 3 4	SIZE 2x4 2x4 2x4
11. SCHEDULE A OPTION 2 IS NOT PERMITTED @ SW2. 12. 10d COMMON ARE NOT PERMITTED WITH SCHEDULE A OPTION 2. 13. WHERE WSP ARE USED IN LIEU OF METAL CONNECTORS AT W AND W7 WALLS, SHEATH PER SW6. 14. WSP MAY BE 3/8" MIN WHERE 10d COMMON ARE NOT USED & OPTION 2 IS NOT USED. 15. OSB MAY BE 7/16" MIN WHERE 10d COMMON ARE NOT USED. 16. WHERE SW IS CONTINUOUS ACROSS INTERSECTING WALLS, REF DETAIL 42. 17. WHERE SW IS CONTINUOUS ACROSS OPENINGS, REF DETAIL 44. 18. WHERE SW IS CONTINUOUS ACROSS WALL FURRING, SHEATHING SHALL BE CONTINUOUS BEHIND WALL FURRING. 19. WSP MAY BE INSTALLED OVER GYPSUM WALL BOARD W/ 10d @ 8d BOX SPACING. 20. AT W7 AND W4 WALLS IT IS ACCEPTABLE TO USE 1 1/4" x #6 TYPE S OR W SCREWS AT THE INDICATED SPACING OR IN A 4" EDGE AND 12" FIE SPACING IF HORZ JOINTS ARE BLOCKED. SCHEDULE 3 - HOLDOWN AB EMBEDMENT ADHESIVE NOTES A 2 2x4 B 3 2x4				BOLT Ø		AB EMBEDM ADHES INT & 1 1/2" x 5 1/2"	MENT SIVE ED		NOTES		MARK A B	ULT-UP POS QUANTITY 2 3	SIZE 2x4 2x4
11. SCHEDULE A OPTION 2 IS NOT PERMITTED @ SW2. 12. 10d COMMON ARE NOT PERMITTED WITH SCHEDULE A OPTION 2. 13. WHERE WSP ARE USED IN LIEU OF METAL CONNECTORS AT W AND W7 WALLS, SHEATH PER SW6. 14. WSP MAY BE 3/8" MIN WHERE 10d COMMON ARE NOT USED & OPTION 2 IS NOT USED. 15. OSB MAY BE 7/16" MIN WHERE 10d COMMON ARE NOT USED. 16. WHERE SW IS CONTINUOUS ACROSS INTERSECTING WALLS, REF DETAIL 42. 17. WHERE SW IS CONTINUOUS ACROSS OPENINGS, REF DETAIL 44. 18. WHERE SW IS CONTINUOUS ACROSS WALL FURRING, SHEATHING SHALL BE CONTINUOUS BEHIND WALL FURRING. 19. WSP MAY BE INSTALLED OVER GYPSUM WALL BOARD W/ 10d @ 8d BOX SPACING. 20. AT W7 AND W4 WALLS IT IS ACCEPTABLE TO USE 1 1/4" x #6 TYPE S OR W SCREWS AT THE INDICATED SPACING OR IN A 4" EDGE AND 12" FIE SPACING IF HORZ JOINTS ARE BLOCKED. SCHEDULE 3 - HOLDOWN AB EMBEDMENT A B EMBEDMENT MARK QUANTITY SIZE A 2 2x4				BOLT Ø		AB EMBEDN ADHES	MENT	GE	NOTES		BL MARK A	JILT-UP POS QUANTITY 2	SIZE 2x4
11. SCHEDULE A OPTION 2 IS NOT PERMITTED @ SW2. 12. 10d COMMON ARE NOT PERMITTED WITH SCHEDULE A OPTION 2. 13. WHERE WSP ARE USED IN LIEU OF METAL CONNECTORS AT W AND W7 WALLS, SHEATH PER SW6. 14. WSP MAY BE 3/8" MIN WHERE 10d COMMON ARE NOT USED & OPTION 2 IS NOT USED. 15. OSB MAY BE 7/16" MIN WHERE 10d COMMON ARE NOT USED. 16. WHERE SW IS CONTINUOUS ACROSS INTERSECTING WALLS, REF DETAIL 42. 17. WHERE SW IS CONTINUOUS ACROSS OPENINGS, REF DETAIL 44. 18. WHERE SW IS CONTINUOUS ACROSS WALL FURRING, SHEATHING SHALL BE CONTINUOUS BEHIND WALL FURRING. 19. WSP MAY BE INSTALLED OVER GYPSUM WALL BOARD W/ 10d @ 8d BOX SPACING. 20. AT W7 AND W4 WALLS IT IS ACCEPTABLE TO USE 1 1/4" x #6 TYPE S OR W SCREWS AT THE INDICATED SPACING OR IN A 4" EDGE AND 12" FIE SPACING IF HORZ JOINTS ARE BLOCKED. SCHEDULE 3 - HOLDOWN AB EMBEDMENT A B EMBEDMENT MARK QUANTITY SIZE A 2 2x4	MAKK			BOLT Ø		AB EMBEDM ADHES	MENT		NOTES		BL MARK	JILT-UP POS QUANTITY	ST SIZE
11. SCHEDULE A OPTION 2 IS NOT PERMITTED @ SW2. 12. 10d COMMON ARE NOT PERMITTED WITH SCHEDULE A OPTION 2. 13. WHERE WSP ARE USED IN LIEU OF METAL CONNECTORS AT W AND W7 WALLS, SHEATH PER SW6. 14. WSP MAY BE 3/8" MIN WHERE 10d COMMON ARE NOT USED & OPTION 2 IS NOT USED. 15. OSB MAY BE 7/16" MIN WHERE 10d COMMON ARE NOT USED. 16. WHERE SW IS CONTINUOUS ACROSS INTERSECTING WALLS, REF DETAIL 42. 17. WHERE SW IS CONTINUOUS ACROSS OPENINGS, REF DETAIL 44. 18. WHERE SW IS CONTINUOUS ACROSS WALL FURRING, SHEATHING SHALL BE CONTINUOUS BEHIND WALL FURRING. 19. WSP MAY BE INSTALLED OVER GYPSUM WALL BOARD W/ 10d @ 8d BOX SPACING. 20. AT W7 AND W4 WALLS IT IS ACCEPTABLE TO USE 1 1/4" x #6 TYPE S OR W SCREWS AT THE INDICATED SPACING OR IN A 4" EDGE AND 12" FIE SPACING IF HORZ JOINTS ARE BLOCKED. SCHEDULE 3 - HOLDOWN AB EMBEDMENT BUILT-UP POST	_ خ			Ø	LE :	AB EMBEDM	MENT				BL	JILT-UP POS	ST
11. SCHEDULE A OPTION 2 IS NOT PERMITTED @ SW2. 12. 10d COMMON ARE NOT PERMITTED WITH SCHEDULE A OPTION 2. 13. WHERE WSP ARE USED IN LIEU OF METAL CONNECTORS AT W AND W7 WALLS, SHEATH PER SW6. 14. WSP MAY BE 3/8" MIN WHERE 10d COMMON ARE NOT USED & OPTION 2 IS NOT USED. 15. OSB MAY BE 7/16" MIN WHERE 10d COMMON ARE NOT USED. 16. WHERE SW IS CONTINUOUS ACROSS INTERSECTING WALLS, REF DETAIL 42. 17. WHERE SW IS CONTINUOUS ACROSS OPENINGS, REF DETAIL 44. 18. WHERE SW IS CONTINUOUS ACROSS WALL FURRING, SHEATHING SHALL BE CONTINUOUS BEHIND WALL FURRING. 19. WSP MAY BE INSTALLED OVER GYPSUM WALL BOARD W/ 10d @ 8d BOX SPACING. 20. AT W7 AND W4 WALLS IT IS ACCEPTABLE TO USE 1 1/4" x #6 TYPE S OR W SCREWS AT THE INDICATED SPACING OR IN A 4" EDGE AND 12" FIE SPACING IF HORZ JOINTS ARE BLOCKED. SCHEDULE 3 - HOLDOWN BCHEDULE 6 - BUILT-UP POST			SCH	Ø	LE:								
11. SCHEDULE A OPTION 2 IS NOT PERMITTED @ SW2. 12. 10d COMMON ARE NOT PERMITTED WITH SCHEDULE A OPTION 2. 13. WHERE WSP ARE USED IN LIEU OF METAL CONNECTORS AT W AND W7 WALLS, SHEATH PER SW6. 14. WSP MAY BE 3/8" MIN WHERE 10d COMMON ARE NOT USED & OPTION 2 IS NOT USED. 15. OSB MAY BE 7/16" MIN WHERE 10d COMMON ARE NOT USED. 16. WHERE SW IS CONTINUOUS ACROSS INTERSECTING WALLS, REF DETAIL 42. 17. WHERE SW IS CONTINUOUS ACROSS OPENINGS, REF DETAIL 44. 18. WHERE SW IS CONTINUOUS ACROSS WALL FURRING, SHEATHING SHALL BE CONTINUOUS BEHIND WALL FURRING. 19. WSP MAY BE INSTALLED OVER GYPSUM WALL BOARD W/ 10d @ 8d BOX SPACING. 20. AT W7 AND W4 WALLS IT IS ACCEPTABLE TO USE 1 1/4" x #6 TYPE S OR W SCREWS AT THE INDICATED SPACING OR IN A 4" EDGE AND 12" FIE SPACING IF HORZ JOINTS ARE BLOCKED.			SCH	EDU	LE :	3 - HOLDOV	WN				S	CHEDULE 6	-
11. SCHEDULE A OPTION 2 IS NOT PERMITTED @ SW2. 12. 10d COMMON ARE NOT PERMITTED WITH SCHEDULE A OPTION 2. 13. WHERE WSP ARE USED IN LIEU OF METAL CONNECTORS AT W AND W7 WALLS, SHEATH PER SW6. 14. WSP MAY BE 3/8" MIN WHERE 10d COMMON ARE NOT USED & OPTION 2 IS NOT USED. 15. OSB MAY BE 7/16" MIN WHERE 10d COMMON ARE NOT USED. 16. WHERE SW IS CONTINUOUS ACROSS INTERSECTING WALLS, REF DETAIL 42. 17. WHERE SW IS CONTINUOUS ACROSS OPENINGS, REF DETAIL 44. 18. WHERE SW IS CONTINUOUS ACROSS WALL FURRING, SHEATHING SHALL BE CONTINUOUS BEHIND WALL FURRING. 19. WSP MAY BE INSTALLED OVER GYPSUM WALL BOARD W/ 10d @ 8d BOX SPACING. 20. AT W7 AND W4 WALLS IT IS ACCEPTABLE TO USE 1 1/4" x #6 TYPE S OR W SCREWS AT THE INDICATED SPACING OR IN A 4" EDGE AND 12" FIE													
9. DRIVE FASTENERS FLUSH, DO NOT PENETRATE THE SURFACE OF THE SHEATHING.	10 11 12 13 14 15 16 17 18	. WHERE WSP IS REQD . SCHEDULE A OPTION . 10d COMMON ARE NO . WHERE WSP ARE USE . WSP MAY BE 3/8" MIN . OSB MAY BE 7/16" MIN . WHERE SW IS CONTIN . WSP MAY BE INSTALLI . AT W7 AND W4 WALLS	AND AF 2 IS NO T PERM D IN LIE WHERE I WHERI IUOUS A IUOUS A ED OVE B IT IS A	RCH RE T PERI IITTED EU OF I E 10d C ACROS ACROS ACROS ER GYP CCEPT	EQUIFMITTE WITH META OMMO COMMO SS INT SS OP SS WA SSUM TABLE	RES GYPSUM WALED @ SW2. I SCHEDULE A OPLL CONNECTORS & ON ARE NOT USE ON ARE NOT	L BOAI PTION 2 AT W A D & OP ED. LS, REI FAIL 44. EATHIN 10d @ 8	RD FOR .ND W7 .TION 2 F DETA G SHAL 8d BOX	WALLS, SHEATH IS NOT USED. IL 42. L BE CONTINUOUSPACING.	PER SW6. JS BEHIND	WALL FURRING	G.	ND 12" FIE
									SUM WALL BOAR	D.			
	3.	PROVIDE 6d COOLER									RATION.		
6. INSTALL STAPLES WITH CROWNS PARALLEL TO LONG DIMENSION OF FRAMING WITH 1" MIN PENETRATION. 7. PROVIDE 6d COOLER NAILS OR 1 5/8" LONG STAPLES W/ 5/8" THICK GYPSUM WALL BOARD. 8. NO FASTENERS SHALL BE CLOSER THAN 3/8" FROM PANEL EDGE.	7. 8.			WNS P	۸РЛ	LEL TO LONG DIN	4ENICIO						

4. STUDS SHALL BE SPACED @ 16" OC MAX UNO.

	II T-UP PO	SCHEDULE 6 - BUILT-UP POST						
MARK	QUANTITY	SIZE						
Α	2	2x4						
В	3	2x4						
С	4	2x4						
D	5	2x4						
E	2	2x6						
F	3	2x6						
G	4	2x6						
Н	5	2x6						
WALL FRAM 2. FACE NAIL 3. TRUSSES S BUILT-UP P AREA OF TI 4. ALL BUILT-U	W/ (2) 10d @ 8" (SHALL BE SUPPO OST COMPRISII HE TRUSS BEAF JP POST SHALL US TO THE FOU	OC @ EA PLY ORTED BY NG THE FULL RING (MIN). BE						

SCHEDULE 7 - BUILT-UP JAMB

LOCATION KING JACK KING JACK KING JACK

UPPERMOST 1 1 1 1 - -

FIRST OF 3 2 1 2 2 2 2

STUD SIZE & MATERIAL SHALL MATCH STUD WALL FRAMING.
 FACE NAIL W/ (2) 10d @ 8" OC @ EA PLY.
 ALL BUILT-UP JAMBS SHALL BE CONTINUOUS TO THE FOUNDATION

SECOND OF 3 1 1 1 2 -

OR BEAM BELOW.

	EERED LUMBER (N MEMBER(S)	· · · · · · · · · · · · · · · · · · ·
LAN MARK	` '	HANGER
B207	1 3/4" x 7 1/4"	HU7
B209	1 3/4" x 9 1/4"	HU7
B211	1 3/4" x 11 1/4"	HU11
B214	1 3/4" x 14"	HU14
B405	(2) 1 3/4" x 5 1/2"	-
B407	(2) 1 3/4" x 7 1/4"	HHUS48
B409	(2) 1 3/4" x 9 1/4"	HHUS410
B411	(2) 1 3/4" x 11 1/4"	HHUS410
B414	(2) 1 3/4" x 14"	HHUS410
B416	(2) 1 3/4" x 16"	HGUS412
B418	(2) 1 3/4" x 18"	HGUS412
B505	(3) 1 3/4" x 5 1/2"	-
B507	(3) 1 3/4" x 7 1/4"	HU68
B509	(3) 1 3/4" x 9 1/4"	HHUS5.50/10
B511	(3) 1 3/4" x 11 1/4"	HHUS5.50/10
B514	(3) 1 3/4" x 14"	HHUS5.50/10
B516	(3) 1 3/4" x 16"	HHUS5.50/10
B518	(3) 1 3/4" x 18"	HHUS5.50/10
B711	(4) 1 3/4" x 11 1/4"	HHUS7.25/10
B714	(4) 1 3/4" x 14"	HHUS7.25/10
B716	(4) 1 3/4" x 16"	HHUS7.25/10
B718	(4) 1 3/4" x 18"	HHUS7.25/10
	SAWN LUMBER	
AN MARK	MEMBER	HANGER
126	(1) 2x6	HU26
128	(1) 2x8	HU28
1210	(1) 2x10	HU210
1212	(1) 2x12	HU212
224	(2) 2x4	HU24-2
226	(2) 2x6	HU26-2
228	(2) 2x8	HU26-2
2210	(2) 2x10	HU210-2
2212	(2) 2x12	HU212-2
326	(3) 2x6	HU26-3
328	(3) 2x8	HU28-3
3210	(3) 2x10	HU210-3
3212	(3) 2x12	HU212-3
4212	(4) 2x12	HHUS210-4

PLAN LEGEND

ITEM

SECTION CUT

ELEVATION MARKER FOUNDATION

EXTERIOR OR

BEARING WALL, REF SCHEDULE

LOAD BEARING

EXTERIOR OR BEARING WALL W/ STUDS @ X" OC X KING STUDS AND Y JACK STUDS BUILT-UP POST, REF SCHEDULE SHEAR WALL, REF SCHEDULE DESIGN TRUSS TOP

CHORD FOR ADDITIONAL LIVE LOAD PER PLAN

16d BOX (3 1/2" X 0.135")

10d COMMON (3" x 0.148")

8d BOX (2 1/2" x 0.113")

€ 6d COOLER (1 7/8" x 0.092")

€ 6d WALLBOARD (1 7/8" x 0.092")

5d COOLER (1 5/8" x 0.086")

SUBSTITUTED FOR 5d COOLER NAILS. 2. 6d WALLBOARD NAILS MAY BE

SUBSTITUTED FOR 6d COOLER NAILS. 3. ADDITIONAL NAIL SIZES MAY BE REQUIRED

1. 5d WALLBOARD NAILS MAY BE

W/ METAL CONNECTORS.

8d COMMON (2 1/2" x 0.131

10d (3" x 0.128")

 NAIL INFORMATION & REQS

 HEAD DIA PEN DIA
 MIN PEN DIA PENDENDIA PEN DIA PENDENDIA PEN DIA PENDENDIA PENDENDIA

5/16" 1 1/2"

5/16" 1 3/8"

9/32" 1 3/8"

19/64" 1 1/4"

1/4" 1"

MARK

1. PROVIDE (2) 2x6 MIN HDR OVER OPNGS IN EXT & LOAD BRG 2x4 WALLS.
2. PROVIDE (3) 2x6 MIN HDR OVER OPNGS IN EXT & LOAD BRG 2x6 WALLS.
3. PROVIDE (1) 2x FLAT OVER OPNGS IN INT NON-LOAD BRG WALLS UP TO 6'-0'
REF DETAIL 45 FOR OPNGS OVER 6'-0".
4. ENGINEERED LUMBER IS MICROLLAM LVL (LAMINATED VENEER LUMBER).
CONTACT ENGINEER FOR ALTERNATE MATERIAL.
5. DROPPED BEAMS IN PARALLEL WALLS SHALL BE SUPPORTED IN
ACCORDANCE W/ THE BUILT-UP JAMB SCHEDULE.
6. ALL BEAMS BEARING ON WALL SHALL BE SUPPORTED BY BUILT-UP POSTS
WITH EDGE DIMENSIONS THAT AT LEAST MATCH THE WIDTH OF THE BEAM
ONE DIRECTION AND THE WIDTH OF THE WALL IN THE OTHER, UNO. ALL
BEAMS BEARING ON FREE STANDING COLUMNS SHALL BE SUPPORTED BY
BUILT-UP POSTS WITH EDGE DIMENSIONS THAT AT LEAST MATCH THE WID
OF THE BEAM IN BOTH DIRECTIONS, UNO.
7. REF DETAIL 25 FOR TYPICAL BUILT-UP BEAM FASTENERS.

ABBREVIATION	DEFINITION	ABBREVIATION	DEFINITION
AAC	AUTOCLAVE AERATED CONCRETE	JB	JOIST BEARING
AB	ANCHOR BOLT	KSI	KIPS PER SQUARE INCH
ACI	AMERICAN CONCRETE INSTITUTE	LG	LIGHT GAUGE
ADDL	ADDITIONAL	LBS	POUNDS
ADJ	ADJACENT	LLH	LONG LEG HORIZONTAL
AISC	AMERICAN INSTITUTE OF STEEL CONSTRUCTION	LLV	LONG LEG VERTICAL
AISI	AMERICAN IRON AND STEEL INSTITUTE	LVL	LEVEL, LAMINATED VENEER LUMBER
APPROX	APPROXIMATE, APPROXIMATELY	MAS	MASONRY
ARCH	ARCHITECTURAL, ARCHITECT	MATL	MATERIAL
ASCE	AMERICAN SOCIETY OF CIVIL ENGINEERS	MAX	MAXIMUM
ASTM	AMERICAN SOCIETY FOR TESTING AND	MECH	MECHANICAL
	MATERIALS	MEP	MECHANICAL, ELECTRICAL & PLUMBING
AWS	AMERICAN WELDING SOCIETY	MFR, MFG	MANUFACTURER
BBE	BEAM BY ENGINEER OF RECORD	MIN	MINIMUM
BM	BEAM DOTTOM OF DEAM	MISC	MISCELLANEOUS
BOB	BOTTOM OF BEAM	MTL	METAL
BOD	BOTTOM OF DECK	MWFRS	MAIN WIND FORCE RESISTING SYSTEM
BOF BRG	BOTTOM OF FOOTING	NA	NOT APPLICABLE
	BEARING	NP	NOT PERMITED
BTM BTWN	BOTTOM BETWEEN	NTS	NOT TO SCALE
CANT	CANTILEVER	OC	ON CENTER
CANT	CANTILEVER CAST IN PLACE	OCEW	ON CENTER EACH WAY
CJ	CONTROL JOINT	OH	OPPOSITE HAND
CL	CENTROL SOINT CENTER LINE	OPNG	OPENING
CLG	CEILING	OPP	OPPOSITE
CLR	CLEAR	OSB	OREINTED STRAND BOARD
CMU	CONCRETE MASONRY UNIT	PAF	POWDER ACTUATED FASTENER
COL	COLUMN	PCI	PRECAST CONCRETE INSTITUTE
C&C	COMPONENTS AND CLADDING	PERP	PERPENDICULAR
CONC	CONCRETE	PJ	PANEL JOINT
CONN	CONNECTION	PL	PLATE
CONST	CONSTRUCTION	PLF	POUNDS PER LINEAR FOOT
CJ	CONSTRUCTION JOINT	PSF	POUNDS PER SQUARE FOOT
CONT	CONTINUOUS	PSI	POUNDS PER SQUARE INCH
CONV	CONVENTIONAL	PT	POST-TENSION
CRSI	CONCRETE REINFORCING STEEL INSTITUTE	PTI	POST-TENSIONING INSTITUTE
DBL	DOUBLE	REF REINF	REFERENCE REINFORCING, REINFORCEMENT
DEMO	DEMOLITION, DEMOLISH	REQD	REQUIRED
DET, DTL	DETAIL	REQS	REQUIREMENTS
DIA	DIAMETER	SCHED	SCHEDULE
DIAG	DIAGONAL	SCL	STRUCTURAL COMPOSITE LUMBER
EA	EACH	SIM	SIMILAR
EE	EACH END	SJI	STEEL JOIST INSTITUTE
EF	EACH FACE	SPA	SPACE
EJ	EXPANSION JOINT	SPECS	SPECIFICATIONS
ELEV	ELEVATION, ELEVATOR	STD	STANDARD
EOR	ENGINEER OF RECORD	STL	STEEL
EQ	EQUAL	STRUCT	STRUCTURAL
ES	EACH SIDE	SW	SHEARWALL
EXIST	EXISTING	TBM	TRUSS BY MANUFACTURER
EXT	EXTERIOR	T/B	TOP AND BOTTOM
FND, FDN	FOUNDATION	TDI	TDI ENGINEERING, LLC
FF	FINISHED FLOOR	TO	TOP OF
FIN	FINISHED	ТОВ	TOP OF BEAM
FRP	FIBER REINFORCEMENT POLYMER	TOC	TOP OF CONCRETE
FV	FIELD VERIFY	TOF	TOP OF FOOTING
GA	GAUGE	TOP	TOP OF PARAPET, TOP OF PANEL, TOP OF PI
GALV	GALVANIZED	TOS	TOP OF STEEL
GT	GIRDER TRUSS	TOW	TOP OF WALL
GYP	GYPSUM BOARD	TPL	TRIPLE
HCP	HOLLOW CORE PLANK	TYP	TYPICAL
HD	HOLDOWN	UNO	UNLESS NOTED OTHERWISE
HORZ, HORIZ	HORIZONTAL	VERT	VERTICAL
HSA	HEADED STUD ANCHOR	VIF	VERIFY IN FIELD
HSS	HOLLOW STRUCTURAL SECTION	W/	WITH
HT	HEIGHT	WSP	WOOD STRUCTURAL PANEL (PLYWOOD OR C
IBC	INTERNATIONAL BUILDING CODE	\\/T	WEIGHT


INSULATED CONCRETE FORM

ABBREVIATIONS LIST

ABBREVIATIONS LIST

	HOLDOWN	STUDS	VERT BOLT Ø	AB EMBEDMENT				
HD MARK					ADHESIVE			
				CIP	INT & 1 1/2" x 5 1/2" LUG	EDGE		NOTES
						2x4	2x6	
Α	HD3B	(2) 2x	5/8"	9"	6"	6"	6"	-
В	HD5B	(3) 2x	5/8"	9"	6"	NP	6"	-
D	HD3B BACK TO BACK	(4) 2x	5/8"	-	-	6"	-	-
С	HD7B	(3) 2x	7/8"	12"	9"	NP	9"	-
D	HD9B	(3) 2x	7/8"	12"	9"	NP	NP	-
ט	HD7B BACK TO BACK	(6) 2x	7/8"	-	-	NP	9"	-
Ε	HD12	(3) 2x	1"	18"	12"	NP	NP	-
F	DBL HD12	(6) 2x	1"	18"	12"	NP	NP	-
Α	CS16 W/ (7) #10 FASTENER EE	(2) 2x						-
В	CMSTC16	(2) 2x						-
С	CMST14	(3) 2x						-
D	CMST12	(3) 2x						-
 3. 4. 5. 	HOLDOWNS SHALL BE HOLDOWNS AT EXP JO EMBED DEPTH IS FROM THICKEN SLAB AREAS REFERENCE DETAIL 39 REFERENCE "CONCRE" ADHESIVE ANCHOR SY FACE NAIL STUDS W/ (2	INTS SHALLOWE AS REC I. TE AND STEMS 2) 10d @	HALL BEST CO QUIRED CMU A	E INS NC SI TO F ANCH	TALLED PER EDG URFACE AT DROP PROVIDE MIN 6" CO ORS" IN GENERAL	E REQ: S & LU ONCRE . NOTE	GS. TE CO\	•

SCHEDULE 4 - STUD WALL							
LOCATION	EXTERIOR	INT LOAD BRG	PL HEIGHT				
UPPERMOST	2x6 @ 16" OC	2x6 @ 16" OC	8'-0"				
SECOND OF 3	2x6 @ 16" OC	2x6 @ 16" OC	8'-1/2"				
FIRST OF 3	2x6 @ 16" OC	2x6 @ 16" OC	8'-6 1/2"				
2. 2x6 STUDS SHAL 3. INT NON-LOAD B OR BETTER @ 10 4. FINGER JOINTED 5. WHERE STUDS A ADD'L STUDS SH 6. SYP OR DFL STU FOR SPF STUDS 7. PLATE HEIGHT IS OR FLOOR SHEA 8. FACE NAIL BUILT 19. ALL STUDS SHAI 10. STUDS INDICAT 11. STUDS INDICAT 12. STUDS INDICAT 13. STUDS INDICAT	FIRST OF 3 2x6 @ 16" OC 2x6 @ 16" OC 8"-6 1/2" 1. 2x4 STUDS SHALL BE SPF STUD GRADE (Fb = 600 PSI) OR BETTER. 2. 2x6 STUDS SHALL BE SPF STUD GRADE (Fb = 600 PSI) OR BETTER. 3. INT NON-LOAD BRG STUDS SHALL BE 2x4 SPF STUD GRADE (Fb = 600 PSI) OR BETTER @ 16" OC. 4. FINGER JOINTED STUDS ARE PERMITTED. 5. WHERE STUDS ARE CUT OR NOTCHED BEYOND CODE APPROVED LIMITS, ADD'L STUDS SHALL BE ADDED. 6. SYP OR DFL STUDS OF EQUAL GRADE AND SPACING MAY BE SUBSTITUTED FOR SPF STUDS. 7. PLATE HEIGHT IS APPROXIMATE AND MEASURED FROM TOP OF CONCRETE OR FLOOR SHEATHING, REF ARCH FOR EXACT DIMENSIONS. 8. FACE NAIL BUILT UP STUDS W/ (2) 10d @ 8" OC EA PLY. 9. ALL STUDS SHALL BE CONTINUOUS TO THE FOUNDATION OR BEAM BELOW. 10. STUDS INDICATED AS 8" OC SHALL BE DOUBLE STUDS @ 16" OC. 11. STUDS INDICATED AS 6" OC SHALL BE TRIPLE STUDS @ 12" OC. 12. STUDS INDICATED AS 5.3" OC SHALL BE TRIPLE STUDS @ 16" OC. 13. STUDS INDICATED AS 4" OC SHALL BE TRIPLE @ 12" OC. 14. REF DETAILS 27, 28, & 40-43 FOR COMMON WALL FRAMING DETAILS						



"Ldh" TENSION DEVELOPMENT LENGTH (EMBEDMENT LENGTH)							
FOR STANDARD END HOOKS							
(GRADE 60 UNCOATED BARS)							
		NOF	RMAL WEIGHT CO	NCRETE			
	/	2" MIN COVER (*)		∤ Ldh			
	Ldh	EXPO:	" MIN COVER ON SED SURFACES. CREASE Ldh DIM • NECESSARY (*)		v	STD 180° HOOK N/ SIDE COVER == 2 1/2" (*)	
BAR SIZE	f'c = 3000 PSI	f'c = 4000 PSI	f'c = 4500 PSI	f'c = 5000 PSI	f'c = 6000 PSI	f'c = 8000 F	
DAIT OIZE	Ldh	Ldh	Ldh	Ldh	Ldh	Ldh	
#3	6"	6"	6"	6"	6"	6"	
#4	8"	7"	7"	6"	6"	6"	
	10"	9"	8"	8"	7"	6"	
#5							
#5 #6	1'-0"	10"	10"	9"	9"	8"	
	1'-0" 1'-2"	10" 1'-0"	10" 11"	9" 11"	9" 10"	8" 9"	
#6		. •				-	
#6 #7	1'-2"	1'-0"	11"	11"	10"	9"	
#6 #7 #8	1'-2"	1'-0"	11"	11"	10" 11"	9"	

		IGHT CONCRETE		
BAR SIZE	f'c = 4000 PSI	f'c = 4500 PSI	fc = 5000 PSI	
	Ld	Ld	Ld	
#3	1'-7"	1'-6"	1'-5"	
#4	2'-1"	2'-0"	1'-11"	
#5	2'-7"	2'-7"	2'-4"	
#6	3'-1"	2'-11"	2'-10"	
#7	4'-6"	4'-3"	4'-1"	
#8	5'-2"	4'-11"	4'-8"	
#9	5'-10"	5'-6"	5'-3"	
#10	6'-7"	6'-2"	5'-11"	
#11	7'-3"	6'-10"	6'-6"	
SPACING LESS THA AND STIR THAN COI DEVELOP CLEAR CO MULTIPLY	ED VALUES ARE AP OF BARS BEING DE IN "Db", CLEAR COV RUPS OR TIES THE DE MINIMUM, OR C ED OR SPLICED IS OVER IS NOT LESS TABLE HODIZONE	EVELOPED OR SPL /ER IS NOT LESS T ROUGHOUT "Ld" IS LEAR SPACING OF NOT LESS THAN 2 THAN "Db". FOR O IES BY 1.5.	ICED IS NOT HAN "Db", NOT LESS BARS BEING "Db", AND THER CASES,	
12" OF FR	RS ARE HORIZONTA ESH CONCRETE CA MENT LENGTH.			
VALUES E		·		
	XY COATED BARS, BY 1.5 FOR BOTTON			
	, <u></u>	,		

5. FOR REINFORCEMENT OTHER THAN GRADE 60, MODIFY THE

REINFORCEMENT YIELD STRENGTH DIVIDED BY 60 KSI.

TABULATED VALUES BY THE RATIO OF THE

Valley Ridge Homes at Canyon Lake

NoackLittle

220 Industrial Blvd Suite 101 Austin, Texas 78745 P512.851.1900 www.noacklittle.com


architecture and interiors


*THINK DESIGN innovate,

integrate, implement...
PROJECT # 157-217

Lot 521 424 Valley Ridge Canyon Lake, TX 78133

100% CD





NLAI Job #:	23012.0
Drawn by:	GMS / CJ
Checked by:	EE
Date of Issue:	10 20 2

S1.01

FOUNDATION PLAN NOTES NOTES, SECTIONS, DIMENSIONS, DROPS, SLOPES, ANCHOR BOLTS, ETC SHOWN IN ONE UNIT OR QUADRANT ARE TYPICAL AT ALL LOCATIONS.


VERIFY ALL DIMENSIONS, DROPS, SLOPES, ETC WITH ARCH PRIOR TO CONSTRUCTION. ARCH PRIOR TO CONSTRUCTION. 3. ALL ELEVATIONS ARE RELATIVE TO TOP OF CONC AT 1ST FLOOR = 100'-0".


4. SLAB THICKNESS SHALL BE 4" MIN WITH #3

@ 14" OCEW, UNO, SLAB DEPTH SHALL BE MAINTAINED THROUGH ALL DROPS, SLOPES, ETC.

5. GRADE BEAM WIDTH SHALL BE 12" MIN AND DEPTH SHALL BE 20" MIN LINO GRADE BEAM WIDTH SHALL BE 12" MIN AND DEPTH SHALL BE 20" MIN, UNO.
 EXT FOOTINGS & GRADE BEAMS SHALL BEAR 18" MIN BELOW FINISHED GRADE, UNO.
 INCREASE DEPTH OF EXTERIOR FOOTINGS AND GRADE BEAMS AS REQUIRED TO MAINTAIN MINIMUM EMBEDMENT INTO FINISHED GRADE.
 REF DETAIL 'X' REFERS TO THE DETAIL ON THE FOLINDATION DETAIL SHEETS. REF DETAIL 'X' REFERS TO THE DETAIL ON THE FOUNDATION DETAIL SHEETS.
 REF DETAIL 'C' FOR ADD'L REINFORCEMENT AT FOOTING AND WALL CORNERS.
 REF DETAIL 'G' FOR ADD'L REINFORCEMENT AT PLUMBING PENETRATIONS.
 REF DETAIL 'B' FOR WALL ANCHOR BOLTS.
 REF DETAIL 'H' FOR HOLDOWN ANCHOR BOLTS.

architecture and interiors 220 Industrial Blvd Suite 101 Austin, Texas 78745 P512.851.1900 www.noacklittle.com







Valley Ridge Homes at Canyon Lake

Lot 521 424 Valley Ridge Canyon Lake, TX 78133

100% CD






NLAI Job #:
Drawn by:
Checked by:
Date of Issue: 23012.05 GMS / CJB EEL 10.29.24


Foundation Plan House B


S2.00B



House B ROOF FRAMING PLAN 1/4" = 1'-0"

ADDL. ORT AS REDD
TO FRAME DIPENNO
TO FR





ROOF FRAMING PLAN LEGEND

(1) EXTEND RAFTERS BELOW TO BEAM/PLATE. PROVIDE FLAT

2 BRACE RAFTERS TO PLATE/BEAM W/ SIMPSON H3 CLIPS

(3) PROVIDE 2x BLOCKING @ MAX 24" OC BETWEEN RAFTERS

TO SUPPORT OVER-FRAMED DORMER.

(4) EXIST PURLIN BRACE TO BEAM/WALL BELOW.

2x12 OVER RAFTERS BELOW TO SUPPORT OVER-FRAMED

@ 16" OC. STRAP PLATE TO STUD W/ SIMPSON H6 @ 32" OC.

RIDGE, VALLEY, OR HIP SUPPORT

SUPPORT LOCATION

House B
3RD LEVEL CEILING FRAMING PLAN
1/4" = 1'-0"

House B
2ND LEVEL CEILING FRAMING PLAN
1/4" = 1'-0"

House B
1ST LEVEL CEILING FRAMING PLAN
1/4" = 1'-0"

NoackLittle
architecture and interiors

220 Industrial Blvd
Suite 101
Austin, Texas 78745
P512.851.1900
www.noacklittle.com

FRAMING PLAN NOTES

NOTES, SECTIONS, DIMENSIONS, DROPS, SLOPES,

ONE UNIT OR QUADRANT ARE TYPICAL AT ALL

REF GENERAL NOTES, SCHEDULE 5, FOR ALL

UNMARKED INTERIOR AND EXTERIOR HEADERS,

REF DETAIL "X" REFERS TO THE DETAIL ON THE

DESIGN. THESE LOADS ARE GENERATED FROM ROOF, CEILING, AND WALL LOADS ABOVE. LINE LOADS SHOWN REPRESENT LOAD-BEARING WALLS ONLY, TRUSS MFR SHALL CONSIDER PARTITION WALLS NOT SHOWN. LOADS PROVIDED ARE ASD. SPACE FLOOR TRUSSES TO PROVIDE CLEARANCE ABOVE MECHANICAL AREAS, COORD W/ MEP. EXTEND EXTERIOR WALLS AT PORCHES AND ENTRIES UP TO ROOF DECK FOR FIRE RATINGS AT THOSE

LOCATIONS. COORDINATE WITH ARCH.

ARCH PRIOR TO CONSTRUCTION.

1ST FLOOR = 100'-0".

TYP UNO ON PLANS.

FRAMING DETAIL SHEETS.

STUDS, JAMBS, BEAMS, COLUMNS, BLOCKING, DRAG

VERIFY ALL DIMENSIONS, DROPS, SLOPES, ETC WITH

ALL ELEVATIONS ARE RELATIVE TO TOP OF CONC AT


TRUSSES, SHEAR WALLS, HOLDOWNS, ETC SHOWN IN




Valley Ridge Homes at Canyon Lake

Lot 521 424 Valley Ridge Canyon Lake, TX 78133

100% CD





 NLAI Job #:
 23012.05

 Drawn by:
 GMS / CJB

 Checked by:
 EEL


 Date of Issue:
 10.29.24

Sheet Title:

Framing Plans - House B

S3.00B


NoackLittle architecture and interiors 220 Industrial Blvd Suite 101 Austin, Texas 78745 P512.851.1900 www.noacklittle.com





Valley Ridge Homes at Canyon Lake

Lot 521 424 Valley Ridge Canyon Lake, TX 78133


100% CD








Shear Wall Plans - House B





CONCRETE COLUMN LINE 6 @ LEVEL 1 W/ CS16 @ OPNGS

House B
3RD LEVEL SHEAR WALL PLAN

1/8" = 1'-0"


House B
2ND LEVEL SHEAR WALL PLAN

House B
1ST LEVEL SHEAR WALL PLAN

1/8" = 1'-0"

1/8" = 1'-0"

S4.00B



NoackLittle
architecture and interiors

220 Industrial Blvd
Suite 101
Austin, Texas 78745
P512.851.1900
www.noacklittle.com

*THINK DESIGN innovate, integrate, implement...


PROJECT # 157-517

Valley Ridge Homes at Canyon Lake

Lot 521 424 Valley Ridge Canyon Lake, TX 78133

100% CD





Drawn by:

Checked by:

Date of Issue:

Checked by:

Date of Issue:

Date of Issue:

Checked by:

Date of Issue:


Date of Issue:


Foundation Details

Sheet Title:

S5.00


RETAINING WALL SCHEDULE														
WALL HEIGHT "H"	WALL WIDTH "W"	FOOTING THICKNESS "FT"	FOOTING WIDTH "FW"	TOE WIDTH	KEY DEPTH	BENT VERT REINF "L1"	BENT VERT REINF "L2"	VERT LEG DIM "X1"	VERT LEG DIM "X2"	VERT WALL REINF "V1"	VERT WALL REINF "V2"	HORIZ WALL REINF "H1"	HORIZ WALL REINF "H2"	TRANSVERSE HEEL REINF
0'-6'	8"	1'-0"	3'-6"	0'-6"	-	#5 @ 12"	-	2'-6"	-	#5 @ 12"	-	#4 @ 12"	-	#5 @ 12"
6'-8'	10"	1'-0"	4'-6"	1'-0"	1'-0"	#4 @ 12"	#4 @ 12"	2'-6"	2'-6"	#4 @ 12"	#4 @ 12"	#4 @ 12"	#4 @ 12"	#5 @ 12"








LOT 521, 424 VALLEY RIDGE

SITE PLAN









(3) #5 x 30" T/B

/ IN FOOTING & AT HORIZ

REINF SPACING IN WALL

REINFORCING EA FACE OF WALL

(2) #5 x 30" T/B

_ _ _ _ _ _ _

RETAINING WALL,

RETAINING WALL CORNER / INTERSECTION REINF (PLAN VIEW)

REINF NOT SHOWN FOR CLARITY, REF SCHED

∠IN FOOTING & AT HORIZ

REINF SPACING IN WALL

THE TOPOGRAPHIC AND ELEVATION DATA SHOWN HEREON WAS OBTAINED FROM CIVIL AND IS NOT CERTIFIED AS CORRECT BY THIS ENGINEER. USERS OF THIS DATA DO SO AT THEIR OWN RISK.

1. ALL TOW, TOF, TOC, ETC ARE FOR DESIGN PURPOSES ONLY. REF CIVIL & ARCH FOR REQUIRED ELEVATIONS. 2. CIVIL GRADING & DETENTION / WATER QUALITY INFORMATION ARE SHOWN FOR COORDINATION PURPOSES ONLY. REFER TO MOST CURRENT CIVIL PLANS FOR FINAL GRADING. NOTIFY ENGINEER OF ANY DISCREPANCIES, SPECIFICALLY

- GRADING DIFFERENCES GREATER THAN 3". . WALLS / FOOTINGS ARE DESIGNED FOR WORST CASE LOADING OF POND, WITH OR WITHOUT WATER, AND PERIMETER BACKFILL / GRADES AS SHOWN ON CIVIL PLANS. REFER TO CIVIL FOR COORDINATION OF ALL PLAN DIMENSIONS.
- PROVIDE 30" x 30" CORNER BARS AT EACH LAYER OF WALL & FOOTING REINFORCING, MATCHING SIZE & QUANTITY.
- 5. PROVIDE CONSTRUCTION JOINTS, PER DETAIL J/S5.01. 6. STEP FOOTINGS ARE REQUIRED PER DETAIL S/S5.01. 7. MATERIALS:

#5 x 30" T/B

RETAINING WALL,

REINF NOT SHOWN FOR CLARITY, REF SCHED

✓ IN FOOTING & AT HORIZ

REINF SPACING IN WALL

#5 x 30" T/B

IN FOOTING & AT HORIZ

REINF SPACING IN WALL

SINGLE LAYER REINFORCING CENTER OF WALL

- A. SELECT FILL BACKFILL PER GEOTECHNICAL REPORT B. FILTER FABRIC - MARAFI 140N OR APPROVED EQUIVALENT C. REF DRAINING GRAVEL - HARD, DURABLE, CLEAN, WASHED WELL-GRADED GRAVEL, OR CRUSHED STONE RANGING IN SIZE FROM 5/8" TO 1" FREE OF ORGANIC MATTER, CLAY BALLS, OR OTHER DELETERIOUS MATTER. D. PERFORATED PVC PIPE - SCHEDULE 40 PVC WITH (2) ROWS OF 1/2"Ø HOLES
- ON 5" CENTERS. ROWS SHALL BE PARALLEL TO AXIS OF PIPE, 120° APART. PIPE SHALL BE ORIENTED WITH PERFORATIONS ON TOP. E. REF C/S5.01 FOR ADDITIONAL REINFORCEMENT AT FOOTING & WALL CORNERS. F. REF DETAIL F/S5.01 FOR FENCING AT TOP OF RETAINING WALL.

ENGINEERING *THINK DESIGN innovate, integrate, implement...
PROJECT # 157-217

NoackLittle

220 Industrial Blvd

Suite 101 Austin, Texas 78745 P512.851.1900 www.noacklittle.com


architecture and interiors



Lot 521 424 Valley Ridge Canyon Lake, TX 78133

100% CD






23012.05 GMS / CJB EEL NLAI Job #: Drawn by: Checked by: 10.29.24 Date of Issue:

Retaining Wall Details

S5.01



FLUSH BEAM, REF PLAN (2x10 MIN)

BEAM REF SCHED -(USE CONNECTOR 'A1' @ PERPENDICULAR WALL)

ALT CONDITION W/ BEAM

A2

LSTA15

LSTA18

ST6224

ST6224

NA

CONNECTOR

OR HD3B

OR HD3B

OR HD3B

CS16 OR HD3B

CS16 OR HD3B

OR HD5B

CS14 OR HD3B HD3B

CMSTC16 (2) HD3B BACK

CMSTC16 (2) HD3B BACK

CMSTC16 (2) HD3B BACK

OR HD3B TO BACK

C1

SPH4 OR SPH6

CSP18 OR SPH6

CS16

TO BACK

SCHEDULE F - HIGH UPLIFT LOAD PATH CONNECTORS

H10A OR MTS16

H10A OR HTS24

1125 # HTS24 OR HD3B ST6215

OR HD3B

OR HD3B

HD3B

MGT OR VGT

OR HD3B

MGT OR VGT

3500 # MGT OR HD5B NA

3700 # (2) VGT OR HD5B NA

. CONTRACTOR SHALL SUBMIT TO THE EOR FOR REVIEW AND APPROVAL, A LIST OF PROPOSED CONNECTORS, ALONG WITH A KEY PLAN IDENTIFYING THEIR LOCATIONS

2. CONTRACTOR SHALL COORDINATE LOCATION OF TRUSSES, BLOCKING AND OTHER

6. CENTER 'A2' STRAP ON DOUBLE TOP PLATE AT FLUSH BEAMS.7. CONTACT ENGINEER FOR UPLIFT LOADS GREATER THAN THOSE LISTED IN SCHEDULE

5. NOTCH FLOOR SHEATHING AS REQD FOR INSTALLATION OF STRAPS AT INTERIOR LOCATIONS.

3. INSTALL HOLDOWN ANCHOR BOLTS WITH MIN EDGE DISTANCE PER DETAIL 'H'. 4. MIN LAP 'L' SHALL BE: CS20 - 9"; CS18 - 11"; CS16 - 14"; CS14 - 19"; CMSTC16 - 25".

OR HD3B

1700 # LGT2 OR HD3B

CONNECTOR 'A2' @ PARALLEL

WALL, CORNER, OR DROPPED

760 #

925#

2500 #

3000 #

PRIOR TO PROCUREMENT OF FRAMING HARDWARE.

FRAMING WITH HARDWARE CONNECTION REQUIRED.

HIGH LIFT TIE DOWN

MIN TRUSS /

STUDS

BEAM PLYS & UPLIFT

REF DET 1, 2, & 3 FOR MIN LAP.

-PROVIDE MAX 3" OC NAILING TO ALL EDGE AND FIELD MEMBERS

—REF DET 1, 2, & 3 FOR MIN LAP.

SCHEDULE B - BEARING WALL OPENING CONNECTORS

LOCATION

ELSEWHERE

UPPERMOST

ELSEWHERE

4. NOTCH FLOOR SHEATHING AS REQD FOR INSTALLATION OF CONNECTOR 'T' AT INT LOCATIONS.

6. WHERE BEAM ABOVE GROUPED OPENINGS IS CONTINUOUS, OPENING WIDTH IN TABLE SHALL

BE FROM OUTSIDE TO OUTSIDE OF OUTERMOST OPENINGS (EXCLUDING BEAMS WITH POST

5. CONNECTOR 'U' MAY BE OMITTED WHERE A SHEAR WALL HOLDOWN IS REQD IN THE SAME LOCATION.

7. FULL HEIGHT OPENINGS IN BALCONY ENCLOSURE WALLS SHALL HAVE CONNECTORS PER SCHEDULE.

STUD TO STUD

LOCATION STUD TO SILL PL

MULTI-STORY

1-STORY

MULTI-STORY

1-STORY

CS22 MULTI-STORY
- 1-STORY

SECTION A-A @

UPPERMOST LEVEL

W/ OPTION 2

- LINE UP AND CONNECT TO COMMON FRAMING MEMBERS.

3. CONNECTOR 'T' SHALL BE INSTALLED ON KING STUDS ONLY.

8. REF SCHEDULE 3 FOR HOLDOWN REQUIREMENTS.

- BE PLACED ON SAME SIDE OF WALL AS ROOF FRAMING CLIPS. 2. MIN METAL STRAP LENGTHS: CS20 - 42"; CS18 - 46"; CS16 - 52"; CS14 - 62"

(MAX) LOCATION BEAM TO

3'-0" TYPICAL

6'-0" TYPICAL

9'-0" TYPICAL

. CONNECTORS SHALL:


CONNECTOR 'U'


ON KING STUDS,

REF SCHED B

OPENINGS AT EXTERIOR & ROOF BEARING WALLS

TOC =





7. LOCATE SDWF SCREWS MAX 4" FROM WALL ENDS.

ROOF TRUSS BLOCKS

REF SCHED F

BUILT-UP COLUMN

TO MATCH TRUSS —

WIDTH (MIN)

CONNECTOR 'B1',

REF SCHED F

BLOCK SOLID @

EA CONNECTOR

SIM AT

END WALL

CONNECTOR 'B1',


CONNECTOR 'C1',

REF SCHED F

REF SCHED F

SCHEDULE E - ROOF FRAMING CLIPS / STRAPS							
ELEMENTS	ALLOWABLE UPLIFT	CONNECTOR					
	60 #	NONE REQD					
	535 #	H2.5A					
TRUSS TO DBL TOP PLATE	650 #	TSP					
	1070 #	(2) H2.5A					
	> 1070 #	REF DETAIL 5					
CONTRACTOR SHALL SUBMIT A LIST OF PROPOSED CONNECTORS, ALONG WITH A KEYED PLAN IDENTIFYING THEIR LOCATIONS TO EOR FOR REVIEW AND APPROVAL PRIOR TO PROCURMENT OF HARDWARE.							
2. INSTALL CONNECTORS ON OUTSIDE OF WALL AT EXTERIOR CONDITIONS.							
WHERE (2) CLIPS ARE REQD ON A SINGLE 2x MEMBER, LOCATE ON OPPOSITE SIDE OF FRAMING AND WALL.							
4. ROOF FRAMING CONNECTORS SHALL BE INSTALLED ON THE SAME SIDE OF WALL AS WSP WHERE WSP IS PRESENT AT INTERIOR.							

ROOF FRAMING CLIP SCHED



WALL BELOW SPACING		DESIGN SHEAR	NAILING TO PLATE	
LENGTH < 5'-4"	NOT REQD	-	-	
TYPICAL	EVERY THIRD	360 PLF	(2) 10d @ 8" OC (6 PER 24" SPACE)	
W7 OR PARTY WALL	EVERY OTHER	400 PLF	(2) 10d @ 6" OC (8 PER 24" SPACE)	
6		365 PLF	(2) 10d @ 8" OC (6 PER 24" SPACE)	
4	EVEDY ODAGE	532 PLF	(2) 10d @ 4" OC (10 PER 24" SPACE)	
3	EVERY SPACE	645 PLF	(2) 10d @ 8" OC (10 PER 24" SPACE)	
2		840 PLF	(2) 10d @ 3" OC (16 PER 24" SPACE)	

SCHEDULE C - ROOF TRUSS BLOCKING


SPACING DESIGN SHEAR NAILING TO PLATE

(MIN 6 PER BLOCK)

8 FLOOR TRUSS BLOCKS

NTS


NoackLittle architecture and interiors 220 Industrial Blvd Suite 101 Austin, Texas 78745 P512.851.1900 www.noacklittle.com




Valley Ridge Homes at Canyon Lake

Lot 521 424 Valley Ridge Canyon Lake, TX 78133

100% CD





23012.05 GMS / CJB EEL 10.29.24 Checked by: Date of Issue:

Framing Details

S6.00

CONNECTOR 'S',

CONNECTOR 'T'

ON KING STUDS, —

REF SCHED B

BLOCK SOLID

(1) AB WITHIN

12" OF JAMB


@ STRAP

REF SCHED B

WOOD BEAM @ CONCRETE COLUMN

NoackLittle
architecture and interiors


220 Industrial Blvd
Suite 101
Austin, Texas 78745
P512.851.1900
www.noacklittle.com




Valley Ridge Homes at Canyon Lake

Lot 521 424 Valley Ridge Canyon Lake, TX 78133

100% CD






Drawn by: GMS / CJB
Checked by: EEL
Date of Issue: 10.29.24


_ . _ .

Framing Details

S6.01




NoackLittle architecture and interiors 220 Industrial Blvd Suite 101 Austin, Texas 78745 P512.851.1900 www.noacklittle.com




Valley Ridge Homes at Canyon Lake

Lot 521 424 Valley Ridge Canyon Lake, TX 78133

100% CD






23012.05 GMS / CJB EEL 10.29.24 Checked by: Date of Issue:

Framing Details

S6.02



NoackLittle
architecture and interiors

220 Industrial Blvd
Suite 101
Austin, Texas 78745
P512.851.1900
www.noacklittle.com

*THINK DESIGN innovate, integrate, integrate, wastin, TX 78749

Austin, TX 78749

Austin, TX 78749


S12-301-3389 | www.tdi-llc.net

Valley Ridge Homes at Canyon Lake

Lot 521 424 Valley Ridge Canyon Lake, TX 78133

100% CD





Drawn by:

Checked by:

Date of Issue:

Checked by:

Date of Issue:

Date of Issue:

Date of Issue:

Framing Details

S6.03

From: Ritzen,Brenda
To: Marisa Kane

Cc: Chadwick Fox; robert@eaglerocktx.com

Subject: RE: 118239

Date: Tuesday, April 29, 2025 8:17:00 AM

Attachments: 118239.pdf image001.png

mageour.pnc

Marisa:

A copy of the Permit to Construct is attached.

Thank you,



Brenda Ritzen

Environmental Health Coordinator 195 David Jonas Dr. New Braunfels, TX 78132 DR:OS00007722 830-608-2090 www.cceo.org

From: Marisa Kane <bri>dgewayllc1@gmail.com>

Sent: Monday, April 28, 2025 1:52 PM **To:** Ritzen,Brenda <rabbjr@co.comal.tx.us>

Cc: Chadwick Fox <chad.f@2x2capitalmanagement.com>; robert@eaglerocktx.com

Subject: Re: 118239

This email originated from outside of the organization.

Do not click links or open attachments unless you recognize the sender and know the content

- Comal IT

Good afternoon, Brenda,

Attached is the revised planning materials for this one for review.

Thank you.

Regards,





BURRIER NIXON ENGINEERS

Reg. No. F-24967 CHRISTINE NIXON, P.E. 9901 BRODIE LN, STE 160, PMB 195 AUSTIN, TX 78748 (512) 694-0537

April 24, 2025

Comal County Comments Response

424 (Lot 521) Valley Ridge, Canyon Lake, TX (Permit 118239)

- The actual physical address assigned to this property is 584 Valley Ridge.
 The correct address for Lot 521 is 424 Valley Ridge. The planning materials have been updated.
- 2) The physical address of the maintenance provider is needed on the maintenance contract.
 - The maintenance contract has been updated.
- 3) Please have the maintenance provider certify that the signature on the contract is his actual signature.
 - The maintenance contract has been updated
- 4) The maintenance contract must indicate that the start date of the contract is the date the "License to Operate" is issued (not LTO).
 - The maintenance contract has been updated
- 5) The maintenance contract must indicate a maintenance schedule in accordance with state regulations, it must also provide the required minimum number of service visits for the 2 year period (8 over 2 years). The maintenance contract has been updated
- 6) Identify the minimum 1 ft setback from the edge of the drip field to the utility easements.
 - A 1 foot setback is now indicated.
- 7) Revise as needed and resubmit.

From: Ritzen,Brenda
To: Marisa Kane

Cc: Chadwick Fox; robert@eaglerocktx.com

Subject: RE: 118239

Date: Friday, April 25, 2025 10:09:00 AM

Attachments: <u>image001.png</u>

Re: SQR Development LLC

Scenic Heights Unit 2 Lot 521

Application for Permit for Authorization to Construct an On-Site Sewage Facility (OSSF)

Marisa:

I have reviewed the revised planning materials and found the following information is needed before I can continue processing the referenced permit submittal:

- The maintenance contract indicates that the reporting months are circled but there are none circled.
- **▼** Identify the 1 ft. separation distance from the easements.
- Identify all property dimensions on the design.
- 4. Revise as needed and resubmit.

Thank you,



Brenda Ritzen

Environmental Health Coordinator 195 David Jonas Dr. New Braunfels, TX 78132 DR:OS00007722 830-608-2090 www.cceo.org

From: Marisa Kane <bri>dgewayllc1@gmail.com>

Sent: Thursday, April 24, 2025 4:42 PM **To:** Ritzen,Brenda <rabbjr@co.comal.tx.us>



Red Stag Septic Services LLC

P: 210-364-8562

E: redstagseptic

A: 439 Russian Sage New Braunfels Tx,78130



Septic System Maintenance Contract

Customer Name: SQR Development LLC - Chadwick Fox
Customer Address: Lot 521 - 424 Valley Ridge, Canyon Lake, TX
Customer Number:

Reg Stag Septic Services LLC will operate and maintain the aerobic septic system at the address above for <u>2</u> year(s) beginning at <u>License to Operate</u> and ending at <u>2</u> years from <u>License to Operate</u>.

During the period we will provide a total of $\underline{8}$ visual inspections occurring within the months circled below:

JAN FEB MAR APR MAY JUN JUL AUG SEP OCT NOV DEC

These inspections will consist of:

- Determining if tank needs to be pumped.
- Inspecting all floats, controls, and electrical components
- Inspecting pumps and aerators
- Clean filters

The property owner will be responsible for maintaining the chorinator. Any additional work that is needed is **not** included in the service fee and will be completed and billed separately. Due to state regulations, if customer refuses to repair damaged or broken equipment necessary for the system's proper daily function; we will be forced to report customer to the appropriate county or city licensing authorities for noncompliance.

All complaints by the property owner regarding the operations of the system will be responded to within 3 business days at the site location listed above.

Service Fee **\$300.00**

n


ch
Customer Signature
03/12/2025
Date

Francisco Ruiz MP0002663

Maintenance Provider

3/12/2025

Date



Drawn by Christine Nixon
Client
SQR Development

Burrier Engineering 424 (Lot 521)Valley Ridge Canyon Lake, TX Comal County

Scale 1"=20'



ON-SITE SEWA VOID PPLICATION

195 DAVID JONAS DR

NEW BRAUNFELS, TX 78132 (830) 608-2090 WWW.CCEO.ORG

Planning Materials & Site Evaluation as Required Completed By Christine Nixon, PE
System Description AerobicDrip
Size of Septic System Required Based on Planning Materials & Soil Evaluation
Tank Size(s) (Gallons) 1245 Gal Absorption/Application Area (Sq Ft) 4926 Sq Ft
Gallons Per Day (As Per TCEQ Table III) 240 gpd (Sites generating more than 5000 gallons per day are required to obtain a permit through TCEQ.)
Is the property located over the Edwards Recharge Zone? Yes X No (If yes, the planning materials must be completed by a Registered Sanitarian (R.S.) or Professional Engineer (P.E.))
Is there an existing TCEQ approved WPAP for the property? Yes No
(If yes, the R.S. or P.E. shall certify that the OSSF design complies with all provisions of the existing WPAP.)
If there is no existing WPAP, does the proposed development activity require a TCEQ approved WPAP? Yes No (If yes, the R.S. or P.E. shall certify that the OSSF design will comply with all provisions of the proposed WPAP. A Permit to Construct will not be issued for the proposed OSSF until the proposed WPAP has been approved by the appropriate regional office.)
Is the property located over the Edwards Contributing Zone? X Yes No
Is there an existing TCEQ approval CZP for the property? Yes X No
(If yes, the P.E. or R.S. shall certify that the OSSF design complies with all provisions of the existing CZP.)
If there is no existing CZP, does the proposed development activity require a TCFQ approved CZP? Yes X No
(If yes, the R.S. or P.E. shall certify that the OSSF design will comply issued for the proposed OSSF until the CZP has been approved by the arrow of the proposed OSSF until the CZP has been approved by the arrow of the proposed OSSF until the CZP has been approved by the arrow of the proposed OSSF until the CZP has been approved by the arrow of the proposed CZP. A Permit to Construct will not be issued for the proposed OSSF until the CZP has been approved by the arrow of the proposed CZP.
Is this property within an incorporated city? Yes X No
If yes, indicate the city:
By signing this application, I certify that:
- The information provided above is true and correct to the best of my knowledge.
- I affirmatively consent to the online posting/public release of my e-mail address associated with this permit application, as applicable.
Signature of Designer 1/2/25 Date
- g. a.a. o Doigno





BURRIER NIXON ENGINEERS

Reg. No. F-24967 CHRISTINE NIXON, P.E. 9901 BRODIE LN, STE 160, PMB 195 AUSTIN, TX 78748 (512) 694-0537

April 24, 2025

Comal County Comments Response

424 (Lot 521) Valley Ridge, Canyon Lake, TX (Permit 118239)

- The actual physical address assigned to this property is 584 Valley Ridge.
 The correct address for Lot 521 is 424 Valley Ridge. The planning materials have been updated.
- 2) The physical address of the maintenance provider is needed on the maintenance contract.
 - The maintenance contract has been updated.
- 3) Please have the maintenance provider certify that the signature on the contract is his actual signature.
 - The maintenance contract has been updated
- 4) The maintenance contract must indicate that the start date of the contract is the date the "License to Operate" is issued (not LTO).
 - The maintenance contract has been updated
- 5) The maintenance contract must indicate a maintenance schedule in accordance with state regulations, it must also provide the required minimum number of service visits for the 2 year period (8 over 2 years). The maintenance contract has been updated
- 6) Identify the minimum 1 ft setback from the edge of the drip field to the utility easements.
 - A 1 foot setback is now indicated.
- 7) Revise as needed and resubmit.

From: Ritzen,Brenda
To: Marisa Kane

Cc: <u>chad.f@2x2capitalmanagement.com</u>

Subject: RE: Permit 118239

Date: Friday, March 7, 2025 12:16:00 PM

Attachments: <u>image001.png</u>

Re: SQR Development LLC

Scenic Heights Unit 2 Lot 521

Application for Permit for Authorization to Construct an On-Site Sewage Facility (OSSF)

Owner / Agent :

The following information is needed before I can continue processing the referenced permit submittal:

- Maintenance provider must certify that the signature on the contract is his true signature.
- Physical address of maintenance provider needed on the maintenance contract.
- The maintenance contract must indicate that the start date of the contract is the date the "License to Operate" is issued (not LTO).
- The maintenance contract must indicate a maintenance schedule in accordance with state regulations, it must also provide the required minimum number of service visits for the 2 year period (8 over 2 years).
- 5. Identify minimum 1 ft. separation distance from the drip tubing to the utility easement.
- 6. Revise as needed and resubmit.

Thank you,



Brenda Ritzen

Environmental Health Coordinator 195 David Jonas Dr. New Braunfels, TX 78132 DR:OS00007722 830-608-2090 www.cceo.org

From: Marisa Kane <bri>dgewayllc1@gmail.com>

Sent: Thursday, March 6, 2025 2:00 PM **To:** Ritzen, Brenda < rabbjr@co.comal.tx.us> **Cc:** chad.f@2x2capitalmanagement.com

Subject: Re: Permit 118239

This email originated from outside of the organization.

Do not click links or open attachments unless you recognize the sender and know the content

is safe.

- Comal II

Good afternoon, Brenda,

Attached is the revised planning materials requested for your review and approval.

Have a great day.

Regards,

Marisa Kane

Ph: 830-660-5498

Email: <u>Bridgewayllc1@gmail.com</u> <u>www.consultingbridgeway.com</u>

Development & Consulting Bridgeway, LLC

Business Mission: Dedication to the highest quality of customer service, delivered with a sense of warmth, friendliness, individual pride and company spirit.

Facebook





Red Stag Septic Services LLC

Septic System Maintenance Contract

210-364-8562

P.O Box 310312 New Braunfels Tx, 78131

Customer Name: SQR Development	LLC - Chadwick Fox
Customer Address: 424 Valley Ridge Ca	anyon Lake Tx, 78133 (Lot 521)
Customer Number:	
Reg Stag Septic Services LLC will operate and m beginning at LTO and ending at	naintain the aerobic septic system at the address above for <u>2</u> <u>year(s)</u> 2 years from LTO
During the period we will provide a total of 4 vis	sual inspections occurring within the months listed below:
JAN FEB MAR APR MAY JUN	I JUL AUG SEP OCT NOV DEC
These inspections will consist of:	
Determining if tank needs to be pumped	VOID
Inspecting all floats, controls, and elect	rical components
Inspecting pumps and aerators	
Clean filters	
included in the service fee and will be complete	taining the chlorinator. Any additional work that is needed is not d and billed separately. Due to state regulations, if customer refuses to for the system's proper daily function; we will be forced to report sing authorities for noncompliance.
All complaints by the property owner regarding t at the site location listed above.	he operations of the system will be responded to within 3 business days
Service Fee: \$300.00	Francisco Ruiz
Chadwick Fox (Dec 23, 2024 13:43 CST)	Francisco Ruiz MP0002663
Customer Signature	Maintenance Provider 210-364-8562
23/12/24	12/24/2023
Date	Date







March 3, 2025

SITE DESCRIPTION / EVALUATION

The site is located in Comal County, Lot 521 Valley Ridge, Canyon Lake, TX 78133. The owner is SQR Development, LLC. The site is considered unsuitable for a standard sub-surface septic system (see attached site evaluation). A drip irrigation is being designed. The sizing was determined as specified in the Texas Commission on Environmental Quality On-Site Sewage Facility-Chapter 285.33 © (2) (D). The proper performance of the OSSF cannot be guaranteed even though all provision of the standards have been generally complied with. The on-site sewage facility irrigation area placed on the flattest portion of the site. The site is located outside the regulatory 100 year flood plain. Vegetation at the proposed site consists of natural grasses and no recharge features are located within the area. The system is being designed for a three-bedroom home less than 2500 square feet (Q=240 gpd). Water saving devices will be utilized, and public water is being supplied.

SYSTEM DESCRIPTION

The on-site sewage facility will utilize a proprietary treatment plant with drip irrigation disposal. A timer will be set to dose for 563 seconds (9.4 minutes) every three hours. That will deliver the needed 30 gallons 8 times per day. Additionally, the floats will be adjusted according to the attached pump tank cross section. Wastewater from the residence will flow to a pretreatment/trash tank, then to the treatment plant. After treatment, the effluent will flow to a pump tank for discharge through a drip irrigation pressure emitter system. The surface of the existing soil must be scarified (any large rocks greater than 6" in diameter must be removed during scarification and replaced with suitable soil). Because there is limited suitable soil, the installer will be required to place 12 inches of Type III soil on the natural ground before laying the drip tubing. The drip lines will be placed on the fill and then covered with an additional 8" of soil (Ty III). A spin filter will be installed in the pressure lines that is 140 mesh or greater. A pressure regulator (set at 50 psi) with bypass will be installed in the supply). The drip emitter line must be flushed periodically. This is accomplished by openin m the drip field to the pre-treatment tank. In this process, the velocity of water moving the st be at least 2 feet per second. To prevent plugging of the emitters, it is recommended that field flushing take place on a regular basis. Field flushing should be done at least several times per year. This will clean out the emitter lines, and will help prevent emitter blockage, slime buildup, and inorganic scale buildup. Gate valves shall be placed on the drip line before it connects to the return line. Each gate valve must be opened separately for flushing through each zone. THE FLUSH RETURN SHOULD RETURN TO THE TRASH TANK. All drip line connections to manifolds should have at least 18" of PVC (see detail). When running dipper lines that take turns, loops or series of loops back to the return flush line before making a connection, make a transition to solid tubing that will resist kinking and will not emit effluent in the turns (see detail).

The installer will provide the owner with an owner's manual containing the maintenance and operation instructions.







November 19, 2024


SITE DESCRIPTION / EVALUATION

The site is located in Comal County, Lot 521 Valley Ridge, Canyon Lake, TX 78133. The owner is 2x2 Capital Development. The site is considered unsuitable for a standard sub-surface septic system (see attached site evaluation). A drip irrigation is being designed. The sizing was determined as specified in the Texas Commission on Environmental Quality On-Site Sewage Facility-Chapter 285.33 © (2) (D). The proper performance of the OSSF cannot be guaranteed even though all provision of the standards have been generally complied with. The on-site sewage facility irrigation area placed on the flattest portion of the site. The site is located outside the regulatory 100 year flood plain. Vegetation at the proposed site consists of natural grasses and no recharge features are located within the area. The system is being designed for a three-bedroom home less than 2500 square feet (Q=240 gpd). Water saving devices will be utilized, and public water is being supplied.

SYSTEM DESCRIPTION

The on-site sewage facility will utilize a proprietary treatment plant with drip irrigation disposal. A timer will be set to dose for 563 seconds (9.4 minutes) every three hours. That will deliver the needed 30 gallons 8 times per day. Additionally, the floats will be adjusted according to the attached pump tank cross section. Wastewater from the residence will flow to a pretreatment/trash tank, then to the treatment plant. After treatment, the effluent will flow to a pump tank for discharge through a drip irrigation pressure emitter system. The surface of the existing soil must be scarified (any large rocks greater than 6" in diameter must be removed during scarification and replaced with suitable soil). Because there is limited suitable soil, the installer will be required to place 12 inches of Type III soil on the natural ground before laying the drip tubing. The drip lines will be placed on the fill and then covered with an additional 8" of soil (Ty III). A spin filter will be installed in the pressure lines that is 140 mesh or greater. A pressure regulator (set at 50 psi) with bypass will be installed in the supply line he drip emitter line must be flushed periodically. This is accomplished by opening the e drip field to the pre-treatment tank. In this process, the velocity of water moving through at least 2 feet per second. To prevent plugging of the emitters, it is recommended that held flushing take place on a regular basis. Field flushing should be done at least several times per year. This will clean out the emitter lines, and will help prevent emitter blockage, slime buildup, and inorganic scale buildup. Gate valves shall be placed on the drip line before it connects to the return line. Each gate valve must be opened separately for flushing through each zone. THE FLUSH RETURN SHOULD RETURN TO THE TRASH TANK. All drip line connections to manifolds should have at least 18" of PVC (see detail). When running dipper lines that take turns, loops or series of loops back to the return flush line before making a connection, make a transition to solid tubing that will resist kinking and will not emit effluent in the turns (see detail).

The installer will provide the owner with an owner's manual containing the maintenance and operation instructions.



Drawn Christine Nixon Client SQR Development

Engineering

Comal County

Scale 1"=20'

From: Ritzen, Brenda

To: chad.f@2x2capitalmanagement.com; Marisa Kane

Subject: Permit 118239

Date: Tuesday, January 28, 2025 4:03:00 PM

Attachments: <u>image001.png</u>

Re: SQR Development LLC

Scenic Heights Unit 1 Lot 521

Application for Permit for Authorization to Construct an On-Site Sewage Facility (OSSF)

Owner / Agent :

The following information is needed before I can continue processing the referenced permit submittal:


- 1. Maintenance provider signature needed on the maintenance contract.
- 2. Physical address of maintenance provider needed on the maintenance contract.
- 3. The maintenance contract must indicate that the start date of the contract is the date the License to Operate is issued.
- 4. The maintenance contract must indicate a maintenance schedule in accordance with state regulations, it must also provide the required minimum number of service visits for the 2 year period (8 over 2 years).
- A different property owner is indicated within the planning materials.
- Clearly outline the location of the home/improvements.
- 7. Identify utility easements on the design.
- Show test hole locations on the design.
- Show driveway location on the design.
- 10. Revise as needed and resubmit.

Thank you,



Brenda Ritzen


Environmental Health Coordinator 195 David Jonas Dr. New Braunfels, TX 78132 DR:OS00007722 830-608-2090 www.cceo.org



Red Stag Septic Services LLC

Septic System Maintenance Contract

Customer Name:	
Customer Address: Lot 521 \	Valley Ridge Canyon Lake Tx, 78133 (Lot 521)
Customer Number:	
Reg Stag Septic Services LLC will ope beginning at and	erate and maintain the aerobic septic system at the address above for <u>2 year(s</u> dending at
During the period we will provide a to	otal of 4 visual inspections occurring within the months circled below:
JAN FEB MAR APR MA	AY JUN JUL AUG SEP OCT NOV DEC
These inspections will consist of:	
Determining if tank needs to	be pump d VOID
Inspecting all floats, controls	s, and electrical components
Inspecting pumps and aerato	ors
Clean filters	
included in the service fee and will be repair damaged or broken equipment	le for maintaining the chlorinator. Any additional work that is needed is not e completed and billed separately. Due to state regulations, if customer refuses to t necessary for the system's proper daily function; we will be forced to report or city licensing authorities for noncompliance.
at the site location listed above. Service Fee: \$300.00	regarding the operations of the system will be responded to within 3 business day
Chadwick Fox (Dec 23, 2024 13:43 CST)	Francisco Ruiz MP0002663
Customer Signature	Maintenance Provider
23/12/24	
Date	Date



Date 11/19/2024

Drawn by Christine Nixon

Client
2x2 Capital Development

Burrier Engineering Lot 521 Valley Ridge Canyon Lake, TX Comal County

Scale 1"=20'

MODIFICATION OF DEED OF TRUST

RECORDATION REQUESTED BY:

First Financial Bank, N.A. Eastland Main Office 201 E Main St P. O. Box 788 Eastland, TX 76448-0788

WHEN RECORDED MAIL TO:

First Financial Bank, N.A. Credit Department P. O. Box 2559 Abilene, TX 79604-2559

SEND TAX NOTICES TO:

SQR Development, LLC 129 VALLEY RIDGE DR DRIPPING SPRINGS, TX 78620-3670

SPACE ABOVE THIS LINE IS FOR RECORDER'S USE ONLY



`#################%0735%12302023%##############

THIS MODIFICATION OF DEED OF TRUST dated December 30, 2023, is made and executed between SQR Development, LLC, a Texas limited liability company ("Grantor") and First Financial Bank, N.A., whose address is Eastland Main Office, 201 E Main St, P. O. Box 788, Eastland, TX 76448-0788 ("Lender").

DEED OF TRUST. Lender and Grantor have entered into a Deed of Trust dated December 30, 2022 (the "Deed of Trust") which has been recorded in COMAL County, State of Texas, as follows:

Deed of Trust recorded on January 3, 2023 as Instrument Number 202306000175 of the Official Public Records of Comal County, Texas and all subsequently executed modifications and/or extensions of such Deed of Trust.

REAL PROPERTY DESCRIPTION. The Deed of Trust covers the following described real property located in COMAL County, State of Texas:

Lots 494, 495, 498, 499, 501, 502, 503, 504, 514, 515, 516, 520, 521 and 522 of SCENIC HEIGHTS UNIT NO.2, a Subdivision in Comal County, Texas, according to the map or plat of record in Volume 2, Page 36, of the MAP AND PLAT Records of Comal County, Texas.

The Real Property or its address is commonly known as LOTS 494, 495, 498, 499, 501, 502, 503, 504, 514, 515, 516, 520, 521, AND 522 OF SCENIC HEIGHTS UNIT NO. 2, COMAL COUNTY, TX.

MODIFICATION. Lender and Grantor hereby modify the Deed of Trust as follows:

Extend maturity date from December 30, 2023 to February 28, 2026.

CONTINUING VALIDITY. Except as expressly modified above, the terms of the original Deed of Trust shall remain unchanged and in full force and effect. Consent by Lender to this Modification does not waive Lender's right to require strict performance of the Deed of Trust as changed above nor obligate Lender to make any future modifications. Nothing in this Modification shall constitute a satisfaction of the promissory note or other credit agreement secured by the Deed of Trust (the "Note"). It is the intention of Lender to retain as liable all parties to the Deed of Trust and all parties, makers and endorsers to the Note, including accommodation parties, unless a party is expressly released by Lender in writing. Any maker or endorser, including accommodation makers, shall not be released by virtue of this Modification. If any person who signed the original Deed of Trust does not sign this Modification, then all persons signing below acknowledge that this Modification is given conditionally, based on the representation to Lender that the non-signing person consents to the changes and provisions of this Modification or otherwise will not be released by it. This waiver applies not only to any initial extension or modification, but also to all such subsequent actions.

GRANTOR ACKNOWLEDGES HAVING READ ALL THE PROVISIONS OF THIS MODIFICATION OF DEED OF TRUST AND GRANTOR AGREES TO ITS TERMS. THIS MODIFICATION OF DEED OF TRUST IS DATED DECEMBER 30, 2023.

GRANTOR:	
SOR DEVELOPMENT, LCC	
CSA FAMILY) LIMITED PARTNERSHIP, Manager of Soft Development, LLC By: Carole Crumley, President of ESA Family Limited Partnership	
LENDER:	
x Muly Stutuch Ashley Diethrich, rice President	
LIMITED LIABILITY COMPANY AC	KNOWLEDGMENT
STATE OF _ TOURS	ASHLEY DIETHRICH NOTARY PUBLIC STATE OF TEXAS ID # 12967865-0 My Comm. Expires 12-09-2025
This instrument was acknowledged before me on February 21 Development, LLC and Carole Crumley, President of CSA Family Limited Partnership company, on behalf of said limited liability company.	by Chadwick Fox, Manager of SQR, Manager of SQR, Manager of SQR Development, LLC, a Texas limited liability
	Notary Public, Stafe of Texas

MODIFICATION OF DEED OF TRUST

	(Continued)	Page 3
LE C	NDER ACKNOWLEDGMENT	
STATE OF PEXAS	,	
STATE OF TEXAS COUNTY OF EASHAND) ss)	
This instrument was acknowledged before me this Vice President of First Financial Bank, N.A	27th day of February	, 20_24 by Ashley Diethrich as
MEAGAN MATHIS NOTARY PUBLIC STATE OF TEXAS 1D # 13347512-1 My Comm. Expires 12-06-2025	Maya Notary Public	Matuis c, State of Texas
LaserPro, Ver. 23.2.20.003 Copr. Finastra USA Cor	poration 1997, 2024. All Rights Reserved	TX C:\CFI\LPL\G202.FC TR-24001539
	PR-14	

Filed and Recorded **Official Public Records Bobbie Koepp, County Clerk Comal County, Texas** 03/11/2024 08:02:52 AM CHRISTY 3 Pages(s) 202406007203







OSSF DEVELOPMENT APPLICATION CHECKLIST

Staff will complete shaded items

118239

		Date Received	Initiais	Permit Number				
Plac	uctions: e a check mark next to all items that apply. For items tha cklist <u>must</u> accompany the completed application.	it do not apply, plac	ce "N/A". This (OSSF Development Application				
oss	F Permit							
\checkmark	Completed Application for Permit for Authorization to Co	onstruct an On-Site	e Sewage Facil	ity and License to Operate				
\checkmark	Site/Soil Evaluation Completed by a Certified Site Evaluator or a Professional Engineer							
\	Planning Materials of the OSSF as Required by the TCEQ Rules for OSSF Chapter 285. Planning Materials shall consist of a scaled design and all system specifications.							
<u> </u>	Required Permit Fee - See Attached Fee Schedule							
\checkmark	Copy of Recorded Deed							
\checkmark	Surface Application/Aerobic Treatment System							
	Recorded Certification of OSSF Requiring Mainte	nance/Affidavit to t	he Public					
	Signed Maintenance Contract with Effective Date	as Issuance of Lic	ense to Opera	te				
	I affirm that I have provided all information required for my OSSF Development Application and that this application constitutes a completed OSSF Development Application.							
	Marisa Kans	12/23/20)24					
	Signature of Applicant		ļ	Date				
	COMPLETE APPLICATION Check No Receipt No	—— (M		ETE APPLICATION cled, Application Refeused)				
				Revised: September 2019				