Comal County Environmental Health OSSF Inspection Sheet

staller Name:	OSSF Installer #:	
1st Inspection Date:	2nd Inspection Date:	3rd Inspection Date:
Inspector Name:	Inspector Name:	Inspector Name:

Perm	it#:		Address:				
No.	Description	Answer	Citations	Notes	1st Insp.	2nd Insp.	3rd Insp.
1	SITE AND SOIL CONDITIONS & SETBACK DISTANCES Site and Soil Conditions Consistent with Submitted Planning Materials		285.31(a) 285.30(b)(1)(A)(iv) 285.30(b)(1)(A)(v) 285.30(b)(1)(A)(iii) 285.30(b)(1)(A)(ii) 285.30(b)(1)(A)(i)				
2	SITE AND SOIL CONDITIONS & SETBACK DISTANCES Setback Distances Meet Minimum Standards		285.91(10) 285.30(b)(4) 285.31(d)				
3	SEWER PIPE Proper Type Pipe from Structure to Disposal System (Cast Iron, Ductile Iron, Sch. 40, SDR 26)		285.32(a)(1)				
4	SEWER PIPE Slope from the Sewer to the Tank at least 1/8 Inch Per Foot		285.32(a)(3)				
	SEWER PIPE Two Way Sanitary - Type Cleanout Properly Installed (Add. C/O Every 100' &/or 90 degree bends)		285.32(a)(5)				
5	PRETREATMENT Installed (if required) TCEQ Approved List PRETREATMENT Septic Tank(s) Meet Minimum Requirements		285.32(b)(1)(G) 285.32(b)(1)(E)(iii) 285.32(b)(1)(E)(iv) 285.32(b)(1)(F) 285.32(b)(1)(C)(i) 285.32(b)(1)(C)(ii) 285.32(b)(1)(D) 285.32(b)(1)(E) 285.32(b)(1)(E) 285.32(b)(1)(E) 285.32(b)(1)(E)(ii)(II) 285.32(b)(1)(E)(ii)(II) 285.32(b)(1)(E)(ii)(II) 285.32(b)(1)(E)(ii)(II)				
7	PRETREATMENT Grease Interceptors if required for commercial		285.34(d)				

Inspector Notes:

Comal County Environmental Health OSSF Inspection Sheet


	B	A	C't at a		4	2-11	211.
No.	Description	Answer	Citations	Notes	1st Insp.	2nd Insp.	3rd Insp.
8	SEPTIC TANK Tank(s) Clearly Marked SEPTIC TANK If SingleTank, 2Compartments Provided withBaffle SEPTIC TANK Inlet Flowline Greater than3" and " T " Provided on Inlet and OutletSEPTIC TANK Septic Tank(s) MeetMinimum Requirements		285.32(b)(1) (E)285.91(2)285.32(b)(1) (F)285.32(b)(1)(E) (iii)285.32(b)(1)(E)(ii) (I)285.32(b)(1)(E) (i)285.32(b)(1)(E) (i)285.32(b)(1)(C) (i)285.32(b)(1)(C) (ii)285.32(b)(1)(C) (ii)285.32(b)(1)(C) (i)285.32(b)(1) (B)285.32(b)(1) (A)285.32(b)(1)(E)(iv)				
9	ALL TANKS Installed on 4" Sand Cushion/ Proper Backfill Used		285.32(b)(1)(F) 285.32(b)(1)(G) 285.34(b)				
	SEPTIC TANK Inspection / Clean Out Port & Risers Provided on Tanks Buried Greater than 12" Sealed and Capped		285.38(d)				
11	SEPTIC TANK Secondary restraint system providedSEPTIC TANK Riser permanently fastened to lid or cast into tank SEPTIC TANK Riser cap protected against unauthorized intrusions		285.38(d) 285.38(e)				
	SEPTIC TANK Tank Volume Installed						
	PUMP TANK Volume Installed						
13	AEROBIC TREATMENT UNIT Size Installed						
14	AEROBIC TREATMENT UNIT Manufacturer AEROBIC TREATMENT UNIT Model Number						
16	DISPOSAL SYSTEM Absorptive		285.33(a)(4) 285.33(a)(1) 285.33(a)(2) 285.33(a)(3)				
17	DISPOSAL SYSTEM Leaching Chamber		285.33(a)(1) 285.33(a)(3) 285.33(a)(4) 285.33(a)(2)				
	DISPOSAL SYSTEM Drip Irrigation		285.33(c)(3)(A)-(F)				
18							

Comal County Environmental Health OSSF Inspection Sheet

	I I			- 		I	I
No.	Description	Answer	Citations	Notes	1st Insp.	2nd Insp.	3rd Insp.
32	EFFLUENT DISPOSAL SYSTEM Utilized Only by Single Family Dwelling EFFLUENT DISPOSAL SYSTEM Topographic Slopes < 2.0% EFFLUENT DISPOSAL SYSTEM Adequate Length of Drain Field (1000 Linear ft. for 2 bedrooms or Less & an additional 400 ft. for each additional bedroom) EFFLUENT DISPOSAL SYSTEM Lateral Depth of 18 inches to 3 ft. & Vertical Separation of 1ft on bottom and 2 ft. to restrictive horizon and ground water respectfully EFFLUENT DISPOSAL SYSTEM Lateral Drain Pipe (1.25 - 1.5" dia.) & Pipe Holes (3/16 - 1/4" dia. Hole Size) 5 ft. Apart		285.33(b)(3)(A) 285.33(b)(3)(A) 285.33(b)(3) (B)285.91(13) 285.33(b)(3)(D) 285.33(b)(3)(F)				
	AEROBIC TREATMENT UNIT IS Aerobic Unit Installed According to Approved Guidelines.		285.32(c)(1)				
	AEROBIC TREATMENT UNIT Inspection/Clean Out Port & Risers Provided AEROBIC TREATMENT UNIT Secondary restraint system provided AEROBIC TREATMENT UNIT Riser permanently fastened to lid or cast into tank AEROBIC TREATMENT UNIT Riser cap protected against unauthorized intrusions						
	AEROBIC TREATMENT UNIT Chlorinator Properly Installed with Chlorine Tablets in Place.						
	PUMP TANK Is the Pump Tank an approved concrete tank or other acceptable materials & construction PUMP TANK Sampling Port Provided in the Treated Effluent Line PUMP TANK Check Valve and/or Anti- Siphon Device Present When Required PUMP TANK Audible and Visual High Water Alarm Installed on Separate Circuit From Pump PUMP TANK Inspection/Clean Out						
37	Port & Risers Provided PUMP TANK Secondary restraint system provided PUMP TANK Riser permanently fastened to lid or cast into tank PUMP TANK Riser cap protected against unauthorized intrusions						
38	PUMP TANK Secondary restraint system provided PUMP TANK Electrical						
	Connections in Approved Junction Boxes / Wiring Buried						

Comal County Environmental Health OSSF Inspection Sheet

				-			
No.	Description	Answer	Citations	Notes	1st Insp.	2nd Insp.	3rd Insp.
	APPLICATION AREA Distribution Pipe, Fitting, Sprinkler Heads & Valve Covers Color Coded Purple?		285.33(d)(2)(G)(iii)(II) 285.33(d)(2)(G)(iii)(III) 285.33(d)(2)(G)(v) 285.33(d)(2)(G)(iii) 285.33(d)(2)(G)(iv) 285.33(d)(2)(G)(i) 285.33(d)(2)(G)(iii) 285.33(d)(2)(G)(iii)(I)				
	APPLICATION AREA Low Angle Nozzles Used / Pressure is as required APPLICATION AREA Acceptable Area, nothing within 10 ft of sprinkler heads? APPLICATION AREA The Landscape Plan is as Designed		285.33(d)(2)(G) (i)285.33(d)(2) (A)285.33(d)(2)(F)				
	APPLICATION AREA Area Installed						
	PUMP TANK Meets Minimum Reserve Capacity Requirements						
	PUMP TANK Material Type & Manufacturer						
	PUMP TANK Type/Size of Pump Installed						



Permit of Authorization to Construct an On-Site Sewage Facility Permit Valid For One Year From Date Issued

Permit Number: 119024

Issued This Date: 10/15/2025

This permit is hereby given to: LJ Quality Homes, LLC

To start construction of a private, on-site sewage facility located at:

1475 BONNYVIEW DR CANYON LAKE, TX 78133

Subdivision: Canyon Lake Forest

Unit: 2

Lot: 889

Block: 0

Acreage: 0.2100

APPROVED MINIMUM SIZES AS PER ATTACHED DESIGN

Type of System: Aerobic

Drip Irrigation

This permit gives permission for the construction of the above referenced on-site facility to commence. Installation must be completed by an installer holding a valid registration card from the Texas Commission on Environmental Quality (TCEQ). Installation and inspection must comply with current TCEQ and Comal County requirements.

Call (830) 608-2090 to schedule inspections.



Signature of Owner

ON-SITE SEWAGE FACILITY APPLICATION

195 DAVID JONAS DR NEW BRAUNFELS, TX 78132 (830) 608-2090 WWW.CCEO.ORG

> Page 1 of 2 Revised January 2021

Date 04/02/20	24	Permit Number <u>117376</u>				
1. APPLICANT	/ AGENT INFORMATION			11	9024	
Owner Name	LJ Quality Homes, LLC	Agent Name	John J. Ha		7024	
Mailing Addres	s 5862 Hopper Court	Agent Address				
City, State, Zip	New Braunfels, Tx. 78132			io, Tx. 78247		
Phone # 210-367-9249		Phone #	210-705-4			
Email	jmartin6107@gmail.com		jhaag@sat			
2. LOCATION			j			
Subdivision Na	me Canyon Lake Forest	U	nit 2	Lot 889	Block	
	Abstract Number			Acreage	0.207	
Address 1475					9.00	
3. TYPE OF DE		onycanyon cano				
X Single Fa	mily Residential					
	construction (House, Mobile, RV, Etc.) House					
	of Bedrooms 3					
Indicate S	Eq Ft of Living Area 1320					
	e Family Residential					
(Planning n	naterials must show adequate land area for doubling	the required land neede	d for treatme	nt units and dispo	sal area)	
Type of F	acility					
Offices, F	actories, Churches, Schools, Parks, Etc Indica	ate Number Of Occupa	ants			
Restaurar	nts, Lounges, Theaters - Indicate Number of Sea	ats				
Hotel, Mo	tel, Hospital, Nursing Home - Indicate Number o	f Beds				
Travel Tra	iler/RV Parks - Indicate Number of Spaces					
Miscellane	eous					
		Structure Only)		AOE\ 8		
	of the proposed OSSF located in the United Stat					
	No (If yes, owner must provide approval from USACE for	proposed OSSF improvem	ents within the	e USACE flowage e	easement)	
Source of Wate						
SIGNATURE O	cation, I certify that:					
he completed app	lication and all additional information submitted does am the property owner or I possess the appropriate					
thorization is here e/soil evaluation a	by given to the permitting authority and designated and inspection of private sewage facilities ermit of authorization to construct will not be issued					
the Comal County	Flood Damage Prevention Order. t to the online posting/public release of my e-mail ac					
//		0/1	/ /			



ON-SITE SEWAGE FACILITY APPLICATION

195 DAVID JONAS DR NEW BRAUNFELS, TX 78132 (830) 608-2090 WWW.CCEO.ORG

Planning Materials & Site Evaluation as Required Completed By <u>John J. Haag, P.E.</u>								
System Description Proprietary aerobic treatment w	ith drip disposal							
Size of Septic System Required Based on Planning	ize of Septic System Required Based on Planning Materials & Soil Evaluation							
Tank Size(s) (Gallons) NuWater B-550 (600 gpd)	Absorption/Application Area (Sq Ft) 1200 min							
Gallons Per Day (As Per TCEQ Table III) 240 (Sites generating more than 5000 gallons per day are requ	uired to obtain a permit through TCEQ.)							
Is the property located over the Edwards Recharge 2 (If yes, the planning materials must be completed by a Re								
Is there an existing TCEQ approved WPAP for the p	roperty? Yes No							
(If yes, the R.S. or P.E. shall certify that the OSSF design	complies with all provisions of the existing WPAP.)							
If there is no existing WPAP, does the proposed dev (If yes, the R.S. or P.E. shall certify that the OSSF design be issued for the proposed OSSF until the proposed WPA	will comply with all provisions of the proposed WPAP. A Permit to Construct will not							
Is the property located over the Edwards Contributin	g Zone? X Yes No							
Is there an existing TCEQ approval CZP for the prop	perty? Yes No							
(If yes, the P.E. or R.S. shall certify that the OSSF design $$	complies with all provisions of the existing CZP.)							
If there is no existing CZP, does the proposed devel- (If yes, the R.S. or P.E. shall certify that the OSSF design issued for the proposed OSSF until the CZP has been app	will comply with all provisions of the proposed CZP. A Permit to Construct will not be							
Is this property within an incorporated city?	s 🔀 No							
If yes, indicate the city:								
By signing this application, I certify that:								
- The information provided above is true and correct to	the best of my knowledge.							
- I affirmatively consent to the online posting/public rele	ase of my e-mail address associated with this permit application, as applicable.							
fle I bleas the	03/28/2024							
Signature of Designer	Date							





202406010901 04/11/2024 02:54:36 PM 1/1

STATE OF TEXAS

CERTIFICATION OF OSSF REQUIRING MAINTENANCE

According to Texas Commission on Environmental Quality (TCEQ) Rules for On- Site Sewage Facilities, this document is filed in the Deed Records of Comal County, Texas.

T

The Texas Health and Safety Code, Chapter 366 authorizes the TCEQ to regulate on-site sewage facilities (OSSFs). Additionally, the Texas Water Code (TWC), § 5.012 and § 5.013, gives the TCEQ primary responsibility for implementing the laws of the State of Texas relating to water and adopting rules necessary to carry out its powers and duties under the TWC. The TCEQ, under the authority of the TWC and the Texas Health and Safety Code, requires owners to provide notice to the public that certain types of OSSFs are located on specific pieces of property. To achieve this notice, the TCEQ requires a recorded affidavit. Additionally, the owner must provide proof of the recording to the OSSF permitting authority. This recorded affidavit is not a representation or warranty by the TCEQ of the suitability of this OSSF, nor does it constitute any guarantee by the TCEQ that the appropriate OSSF was installed.

II

An OSSF requiring a maintenance contract, according to 30 Texas Administrative Code §285.91(12) will be installed on the property described as (insert legal description):

Legal Description: Lot 889, Canyon Lake Forest, Unit 2

This property is owned by: LJ Quality Homes, LLC

This OSSF must be covered by a continuous maintenance contract for the first two years. After the initial two-year service policy, the owner of an aerobic system for a single-family residence shall either obtain a maintenance contract within 30 days or maintain the system personally.

The owner will, upon any sale or transfer of the above-described property, request a transfer of the permit for the OSSF to the buyer or new owner. A copy of the planning materials for the OSSF can be obtained from Comal County.

WITNESS BY HAND(S) ON THIS 11 DAY OF Apcil

17029


Jacob Martin (Owner, LJ Quality Homes, LLC)

SWORN TO AND SUBSCRIBED BEFORE ME ON THIS 11 DAY OF April ,2024

Notary Public, State of Texas

Filed and Recorded Official Public Records Bobbie Koepp, County Clerk Comal County, Texas 04/11/2024 02:54:36 PM LAURA 1 Page(s) 202406010901

bie Koepo



Received

Brandon Mark Olvera 10/15/2025 2:13:03 PM

Baker Service and Maintenance OSSF Systems PS LLC 15375 Cranes Mill Rd., Canyon Lake, TX 78133 830-899-2971

In consideration of payment for this service contract of the service contract
In consideration of payment for this service contract, we will abide by and agree to its terms and conditions: Substitute 15 Quality Homes, CLC Substitute 15 Quality Homes, CLC Address: 1886
Name: 45 Quality Homes, LLC Address: 1436
Subdivision/ County: Convoir Luke Forest, Coma
Permit # 119024 Model # Acubic Orio Serial #
Phone: 210-367-9249
() Initial Two Year Service Agreement
& Two Year Limited Warranty () One Year Service Agreement
Desiriara:
Legal Description: NAME TRANSFER ANALYSIS
The Effective date of this initial maintenance contract shall be the date the License to Operate is issued. For \$ 200 - This contract will be in effect FROM 2 years from 27 and will provide the following:
1. An inspection/service call every (4) four months which will be and will provide the following:
The state of the control of the state of the
mechanical & electrical components as necessary to insure proper function of the system. 2. An effluent quality inspection consisting of a visual check for color, turbidity, scum, overflow an odor.
3. THE PROPERTY OWNER IS RESPONSIBLE FOR PURCHASING AND KEEPING CHLORINE IN THE CHLORINATOR (IF
APPLICALBE). IF THE CHLORINE TEST REVELS "NO CHLORINE" IN THE SYSTEM, THE PROPERTY OWNER MAY INCURE
AN ADDITIONAL COST.
4. If any improper operation is observed (which cannot be corrected at that time) the property owner will be notified
immediately of the conditions and the estimated cost.
5. The response time to a complaint by the property owner regarding operation of the system, shall be within 48 hours,
from the time of notification. One service call a year, if needed, will be provided with no cost to property owner.
6. ANY PARTS, WARRANTY OR NON-WARRANTY, FREIGHT CHARGES, LABOR OR SERVICE CALLS DUE NOT PAID FOR
REMAIN THE PROPERTY OF BAKER SEPTIC SERVICE, LLC AND COULD RESULT IN REPOSSESSION OF PARTS BY BAKER
SEPTIC SERVICE, LLC.
7. THE SIGING OF THIS SERVICE AGREEMENT QUTHORIZES BAKER SEPTIC SERVICE, LLC TO ENTER THE PROPETY TO
EXECUTE ALL TERMS OF THIS CONTRACT.
BAKER SEPTIC SERVICE, LLC, WILL WARRANTY INSTALLAION of the septic system according to state and county regulations and the
designs approved by the county. HOMEOWNER WILL BE RESPONSIBE FOR SERVICE CALL, LABOR, AND SHIPPING COSTS ON ANY
"WARRANTED PARTS" EXCHANGED DURING WARRANTY. All other component will be according to manufacturer's warranties.
IMPORTANT: As Baker Septic Service, LLC cannot control what or how much effluent goes into this septic system, we cannot
warranty how the system will function. Refer to manufacturers or installers instructions for suggestions on septic operation. This
service agreement does not cover the cost of service call, labor or materials that are required or parts out of warranty, the failure
to maintain electrical power to the system, sprinklers that are broken, leaking, stopped-up or otherwise mal-functioning; or sewage
flows exceeding the hydraulic/organic design capabilities and the input of non-biodegradable materials (solvent, grease, oil, paints, etc.), or any usage contrary to the requirements as advised by outhorized sometime to the requirements as advised by outhorized sometimes.
etc.), or any usage contrary to the requirements as advised by authorized service representative. Laboratory test work is available at an additional coast. Chlorine, filters, or parts that are out of warranty are available at a reasonable cost.
This contract does not include the pumping of a tank or of any compartment of a tank, or settlement of soil on or around any part
of the system regardless of reason:
Violations of the warranty also include: Disconnecting the alarm, restricting ventilation to the aerator, over loading the system
above its rated capacity; or flooding by external means. Rodent, insect or Fire Ant damage or any other form of unusual abuse is a
violation.
A renewal service contract should be activated (30) thirty days before expiration of existing contract. We will contact property
owner prior to expiration of existing contract.
Serviced by: Baker Septic Service, LLC
Maintenance Provider MPGSS 2099
(x) Print Name (X) 7 9 cob Mat. 2 Date: 09-15-25
Property Owner Signature
(x) July Date: 10-18-05 Authorized Service Representative

ON-SITE SEWAGE FACILITY (OSSF) SITE EVALUATION FORM

1. OWNER INFORMATION Property Owner's Full Legal Name: LJ Quality Homes, LLC

2. PROPERTY INFORMATION							
City: Canyo	City: Canyon Lake Zip Code: 78133						
Legal Descr	iption:						
Lot: 889	Block:	Subdivision: Canyon Lake Fo	rest	Unit: 2	Phase:		
If not located	If not located in subdivision: Survey:						
Abstract:				Recorded (Vol/Po	3):		

3. SITE EVALUATION INFORMATION:	
Name of Site Evaluator: John J. Haag	PE #: 90158
Date Performed: 04/03/2024	Proposed Excavation Depth: Surface

4. REQUIREMENTS:

- At least two soil evaluations must be performed on the site at opposite ends of the proposed disposal area. Locations of soil evaluations must be shown on the application site drawing or designer's site drawing.
- For subsurface disposal, soil evaluations must be performed to a depth of at least 2 feet below the proposed excavation depth. For surface disposal, the surface horizon must be evaluated.

Soil Profile Ho	Soil Profile Hole Number: 1							
			Drainage					
Depth	Textural	Gravel	(Mottles/Water	Restrictive	Observations			
(ft.)	Class	Analysis	Table)	Horizon				
0	III	<30%	No	Yes	Type III to approx. 3" then auger			
					limestone			
1								
2								
3								
4								
5								

ON-SITE SEWAGE FACILITY (OSSF) SITE EVALUATION FORM

Soil Profile	Soil Profile Hole Number: 2							
			Drainage					
Depth	Textural	Gravel	(Mottles/Water	Restrictive	Observations			
(ft.)	Class	Analysis	Table)	Horizon				
0	III	<30%	No	Yes	Type III to 18" then limestone			
1								
2								
3								
4								
5								

5. FEATURES OF SITE AREA:

Presence of 100 year flood zone:	\square Yes	⊠ No
Presence of adjacent ponds, streams or water impoundments	\square Yes	⊠ No
Existing or proposed water well in nearby area	\square Yes	⊠ No
Organized sewage available to lot or tract	\square Yes	⊠ No
Recharge features within 150 feet	\square Yes	⊠ No

6. I certify that the above statements are true and correct and are based on my own field observations.



04/03/2024

Haag Engineering Consultants, LLC

Firm: F-5789

5/9/24, 8:27 AM Task Comments













AEROBIC TREATMENT DRIP TUBING SYSTEM FOR: LOT 889, BONNEYVIEW DR. CANYON LAKE FOREST. UNIT 2

SITE DESCRIPTION:

Located in Canyon Lake Forest, Lot 889 the proposed system will serve at 3-bedroom, 1320 s.f. residence situated with soils per the Site Evaluation report. An aerobic treatment plant utilizing drip irrigation was chosen as the most appropriate system to serve the conditions on this lot.

PROPOSED SYSTEM:

A 3 or 4 inch SCH-40 pipe discharges from the residence into a AquaKlear AKA600CA (600 gpd) aerobic treatment plant containing a 500 gallon pretreatment tank and a 800 gallon pump chamber. The pump chamber contains a 0.5 HP Franklin C1-Series-20XC1-05P4-2W115 submersible well pump. The well pump is activated by a time controller allowing the distribution ten times per day with a 6-minute run time with the float setting at min. 240 gallons. A high level audible and visual alarm will activate should the pump fail. Distribution is through a self-flushing 100 micron Arkal Disk filter then through a 1" SCH-40 manifold to a minimum 1200 sf drip tubing field with Netifim Bioline drip lines approximately two feet apart with 0.61 gph emitters set every two feet as per the attached schematic. A pressure regulator Model PMR35MF 35psi installed in the pump tank on the manifold to the field will maintain pressure at 35 psi. A 1" SCH-40 return line is installed to continuously flush the system by cycling a 1" ball valve. Solids caught in the disk filter are flushed each cycle back to the pump tank. Agricultural Products, Inc. (Model #VBK-1) 1" PVC vacuum breakers installed on the highest point on each manifold will prevent siphoning of effluent from higher to lower parts in the field. The field area shall be scarified and then built up so that a minimum of 12" of Type II or III soil is above any bedrock or type IV soils then the drip tubing shall be laid and capped with a minimum of 6" of Type II or Type III soil (NOT SAND). The field area shall be sodded with grass prior to system startup. The tank must have risers 2-inches minimum above finished grade on each opening with watertight caps that must be 65# or have a padlock or can only be removed with tools - all risers shall meet the minimum requirements of 30 TAC 285 effective July 6, 2023. A secondary plug, cap or suitable restraint must be provided below riser cap to prevent tank entry should the cap be damaged or removed.

DESIGN SPECIFICATIONS:

Daily flow = Q=240 gpd Pretreatment tank size: 500 gal

Plant size: AquaKlear AKA600CA; 600 gpd (TCEQ approved)

Pump tank size: 800 gal

Min. Reserve capacity after high level: 80 gal (1/3 day req'd)

Application rate: Ra=0.2 gal/sf

Total absorption area: Q/Ra = min. 1200 sf (1,472 sf actual)

Total linear feet of drip tubing: 736' Netifim Bioline drip tubing 0.61 gph Pump requirement: 0.5 HP Franklin C1-Series-20XC1-05P4-2W115



Total System Information Application Area Required (square feet) Total Amount of Bioline® Required (feet) Total Number of Emitters in the Dripfield Zone Information Number of Zones Amount of Bioline® Per Zone (feet) Amount of Bioline® Per Zone (feet) Number of Emitters Per Zone Amount of Bioline® Per Zone (feet) Number of Laterals Per Zone Maximum Number of Laterals Per Zone Maximum Number of Laterals Per Zone Maximum Number of Laterals Per Zone Number of Laterals Per Zone Number of Laterals That Will be Used Maximum Length of Bioline® Laterals Based on Intel Pressure Flow Rate Per Zone (GPM) Holding Capacity of Dripperline Per Zone (Gellons) Additional Flow Requirement to Accommodate Flushing Velocity Holding Capacity (Gallons) of Supply Line & Supply & Flush Manifolds Holding Capacity (Gallons) of Supply Line & Supply & Flush Manifolds Holding Capacity (Gallons) of Supply Line & Supply & Flush Manifolds Holding Capacity (Gallons) of Supply Line & Supply & Flush Manifolds Holding Capacity (Gallons) of Supply Line & Supply Manifolds (Spi) Friction Loss in Supply Line & Supply Manifolds (Spi) Friction Loss in Supply Line & Supply Manifolds (Spi) Friction Loss in Supply Line & Supply Manifolds (Spi) Friction Loss in Supply Line & Supply Manifolds (Spi) Friction Loss in Supply Line & Supply Manifolds (Spi) Friction Loss in Supply Line & Supply Manifolds (Spi) Friction Loss in Supply Line & Supply Manifolds (Spi) Friction Loss in Supply Line & Supply Manifolds (Spi) Friction Loss in Supply Line & Supply Manifolds (Spi) Friction Loss in Supply Line & Supply Manifolds (Spi) Friction Loss in Supply Line & Supply Manifolds (Spi) Friction Loss in Supply Line & Supply Manifolds (Spi) Friction Loss in Supply Line & Supply Manifolds (Spi) Friction Loss in Supply Line & Supply Manifolds (Spi) Friction Loss in Supply Line & Supply Manifolds (Spi) Friction Loss in Supply Line & Supply Manifolds (Spi) Friction Loss in Supply Line & Supply Manifolds (Spi) Friction Loss in Supply Line & Supply Manifolds (Spi) Friction Loss in	Calculation Outputs	
Application Area Required (square feet) Total Amount of Bioline® Required (feet) Total Number of Emitters in the Dripfield Zone Information Number of Zones Amount of Bioline® Per Zone (feet) Number of Emitters Per Zone Maximum Number of Laterals Per Zone Maximum Number of Laterals Per Zone Maximum Number of Laterals Per Zone Maximum Length of Bioline® Laterals Based on Intel Pressure Flow Rate Per Zone (Gellons) Additional Flow Requirement to Accommodate Flushing Velocity Holding Capacity of Dripperline Per Zone (Gallons) Additional Flow Requirement to Accommodate Flushing Velocity Holding Capacity (Gallons) of Supply Line & Supply & Flush Manifolds Holding Capacity (Gallons) of Supply Line Manifolds and Dripperline Head Loss Data - Dosing & Flushing Cycle Friction Loss in Supply Line & Supply Manifolds (psi) Friction Loss in Supply Line & Supply Manifolds (psi) Additional Pressure Required for Return Manifold and Piping to Tank (psi) Additional Pressure Required for Return Manifold and Piping to Tank (psi) Total Runtime Per Zone Per Day (Minutes) Total Runtime Per Zone Per Day (Minut	Total System Information	
Total Amount of Bioline® Required (feet) Total Number of Emitters in the Dripfield Zone Information Number of Zones Amount of Bioline® Per Zone (feet) Number of Emitters Per Zone Number of Emitters Per Zone Minimum Number of Laterals Per Zone Maximum Number of Laterals Per Zone Maximum Length of Bioline® Laterals Based on Intel Pressure Flow Rate Per Zone (GPM) The Indiang Capacity of Dripperline Per Zone (GPM) Additional Flow Requirement to Accommodate Flushing Velocity Holding Capacity of Piping Holding Capacity (Gallons) of Supply Line & Supply & Flush Manifolds Holding Capacity (Gallons) of Supply Line & Supply & Flush Manifolds Holding Capacity (Gallons) of Supply Line & Manifolds Holding Capacity (Gallons) of Supply Line & Manifolds Friction Loss in Supply Line & Supply Manifolds (psi) Friction Loss in Supply Line & Supply Manifolds (ps		1.472
Amount of Bioline® Per Zone (feet) Number of Zones Amount of Bioline® Per Zone (feet) Number of Emitters Per Zone Amount of Bioline® Per Zone (feet) Number of Emitters Per Zone Amount of Bioline® Der Zone (feet) Number of Emitters Per Zone Amount of Bioline® Laterals Per Zone Maximum Number of Laterals Per Zone Maximum Number of Laterals Per Zone Maximum Length of Bioline® Laterals Based on Inlet Pressure Flow Rate Per Zone (GPM) Number of Laterals Per Zone (GPM) Additional Flow Requirement to Accommodate Flushing Velocity Holding Capacity of Dripperline Per Zone (Gallons) Additional Flow Requirement to Accommodate Flushing Velocity Holding Capacity (Gallons) of Supply Line & Supply & Flush Manifolds Holding Capacity (Gallons) of Supply Line, Manifolds and Dripperline Head Loss Data - Dosing & Flushing Cycle Friction Loss per 100' (psi) in Supply Line & Manifolds Friction Loss in Supply Line & Supply Manifolds (psi) Friction Loss in Supply Line & Su	l i i i i i i i i i i i i i i i i i i i	
Amount of Bioline® Per Zone (feet) 736 Number of Zones 1	l de la companya de	
Amount of Bioline® Per Zone (feet) 736 Number of Emitters Per Zone (feet) 736 Number of Emitters Per Zone 368 Minimum Number of Laterals Per Zone 1 Maximum Length of Bioline® Laterals Based on Inlet Pressure Flow Rate Per Zone (GPM) 3,7 Holding Capacity of Dripperline Per Zone (Gallons) 9,8 Additional Flow Requirement to Accommodate Flushing Velocity 3,2 Holding Capacity of Piping Holding Capacity (Gallons) of Supply Line & Supply & Flush Manifolds 9,8 Holding Capacity (Gallons) of Supply Line & Supply & Flush Manifolds 9,8 Holding Capacity (Gallons) of Supply Line & Supply & Flush Manifolds 9,8 Holding Capacity (Gallons) per Zone) of Bioline Holding Capacity (Gallons) per Zone) in Supply Line & Manifolds and Dripperline 26,0 Head Loss Data - Dosing & Flushing Cycle Friction Loss per 100° (psi) in Supply Line & Manifolds 9,8 Friction Loss in Supply Line & Supply Manifolds (psi) 1,2 Velocity (fps) 2,6 Friction Loss in Supply Line & Supply Manifolds (psi) 1,2 Additional Pressure Required for Return Manifold and Piping to Tank (psi) 1,2 Additional Pressure Required for Return Manifold and Piping to Tank (psi) 1,2 Additional Pressure Required for Return Manifold and Piping to Tank (psi) 1,2 Additional Pressure Required for Return Manifold and Piping to Tank (psi) 1,2 Additional Pressure Required for Return Manifold and Piping to Tank (psi) 1,2 Additional Pressure Required for Return Manifold and Piping to Tank (psi) 1,2 Additional Pressure Required for Return Manifold and Piping to Tank (psi) 1,2 Additional Pressure Required for Return Manifold and Piping to Tank (psi) 1,2 Additional Pressure Required for Return Manifold and Piping to Tank (psi) 1,2 Additional Pressure Required for Return Manifold and Piping to Tank (psi) 1,2 Additional Pressure Required for Return Manifold and Piping to Tank (psi) 1,2 Additional Pressure Required for Return Manifold and Piping to Tank (psi) 1,2 Additional Pressure Re	Total Number of Emitters in the Dripheid	300
Amount of Bioline® Per Zone (feet) 736 Number of Emitters Per Zone (feet) 736 Number of Emitters Per Zone 368 Minimum Number of Laterals Per Zone 1 Maximum Length of Bioline® Laterals Based on Inlet Pressure Flow Rate Per Zone (GPM) 3,7 Holding Capacity of Dripperline Per Zone (Gallons) 9,8 Additional Flow Requirement to Accommodate Flushing Velocity 3,2 Holding Capacity of Piping Holding Capacity (Gallons) of Supply Line & Supply & Flush Manifolds 9,8 Holding Capacity (Gallons) of Supply Line & Supply & Flush Manifolds 9,8 Holding Capacity (Gallons) of Supply Line & Supply & Flush Manifolds 9,8 Holding Capacity (Gallons) per Zone) of Bioline Holding Capacity (Gallons) per Zone) in Supply Line & Manifolds and Dripperline 26,0 Head Loss Data - Dosing & Flushing Cycle Friction Loss per 100° (psi) in Supply Line & Manifolds 9,8 Friction Loss in Supply Line & Supply Manifolds (psi) 1,2 Velocity (fps) 2,6 Friction Loss in Supply Line & Supply Manifolds (psi) 1,2 Additional Pressure Required for Return Manifold and Piping to Tank (psi) 1,2 Additional Pressure Required for Return Manifold and Piping to Tank (psi) 1,2 Additional Pressure Required for Return Manifold and Piping to Tank (psi) 1,2 Additional Pressure Required for Return Manifold and Piping to Tank (psi) 1,2 Additional Pressure Required for Return Manifold and Piping to Tank (psi) 1,2 Additional Pressure Required for Return Manifold and Piping to Tank (psi) 1,2 Additional Pressure Required for Return Manifold and Piping to Tank (psi) 1,2 Additional Pressure Required for Return Manifold and Piping to Tank (psi) 1,2 Additional Pressure Required for Return Manifold and Piping to Tank (psi) 1,2 Additional Pressure Required for Return Manifold and Piping to Tank (psi) 1,2 Additional Pressure Required for Return Manifold and Piping to Tank (psi) 1,2 Additional Pressure Required for Return Manifold and Piping to Tank (psi) 1,2 Additional Pressure Re	Zono Information	
Amount of Bioline® Per Zone (feet) Number of Emitters Per Zone Minimum Number of Laterals Per Zone Minimum Number of Laterals Per Zone Maximum Number of Laterals Per Zone Maximum Number of Laterals Per Zone Maximum Length of Bioline® Laterals Based on Intel Pressure Flow Rate Per Zone (Gellons) Additional Flow Requirement to Accommodate Flushing Velocity Holding Capacity of Piping Holding Capacity (Gallons) of Supply Line & Supply & Flush Manifolds Holding Capacity (Gallons) per Zone) of Bioline Holding Capacity (Gallons) of Supply Line & Supply & Flush Manifolds Holding Capacity (Gallons) of Supply Line & Supply & Flush Manifolds Holding Capacity (Gallons) per Zone) of Bioline Head Loss Data - Dosing & Flushing Cycle Friction Loss per 100' (psi) in Supply Line & Manifolds Friction Loss per 100' (psi) in Supply Line & Manifolds Friction Loss in Supply Line & Supply Manifolds (psi) Friction Loss in		
Number of Emitters Per Zone Minimum Number of Laterals Per Zone Maximum Number of Laterals Per Zone 11 Number of Laterals Per Zone 11 Number of Laterals That Will be Used 22 Maximum Length of Bioline® Laterals Based on Inlet Pressure Flow Rate Per Zone (GPM) 3,7 Holding Capacity of Dripperline Per Zone (Gallons) Additional Flow Requirement to Accommodate Flushing Velocity 4,2 Holding Capacity of Piping Holding Capacity (Gallons) of Supply Line & Supply & Flush Manifolds Holding Capacity (Gallons) of Supply Line & Supply & Flush Manifolds Holding Capacity (Gallons) of Supply Line, Manifolds and Dripperline 4,6 Holding Capacity (Gallons) of Supply Line, Manifolds and Dripperline 4,6 Holding Capacity (Gallons) of Supply Line, Manifolds and Dripperline 4,6 Holding Capacity (Gallons) of Supply Line, Manifolds and Dripperline 4,6 Friction Loss in Supply Line & Supply Manifolds (psi) Friction Loss in Suppl	-	
Minimum Number of Laterals Per Zone Maximum Number of Laterals Per Zone Maximum Number of Laterals Per Zone Number of Laterals Per Zone Maximum Length of Bioline Leterals Based on Inlet Pressure Flow Rate Per Zone (GPM) Flow Rate Per Zone (Gallons) Additional Flow Requirement to Accommodate Flushing Velocity Holding Capacity of Piping Holding Capacity (Gallons) of Supply Line & Supply & Flush Manifolds Holding Capacity (Gallons) of Supply Line & Supply & Flush Manifolds Holding Capacity (Gallons) of Supply Line, Manifolds of Supply Line & Manifolds Holding Capacity (Gallons) of Supply Line, Manifolds of Supply Line & Manifolds Holding Capacity (Gallons) of Supply Line & Manifolds Holding Capacity (Gallons) of Supply Line & Manifolds Friction Loss per 100' (psi) in Supply Line & Manifolds Friction Loss in Supply Line & Supply Manifolds (psi) Friction Loss in Supply Line & Supply Manifolds (psi) Friction Loss in Supply Line & Supply Manifolds (psi) Friction Loss in Supply Line & Supply Manifolds (psi) Friction Loss in Supply Line & Supply Manifolds (psi) Friction Loss in Supply Line & Supply Manifolds (psi) Friction Loss in Supply Line & Supply Manifolds (psi) Friction Loss in S	l	
Maximum Number of Laterals Per Zone Number of Laterals That Will be Used Maximum Length of Bioline® Laterals Based on Inlet Pressure Flow Rate Per Zone (GPM) Flow Rate Per Zone (GPM) Additional Flow Requirement to Accommodate Flushing Velocity Holding Capacity of Piping Holding Capacity of Piping Holding Capacity (Gallons) of Supply Line & Supply & Flush Manifolds Holding Capacity (Gallons per Zone) of Bioline Holding Capacity (Gallons per Zone) of Bioline Holding Capacity (Gallons per Zone) of Bioline Head Loss Data - Dosing & Flushing Cycle Friction Loss per 100' (psi) in Supply Line & Manifolds Friction Loss per 100' (psi) in Supply Line & Manifolds Friction Loss in Supply Line & Supply Manifolds (psi) Friction Loss in Supply Line & Supply Manifolds (psi) Friction Loss in Supply Line & Supply Manifolds (psi) Additional Pressure Required for Return Manifold and Piping to Tank (psi) Additional Pressure Required for Return Manifold and Piping to Tank (Feet of Head) TDH (Total Dynamic Head) in Feet of Head TDH (Total Dynamic Head) in Feet of Head Total System Runtime Per Day (Minutes) Control Settings Information Total System Runtime Per Day (Minutes) At Total System Dosing Events Per Day Runtime For Each Dose (Minutes) Off Time Between Doses in the Same Zone (Hours to nearest 0.1) Miscellaneous Information Dosing Volume Per Emitter Per Dose (gallons) Inches Per Week of Dosing Volume of a Single Dose (gallons) Volume of a Single Dose (gallons) TDH (Total Dynamic Head in Feet of Head) TDH (Total Dynamic Head in Feet of Head) TDH (Total Dynamic Head in Feet of Head)	· · · · · · · · · · · · · · · · · · ·	
Maximum Length of Bioline® Laterals Based on Inlet Pressure Flow Rate Per Zone (GPM) 3.7 Holding Capacity of Dripperline Per Zone (Gallons) Additional Flow Requirement to Accommodate Flushing Velocity 3.2 Holding Capacity of Piping Holding Capacity (Gallons) of Supply Line & Supply & Flush Manifolds Holding Capacity (Gallons per Zone) of Bioline Friction Loss Data - Dosing & Flushing Cycle Friction Loss per 100' (psi) in Supply Line & Manifolds Velocity (fps) Friction Loss in Supply Line & Supply Manifolds (Feet of Head) Friction Loss in Supply Line & Supply Manifolds (Feet of Head) Additional Pressure Required for Return Manifold and Piping to Tank (psi) Additional Pressure Required for Return Manifold and Piping to Tank (psi) TDH (Total Dynamic Head) in Feet of Head Total System Runtime Per Day (Minutes) Total System Runtime Per Day (Minutes) Total System Dosing Events Per Day Runtime For Each Dose (Minutes) Off Time Between Doses in the Same Zone (Hours to nearest 0.1) Miscellaneous Information Dosing Volume Per Emitter Per Dose (gallons) Volume of a Single Dose (gallons) Volume of a Single Dose (gallons) Total Pump Flow Rating (GPM) Pump Flow Rating (GPM) TDH (Total Dynamic Head in Feet of Head) 110.9	· · · · · · · · · · · · · · · · · · ·	
Maximum Length of Bioline® Laterals Based on Inlet Pressure Flow Rate Per Zone (GPM) 3.7 Holding Capacity of Dripperline Per Zone (Gallons) 9.8 Additional Flow Requirement to Accommodate Flushing Velocity 3.2 Holding Capacity of Piping Holding Capacity (Gallons) of Supply Line & Supply & Flush Manifolds Holding Capacity (Gallons) of Supply Line, Manifolds Per Zone) of Bioline 9.8 Holding Capacity (Gallons) of Supply Line, Manifolds and Dripperline 26.0 Head Loss Data - Dosing & Flushing Cycle Friction Loss per 100' (psi) in Supply Line & Manifolds Velocity (fps) 2.6 Friction Loss in Supply Line & Supply Manifolds (pest of Head) 10.1 Additional Pressure Required for Return Manifold and Piping to Tank (psi) 1.2 Additional Pressure Required for Return Manifold and Piping to Tank (Feet of Head) 10.1 Additional Pressure Required for Return Manifold and Piping to Tank (Feet of Head) 110.9 Control Settings Information 10.9 Control Settings Information 10.9 Total System Runtime Per Day (Minutes) 64 Total System Dosing Events Per Day (Minutes) 64 Total System Dosing Events Per Day (Minutes) 64 Total System Dosing Events Per Day (Minutes) 65 Off Time Between Doses in the Same Zone (Hours to nearest 0.1) 2.3 Miscellaneous Information 10.07 Dosing Volume Per Emitter Per Dose (gallons) 1.83 Volume of a Single Dose (gallons) 26.2 Pump Selection 10.9 Pump Flow Rating (GPM) 6.9 TDH (Total Dynamic Head in Feet of Head) 110.9	Maximum Number of Laterals Per Zone	11
Flow Rate Per Zone (GPM) Holding Capacity of Dripperline Per Zone (Gallons) Additional Flow Requirement to Accommodate Flushing Velocity Holding Capacity of Piping Holding Capacity (Gallons) of Supply Line & Supply & Flush Manifolds Holding Capacity (Gallons) of Supply Line & Supply & Flush Manifolds Holding Capacity (Gallons) of Supply Line & Supply & Flush Manifolds Holding Capacity (Gallons) of Supply Line & Manifolds and Dripperline Head Loss Data - Dosing & Flushing Cycle Friction Loss per 100° (psi) in Supply Line & Manifolds Friction Loss in Supply Line & Supply Manifolds (psi) Friction Loss in Supply Line & Supply Manifolds (psi) Friction Loss in Supply Line & Supply Manifolds (psi) Additional Pressure Required for Return Manifold and Piping to Tank (psi) 1.2 Additional Pressure Required for Return Manifold and Piping to Tank (psi) 1.2 Additional Pressure Required for Return Manifold and Piping to Tank (psi) 1.2 Control Settings Information Total System Runtime Per Day (Minutes) Total System Runtime Per Day (Minutes) Fotal System Per Day (Minutes) Fotal System Dosing Events Per Day 10 Runtime Per Zone Per Day (Minutes) 64 Total System Dosing Events Per Day 10 Runtime For Each Dose (Minutes) 65 Off Time Between Doses in the Same Zone (Hours to nearest 0.1) Miscellaneous Information Dosing Volume Per Emitter Per Dose (gallons) 1.83 Volume of a Single Dose (gallons) 2.62 Pump Selection Pump Flow Rating (GPM) 5.9 TDH (Total Dynamic Head in Feet of Head) 110.9	Number of Laterals That Will be Used	2
Holding Capacity of Dripperline Per Zone (Gallons) Additional Flow Requirement to Accommodate Flushing Velocity Holding Capacity of Piping Holding Capacity (Gallons) of Supply Line & Supply & Flush Manifolds Holding Capacity (Gallons per Zone) of Bioline Holding Capacity (Gallons) of Supply Line, Manifolds and Dripperline Head Loss Data - Dosing & Flushing Cycle Friction Loss per 100' (psi) in Supply Line & Manifolds Friction Loss in Supply Line & Supply Manifolds (psi) Friction Loss in Supply Line & Supply Manifolds (psi) Friction Loss in Supply Line & Supply Manifolds (Feet of Head) Additional Pressure Required for Return Manifold and Piping to Tank (psi) Additional Pressure Required for Return Manifold and Piping to Tank (psi) TDH (Total Dynamic Head) in Feet of Head Control Settings Information Total System Runtime Per Day (Minutes) Total Runtime Per Zone Per Day (Minutes) Runtime Per Each Dose (Minutes) Off Time Between Doses in the Same Zone (Hours to nearest 0.1) Miscellaneous Information Dosing Volume Per Emitter Per Dose (gallons) Volume of a Single Dose (gallons) Volume of a Single Dose (gallons) TDH (Total Dynamic Head in Feet of Head) TOTH (Total Dynamic Head in Feet of Head)	Maximum Length of Bioline [®] Laterals Based on Inlet Pressure	391
Holding Capacity of Piping Holding Capacity (Gallons) of Supply Line & Supply & Flush Manifolds Holding Capacity (Gallons) of Supply Line & Supply & Flush Manifolds Holding Capacity (Gallons) of Supply Line, Manifolds and Dripperline Head Loss Data - Dosing & Flushing Cycle Friction Loss per 100' (psi) in Supply Line & Manifolds Velocity (fps) Friction Loss in Supply Line & Supply Manifolds (psi) Friction Loss in Supply Line & Supply Manifolds (psi) Additional Pressure Required for Return Manifold and Piping to Tank (psi) Additional Pressure Required for Return Manifold and Piping to Tank (Feet of Head) TDH (Total Dynamic Head) in Feet of Head Total System Runtime Per Day (Minutes) Total System Runtime Per Day (Minutes) Fortial System Dosing Events Per Day Runtime For Each Dose (Minutes) Off Time Between Doses in the Same Zone (Hours to nearest 0.1) Miscellaneous Information Dosing Volume Per Emitter Per Dose (gallons) Volume of a Single Dose (gallons) Fump Flow Rating (GPM) TDH (Total Dynamic Head in Feet of Head) Pump Flow Rating (GPM) TDH (Total Dynamic Head in Feet of Head)	Flow Rate Per Zone (GPM)	3.7
Holding Capacity of Piping Holding Capacity (Gallons) of Supply Line & Supply & Flush Manifolds Holding Capacity (Gallons) of Supply Line & Supply & Flush Manifolds Holding Capacity (Gallons) of Supply Line, Manifolds and Dripperline Head Loss Data - Dosing & Flushing Cycle Friction Loss per 100' (psi) in Supply Line & Manifolds Velocity (fps) Friction Loss in Supply Line & Supply Manifolds (psi) Friction Loss in Supply Line & Supply Manifolds (psi) Friction Loss in Supply Line & Supply Manifolds (Feet of Head) Additional Pressure Required for Return Manifold and Piping to Tank (psi) Additional Pressure Required for Return Manifold and Piping to Tank (Feet of Head) TDH (Total Dynamic Head) in Feet of Head) Control Settings Information Total System Runtime Per Day (Minutes) Fotal Runtime Per Zone Per Day (Minutes) Auntime For Each Dose (Minutes) Off Time Between Doses in the Same Zone (Hours to nearest 0.1) Runtime For Each Dose (gallons) Volume Per Emitter Per Dose (gallons) Volume of a Single Dose (gallons) Volume of a Single Dose (gallons) TDH (Total Dynamic Head in Feet of Head) TDH (Total Dynamic Head in Feet of Head)	Holding Capacity of Dripperline Per Zone (Gallons)	9.8
Holding Capacity (Gallons) of Supply Line & Supply & Flush Manifolds Holding Capacity (Gallons per Zone) of Bioline 9.8 Holding Capacity (Gallons) of Supply Line, Manifolds and Dripperline 26.0 Head Loss Data - Dosing & Flushing Cycle Friction Loss per 100' (psi) in Supply Line & Manifolds Velocity (fps) 2.6 Friction Loss in Supply Line & Supply Manifolds (psi) Friction Loss in Supply Line & Supply Manifolds (psi) Friction Loss in Supply Line & Supply Manifolds (psi) Friction Loss in Supply Line & Supply Manifolds (psi) 1.2 Additional Pressure Required for Return Manifold and Piping to Tank (psi) Additional Pressure Required for Return Manifold and Piping to Tank (Feet of Head) TDH (Total Dynamic Head) in Feet of Head 110.9 Control Settings Information Total System Runtime Per Day (Minutes) Total System Dosing Events Per Day Runtime Por Each Dose (Minutes) Off Time Between Doses in the Same Zone (Hours to nearest 0.1) Miscellaneous Information Dosing Volume Per Emitter Per Dose (gallons) Normalian Volume of a Single Dose (gallons) Volume of a Single Dose (gallons) TOH (Total Dynamic Head in Feet of Head) 110.9	Additional Flow Requirement to Accommodate Flushing Velocity	3.2
Holding Capacity (Gallons) of Supply Line & Supply & Flush Manifolds Holding Capacity (Gallons per Zone) of Bioline 9.8 Holding Capacity (Gallons) of Supply Line, Manifolds and Dripperline 26.0 Head Loss Data - Dosing & Flushing Cycle Friction Loss per 100' (psi) in Supply Line & Manifolds Velocity (fps) 2.6 Friction Loss in Supply Line & Supply Manifolds (psi) Friction Loss in Supply Line & Supply Manifolds (psi) Friction Loss in Supply Line & Supply Manifolds (psi) Friction Loss in Supply Line & Supply Manifolds (psi) 1.2 Additional Pressure Required for Return Manifold and Piping to Tank (psi) Additional Pressure Required for Return Manifold and Piping to Tank (Feet of Head) TDH (Total Dynamic Head) in Feet of Head 110.9 Control Settings Information Total System Runtime Per Day (Minutes) Total System Dosing Events Per Day Runtime Por Each Dose (Minutes) Off Time Between Doses in the Same Zone (Hours to nearest 0.1) Miscellaneous Information Dosing Volume Per Emitter Per Dose (gallons) Normalian Volume of a Single Dose (gallons) Volume of a Single Dose (gallons) TOH (Total Dynamic Head in Feet of Head) 110.9		
Holding Capacity (Gallons per Zone) of Bioline Holding Capacity (Gallons) of Supply Line, Manifolds and Dripperline Head Loss Data - Dosing & Flushing Cycle Friction Loss per 100' (psi) in Supply Line & Manifolds Velocity (fps) 2.6 Friction Loss in Supply Line & Supply Manifolds (psi) Friction Loss in Supply Line & Supply Manifolds (psi) Additional Pressure Required for Return Manifold and Piping to Tank (psi) Additional Pressure Required for Return Manifold and Piping to Tank (psi) Additional Pressure Required for Return Manifold and Piping to Tank (Feet of Head) TDH (Total Dynamic Head) in Feet of Head 110.9 Control Settings Information Total System Runtime Per Day (Minutes) Total Runtime Per Zone Per Day (Minutes) Total System Dosing Events Per Day Runtime For Each Dose (Minutes) Off Time Between Doses in the Same Zone (Hours to nearest 0.1) Miscellaneous Information Dosing Volume Per Emitter Per Dose (gallons) Inches Per Week of Dosing Volume of a Single Dose (gallons) Volume of a Single Dose (gallons) TDH (Total Dynamic Head in Feet of Head) TDH (Total Dynamic Head in Feet of Head)		
Holding Capacity (Gallons) of Supply Line, Manifolds and Dripperline Head Loss Data - Dosing & Flushing Cycle Friction Loss per 100' (psi) in Supply Line & Manifolds Velocity (fps) 2.6 Friction Loss in Supply Line & Supply Manifolds (psi) 4.4 Friction Loss in Supply Line & Supply Manifolds (Feet of Head) 10.1 Additional Pressure Required for Return Manifold and Piping to Tank (psi) 1.2 Additional Pressure Required for Return Manifold and Piping to Tank (Feet of Head) 2.9 TDH (Total Dynamic Head) in Feet of Head) 110.9 Control Settings Information Total System Runtime Per Day (Minutes) 64 Total Runtime Per Zone Per Day (Minutes) 64 Total System Dosing Events Per Day 10 Runtime For Each Dose (Minutes) 6 Off Time Between Doses in the Same Zone (Hours to nearest 0.1) 2.3 Miscellaneous Information Dosing Volume Per Emitter Per Dose (gallons) 1.83 Volume of a Single Dose (gallons) 26.2 Pump Selection Pump Flow Rating (GPM) 6.9 TDH (Total Dynamic Head in Feet of Head) 110.9		
Head Loss Data - Dosing & Flushing Cycle Friction Loss per 100' (psi) in Supply Line & Manifolds Velocity (fps) 2.6 Friction Loss in Supply Line & Supply Manifolds (psi) 4.4 Friction Loss in Supply Line & Supply Manifolds (Feet of Head) Additional Pressure Required for Return Manifold and Piping to Tank (psi) Additional Pressure Required for Return Manifold and Piping to Tank (Feet of Head) TDH (Total Dynamic Head) in Feet of Head Control Settings Information Total System Runtime Per Day (Minutes) 64 Total System Dosing Events Per Day Runtime For Each Dose (Minutes) 65 Off Time Between Doses in the Same Zone (Hours to nearest 0.1) Miscellaneous Information Dosing Volume Per Emitter Per Dose (gallons) Volume of a Single Dose (gallons) Volume of a Single Dose (gallons) Pump Flow Rating (GPM) TDH (Total Dynamic Head in Feet of Head) 110.9		
Friction Loss per 100' (psi) in Supply Line & Manifolds Velocity (fps) 2.6 Friction Loss in Supply Line & Supply Manifolds (psi) 4.4 Friction Loss in Supply Line & Supply Manifolds (psi) 4.4 Friction Loss in Supply Line & Supply Manifolds (Feet of Head) 10.1 Additional Pressure Required for Return Manifold and Piping to Tank (psi) 1.2 Additional Pressure Required for Return Manifold and Piping to Tank (Feet of Head) 2.9 TDH (Total Dynamic Head) in Feet of Head 110.9 Control Settings Information Total System Runtime Per Day (Minutes) 64 Total System Dosing Events Per Day 10 Runtime Per Each Dose (Minutes) 6 Off Time Between Doses in the Same Zone (Hours to nearest 0.1) 2.3 Miscellaneous Information Dosing Volume Per Emitter Per Dose (gallons) 0.07 Inches Per Week of Dosing 1.83 Volume of a Single Dose (gallons) 26.2 Pump Selection Pump Flow Rating (GPM) 6.9 TDH (Total Dynamic Head in Feet of Head) 110.9	Holding Capacity (Gallons) of Supply Line, Manifolds and Dripperline	26.0
Friction Loss per 100' (psi) in Supply Line & Manifolds Velocity (fps) 2.6 Friction Loss in Supply Line & Supply Manifolds (psi) 4.4 Friction Loss in Supply Line & Supply Manifolds (psi) 4.4 Friction Loss in Supply Line & Supply Manifolds (psi) 4.4 Friction Loss in Supply Line & Supply Manifolds (psi) 4.4 Additional Pressure Required for Return Manifold and Piping to Tank (psi) 1.2 Additional Pressure Required for Return Manifold and Piping to Tank (Feet of Head) 2.9 TDH (Total Dynamic Head) in Feet of Head 110.9 Control Settings Information Total System Runtime Per Day (Minutes) 64 Total System Dosing Events Per Day 10 Runtime Per Each Dose (Minutes) 6 Off Time Between Doses in the Same Zone (Hours to nearest 0.1) 2.3 Miscellaneous Information Dosing Volume Per Emitter Per Dose (gallons) 0.07 Inches Per Week of Dosing 1.83 Volume of a Single Dose (gallons) 26.2 Pump Selection Pump Flow Rating (GPM) 6.9 TDH (Total Dynamic Head in Feet of Head) 110.9	Head Leas Date Desires & Flushing Cycle	
Velocity (fps) Friction Loss in Supply Line & Supply Manifolds (psi) Friction Loss in Supply Line & Supply Manifolds (psi) Friction Loss in Supply Line & Supply Manifolds (Feet of Head) Additional Pressure Required for Return Manifold and Piping to Tank (psi) Additional Pressure Required for Return Manifold and Piping to Tank (Feet of Head) TDH (Total Dynamic Head) in Feet of Head Control Settings Information Total System Runtime Per Day (Minutes) Total Runtime Per Zone Per Day (Minutes) Fotal System Dosing Events Per Day Runtime For Each Dose (Minutes) Off Time Between Doses in the Same Zone (Hours to nearest 0.1) Miscellaneous Information Dosing Volume Per Emitter Per Dose (gallons) Volume of a Single Dose (gallons) Volume of a Single Dose (gallons) TOH (Total Dynamic Head in Feet of Head) TOH (Total Dynamic Head in Feet of Head) 110.9		1 2
Friction Loss in Supply Line & Supply Manifolds (psi) Friction Loss in Supply Line & Supply Manifolds (Feet of Head) Additional Pressure Required for Return Manifold and Piping to Tank (psi) Additional Pressure Required for Return Manifold and Piping to Tank (Feet of Head) TDH (Total Dynamic Head) in Feet of Head Control Settings Information Total System Runtime Per Day (Minutes) Total Runtime Per Zone Per Day (Minutes) Total System Dosing Events Per Day Runtime For Each Dose (Minutes) Off Time Between Doses in the Same Zone (Hours to nearest 0.1) Miscellaneous Information Dosing Volume Per Emitter Per Dose (gallons) Volume of a Single Dose (gallons) Volume of a Single Dose (gallons) TDH (Total Dynamic Head in Feet of Head) TDH (Total Dynamic Head in Feet of Head) 110.9		
Friction Loss in Supply Line & Supply Manifolds (Feet of Head) Additional Pressure Required for Return Manifold and Piping to Tank (psi) Additional Pressure Required for Return Manifold and Piping to Tank (Feet of Head) TDH (Total Dynamic Head) in Feet of Head Control Settings Information Total System Runtime Per Day (Minutes) Total Runtime Per Zone Per Day (Minutes) Total System Dosing Events Per Day Runtime For Each Dose (Minutes) Off Time Between Doses in the Same Zone (Hours to nearest 0.1) Miscellaneous Information Dosing Volume Per Emitter Per Dose (gallons) Volume of a Single Dose (gallons) Pump Selection Pump Flow Rating (GPM) TDH (Total Dynamic Head in Feet of Head) 10.1 1.2 1.2 1.2 1.2 1.2 1.3 1.3 1.3 1.3 1.3 1.3 1.3 1.3 1.3 1.3	to the control of the	
Additional Pressure Required for Return Manifold and Piping to Tank (psi) Additional Pressure Required for Return Manifold and Piping to Tank (Feet of Head) TDH (Total Dynamic Head) in Feet of Head Control Settings Information Total System Runtime Per Day (Minutes) Total Runtime Per Zone Per Day (Minutes) A Total System Dosing Events Per Day Runtime For Each Dose (Minutes) Off Time Between Doses in the Same Zone (Hours to nearest 0.1) Miscellaneous Information Dosing Volume Per Emitter Per Dose (gallons) Inches Per Week of Dosing Volume of a Single Dose (gallons) Pump Selection Pump Flow Rating (GPM) TDH (Total Dynamic Head in Feet of Head) 110.9		
Additional Pressure Required for Return Manifold and Piping to Tank (Feet of Head) TDH (Total Dynamic Head) in Feet of Head Control Settings Information Total System Runtime Per Day (Minutes) Total Runtime Per Zone Per Day (Minutes) Total System Dosing Events Per Day Runtime For Each Dose (Minutes) Off Time Between Doses in the Same Zone (Hours to nearest 0.1) Miscellaneous Information Dosing Volume Per Emitter Per Dose (gallons) Inches Per Week of Dosing 1.83 Volume of a Single Dose (gallons) Pump Selection Pump Flow Rating (GPM) TDH (Total Dynamic Head in Feet of Head) 110.9	l in the second of the second	
Control Settings Information Total System Runtime Per Day (Minutes) 64 Total Runtime Per Zone Per Day (Minutes) 64 Total System Dosing Events Per Day Runtime For Each Dose (Minutes) 6 Off Time Between Doses in the Same Zone (Hours to nearest 0.1) Miscellaneous Information Dosing Volume Per Emitter Per Dose (gallons) Inches Per Week of Dosing Volume of a Single Dose (gallons) Pump Selection Pump Flow Rating (GPM) TDH (Total Dynamic Head in Feet of Head) 110.9	l variable de la companya de la comp	
Total System Runtime Per Day (Minutes) Total Runtime Per Zone Per Day (Minutes) Gequation For Each Dose (Minutes) Runtime For Each Dose (Minutes) Off Time Between Doses in the Same Zone (Hours to nearest 0.1) Miscellaneous Information Dosing Volume Per Emitter Per Dose (gallons) Inches Per Week of Dosing Volume of a Single Dose (gallons) Pump Selection Pump Flow Rating (GPM) TDH (Total Dynamic Head in Feet of Head) 110.9	TDH (Total Dynamic Head) in Feet of Head	110.9
Total System Runtime Per Day (Minutes) Total Runtime Per Zone Per Day (Minutes) Gequation For Each Dose (Minutes) Runtime For Each Dose (Minutes) Off Time Between Doses in the Same Zone (Hours to nearest 0.1) Miscellaneous Information Dosing Volume Per Emitter Per Dose (gallons) Inches Per Week of Dosing Volume of a Single Dose (gallons) Pump Selection Pump Flow Rating (GPM) TDH (Total Dynamic Head in Feet of Head) 110.9		
Total Runtime Per Zone Per Day (Minutes) Total System Dosing Events Per Day Runtime For Each Dose (Minutes) 6 Off Time Between Doses in the Same Zone (Hours to nearest 0.1) Miscellaneous Information Dosing Volume Per Emitter Per Dose (gallons) Inches Per Week of Dosing Volume of a Single Dose (gallons) Pump Selection Pump Flow Rating (GPM) TDH (Total Dynamic Head in Feet of Head) 110.9		
Total System Dosing Events Per Day Runtime For Each Dose (Minutes) Off Time Between Doses in the Same Zone (Hours to nearest 0.1) Miscellaneous Information Dosing Volume Per Emitter Per Dose (gallons) Inches Per Week of Dosing Volume of a Single Dose (gallons) Pump Selection Pump Flow Rating (GPM) TDH (Total Dynamic Head in Feet of Head) 110.9	la companya di managan	
Runtime For Each Dose (Minutes) 6 Off Time Between Doses in the Same Zone (Hours to nearest 0.1) 2.3 Miscellaneous Information Dosing Volume Per Emitter Per Dose (gallons) 0.07 Inches Per Week of Dosing 1.83 Volume of a Single Dose (gallons) 26.2 Pump Selection Pump Flow Rating (GPM) 6.9 TDH (Total Dynamic Head in Feet of Head) 110.9		
Miscellaneous Information Dosing Volume Per Emitter Per Dose (gallons) Inches Per Week of Dosing Volume of a Single Dose (gallons) Pump Selection Pump Flow Rating (GPM) TDH (Total Dynamic Head in Feet of Head) 12.3 2.3 2.3 2.3 2.3		
Miscellaneous Information Dosing Volume Per Emitter Per Dose (gallons) Inches Per Week of Dosing Volume of a Single Dose (gallons) Pump Selection Pump Flow Rating (GPM) TDH (Total Dynamic Head in Feet of Head) 110.9	l	
Dosing Volume Per Emitter Per Dose (gallons) Inches Per Week of Dosing 1.83 Volume of a Single Dose (gallons) 26.2 Pump Selection Pump Flow Rating (GPM) TDH (Total Dynamic Head in Feet of Head) 110.9	Oil Tillie between boses in the Same Zone (Hours to hearest 0.1)	2.3
Dosing Volume Per Emitter Per Dose (gallons) Inches Per Week of Dosing 1.83 Volume of a Single Dose (gallons) 26.2 Pump Selection Pump Flow Rating (GPM) TDH (Total Dynamic Head in Feet of Head) 110.9	Miggellaneaus Information	
Inches Per Week of Dosing 1.83 Volume of a Single Dose (gallons) 26.2 Pump Selection Pump Flow Rating (GPM) 6.9 TDH (Total Dynamic Head in Feet of Head) 110.9		0.07
Volume of a Single Dose (gallons) 26.2 Pump Selection Pump Flow Rating (GPM) 6.9 TDH (Total Dynamic Head in Feet of Head) 110.9		
Pump Selection Pump Flow Rating (GPM) TDH (Total Dynamic Head in Feet of Head) 110.9	The state of the s	
Pump Flow Rating (GPM) 6.9 TDH (Total Dynamic Head in Feet of Head) 110.9	volunte of a onligic bose (gallons)	20.2
Pump Flow Rating (GPM) 6.9 TDH (Total Dynamic Head in Feet of Head) 110.9	Pump Selection	
TDH (Total Dynamic Head in Feet of Head) 110.9	· · · · · · · · · · · · · · · · · · ·	6.9
· · · · · · · · · · · · · · · · · · ·	_ · · · · · · · · · · · · · · · · · · ·	
	l	
Pump Model 20xC1-05P4-2W115	Pump Model 20	XC1-05P4-2W115



PIPE AND FITTINGS:

All pipes and fittings in this drip tubing system shall be 1" schedule 40 pvc. All joints shall be sealed with approved solvent type pvc cement. Clipper type cutters are recommended to prevent pvc burrs during cutting of pipes causing possible plugging.

Designed in accordance with Chapter 285, Subchapter D, §285 and §285.40 Texas Commission on Environmental Quality (Revised March 2013).



10/17/2025

Haag Engineering Consultants, LLC

Firm No.: F-5786

GENERAL NOTES:

- NO VEHICULAR TRAFFIC IS ALLOWED ON ANY PORTION OF THE DISPOSAL SYSTEM, UNLESS THE DESIGN SPECIFIES OTHERWISE.
- PIPE ALIGNMENT TO THE DISPOSAL BEDS MAY BE ALTERED AS REQUIRED. ANY CHANGE FROM THE PLANS MUST BE APPROVED BY THE ENGINEER AND THE APPROPRIATE GOVERNMENTAL AGENCY(IES).
- CONTRACTOR SHALL PROTECT TREES WHICH ARE NOT IN THE EXCAVATED CONSTRUCTION AREAS. CONTRACTOR SHALL MINIMIZE ROOT DAMAGE AND REASONABLY ADHERE TO THE DESIGN.
- 4. CONTRACTOR IS RESPONSIBLE FOR VERIFYING A MINIMUM OF 1/4" PER FOOT OF FALL FROM THE BUILDING TO THE SEPTIC TANK.
- NOT AUTOMATIC SPRINKLER SYSTEM SHALL BE INSTALLED OVER THE DISPOSAL AREAS. ANY WATERING IN THESE AREAS SHALL BE DONE BY HAND AND ONLY WHEN REQUIRED TO MAINTAIN GRASS COVER.
- ALL CONSTRUCTION SHALL CONFORM TO THE RULES AND REGULATIONS OF THE APPROPRIATE AUTHORITY - TEXAS COMMISSION ON ENVIRONMENTAL QUALITY (TCEQ) AND ANY APPLICABLE LOCAL BUILDING AND SAFETY CODES.
- 7. CONTRACTOR SHALL BE RESPONSIBLE FOR LOCATING AND VERIFYING THE LOCATION OF ALL EXISTING UNDERGROUND UTILITIES THAT MAY BE AFFECTED BY THE CONSTRUCTION OF THIS SYSTEM.
- THE DRIP FIELD SHALL BE VEGETATED WITH EITHER ST. AUGUSTINE OR BERMUDA SOD.
- FIELDS MUST BE MOWED AT REGULAR INTERVALS. FAILURE TO PROPERLY MAINTAIN VEGETATIVE COVER MAY RESULT IN SYSTEM FAILURE AND SHALL BE THE
- 10. ALL PIPES SHALL BE SCHEDULE 40 PVC OR APPROVED EQUAL, UNLESS NOTED OTHERWISE. ALL JOINTS SHALL BE CLEANED WITH THE APPROPRIATE SOLVENT AND GLUED IN ACCORDANCE WITH THE MANUFACTURER'S RECOMMENDATION.
- ALL POTABLE WATER LINES SHALL BE A MINIMUM OF 10 FEET FROM ANY DISPOSAL SYSTEM OR SEWERAGE PIPE. THE CONTRACTOR SHALL NOTIFY THE ENGINEER OF WATER LINES LESS THAN 10 FEET FROM THE DISPOSAL AREA.
- HIGH WATER ALARM SHALL BE LOCATED IN A NOTICEABLE LOCATION. THE ALARM SHALL BE A VISUAL AND AUDIBLE ALARM AND WIRED ON A SEPARATE CIRCUIT FROM THE PUMPS. ALL EXTERIOR CONTROLS AND CONNECTIONS SHALL BE ENCLOSED IN A WEATHER-PROOF HOUSING. ELECTRICAL CONSTRUCTION SHALL COMPLY WITH ALL LOCAL ELECTRICAL AND BUILDING CODES.
- 13. NO EXCAVATION IS PERMITTED NEAR THE DISPOSAL FIELDS THAT WILL RESULT IN THE NONCOMPLIANCE OF APPLICABLE SETBACKS STATED IN THE RULES AND REGULATIONS OF THE APPROPRIATE AUTHORITY.
- 14. ONLY GOOD QUALITY SANDY LOAM SHALL BE APPLIED OVER THE DISPOSAL FIELDS. CLAY LOAM IS UNACCEPTABLE AND WILL CAUSE SYSTEM FAILURE. SANDY LOAM SHALL BE DEFINED AS SHOWN IN TABLE VI (USDA SOIL TEXTURAL CLASSIFICATIONS) OF THE RULES AND REGULATIONS OF THE TCEO. THE INSTALLER IS RESPONSIBLE FOR VERIFYING THE QUALITY OF EACH LOAD OF LOAM PLACED ON THE
- 15. STORM WATER (RAINFALL RUNOFF) SHOULD NOT BE ALLOWED TO FLOW OVER THE DISPOSAL FIELDS OR THE TANKS. DIVERSION BERMS, SWALES AND/OR RAIN GUTTERS SHOULD BE INSTALLED AS NECESSARY TO PREVENT SUCH RUNOFF.
- THE CONTRACTOR IS RESPONSIBLE FOR STAKING AND VERIFYING THE GRADES PRIOR TO EXCAVATION. ANY DISCREPANCIES OF MORE THAN 6 INCHES SHALL BE REPORTED TO THE ENGINEER PRIOR TO EXCAVATION. THE CONTRACTOR SHALL NOT DEVIATE FROM THESE PLANS WITHOUT THE WRITTEN CONSENT OF THE APPROPRIATE AUTHORITY AND THE ENGINEER.
- 17. THIS DISPOSAL SYSTEM HAS BEEN DESIGNED TO OPERATE PROPERLY AT SPECIFICATIONS NOTED IN THESE PLANS. ALTERATIONS TO THE SYSTEM BY THE OWNER, INCLUDING BUT NOT LIMITED TO LANDSCAPING, DRAINAGE, BUILDING AND/OR WATER USAGE, MAY CAUSE PREMATURE FAILURE AND SHALL BE THE SOLE RESPONSIBILITY OF THE OWNER.
- 18. CONTRACTOR SHALL BE RESPONSIBLE FOR VERIFYING ALL PLUMBING FIXTURES ARE CONNECTED TO THE DESIGNATED SEPTIC TANK(S). LOW FLOW TOILETS (1.6 GAL), SHOWERHEADS AND FAUCETS SHALL BE USED IN THE STRUCTURES.
- CONTRACTOR SHALL BE RESPONSIBLE FOR JOBSITE SAFETY AND PROTECTION OF THE PUBLIC FROM INJURY DURING CONSTRUCTION. THE OWNER SHALL BE RESPONSIBLE FOR THE PREVENTION OF PERSONAL INJURY TO ANYONE ON OR NEAR
- CONTRACTOR SHALL BE RESPONSIBLE TO ENSURE THAT ALL TANKS HAVE ADEQUATE STRENGTH AND INTEGRITY TO PERFORM SATISFACTORILY AS SHOWN ON
- THE WASTEWATER FLOW TO THE SEPTIC SYSTEM SHALL NOT EXCEED THE DESIGN FLOW SHOWN ON THIS PLAN.


PLAN REVISION NOTE:


THIS PLAN WAS REVISED ON 10/17/25 TO REFLECT, AS MUCH AS POSSIBLE. AS-BUILT INFORMATION PROVIDED TO HAAG ENGINEERING CONSULTANTS BY THE SEPTIC SYSTEM INSTALLER. HAAG ENGINEERING CONSULTANTS HAS NOT FIELD VERIFIED ANY SEPTIC SYSTEM AS-BUILT CONDITIONS FOR THIS PROJECT AND DOES NOT ATTEST TO IT'S VALIDITY AND/OR ACCURACY.

> **OSSF LAYOUT** LOT 889, BONNYVIEW DR. **CANYON LAKE FOREST, UNIT 2** CANYON LAKE, TEXAS

Received

Brandon Mark Olvera 10/17/2025 2:23:40 PM





DRIP FIELD CROSS SECTION SCALE: 1"=5

> DRAWN BY: JJH CHECKED BY: JJH DATE: 10/17/25 JOB NO. LJQUALITY24001

> > SHEET 1 OF 1



15831 SECRET TRAILS SAN ANTONIO, TEXAS 78247 FIRM: F-5789

1'' = 20'

TEL: (210) 705-4268

© COPYRIGHT 2024 HAAG ENGINEERING CONSULTANTS; ALL RIGHTS RESERVED

-600 GPD MIN. AEROBIC TREATMENT PLANT

WITH FRANKLIN 20CX1-05P4-2W115 (OR

DISPOSAL AREA LIMITS AND/OR ANY SYSTEM COMPONENT(S).

EXCEEDS TAC 30 CHAPTER 290.44(e).

APPROVED EQUIVALENT) 20 GPM PUMP.

DESIGN DAILY WASTEWATER FLOW = 240 GPD (WATER SAVING DEVICES WERE ASSUMED FOR SEPTIC SYSTEM DESIGN).

TOPOGRAPHIC DATA SOURCE: FEMA 2011 DATA

INSTALLER SHALL VERIFY ALL EASEMENTS, SETBACKS AND PROPERTY LINE BEARINGS AND DISTANCES PRIOR TO CONSTRUCTION ALL RISERS SHALL MEET THE MINIMUM REQUIREMENST OF 30 TAC 285 EFFECTIVE 07/06/2023

NOTE: OSSF IS NOT WITHIN THE EDWARDS AQUIFER RECHARGE ZONE OR FEMA 100 YEAR FLOODPLAIN. SITE EVALUATION BY JOHN J. HAAG. P.E. ON 04/03/2024

Received Brandon Mark Olvera

10/17/2025 2:23:54 PM

ASSEMBLY DETAILS


Dimensions:

Outside Height: 65.5" Outside Width: 77" Outside Length: 158.65



General Notes:

- 1. Structure material to be precast concrete and steel.
- 2. Maximum burial depth is 30" from slab top to grade.
- 3. Treatment Capacity is 600 GPD. Trash Tank is 500 gallons. Pump Tank is 800 gallons.
- 4. BOD Loading = 1.2-1.8 lbs./day
- 5. Standard tablet chlorinator or optional liquid chlorinator. NSF approved chlorinators available.
- 6. 20" access riser with lid. Extension risers available.
- 7. 20 GPM, ½ HP effluent pump.
- 8. Thomas/HiBlow Air Compressor connected with ½" Sch 40 PVC pipe (Max. 50 Lft from plant).
- 9. AKA600CA with timed spray application (AKT Panel).



13.44 GAL/IN

50" - 59.5" - RESERVE - 127.68 GALLONS

50" - ALARM ON

65.5" 12" - 50" - WORKING LEVEL - 510.72 GALLONS

10" - 12" - ON/OFF TETHER - 26.88 GALLONS

0 - 10" SUMP - 134.4 GALLONS

NOTE: SET ON A TIMER TO DOSE IN PREDAWN HOURS BETWEEN MIDNIGHT TO 5AM.

AKA600CA

NOT TO SCALE

DESIGNED TO TREAT 600 GALLONS PER DAY

TRASH TANK: 500 GALLONS
AERATION ZONE: 633 GALLONS


CLARIFIER ZONE: 220 GALLONS PUMP TANK: 800 GALLONS



AguaKlear, Inc.

876 N. Bierdeman Rd. Pearl, MS 39208 877-936-7711





FEATURES

- Supplied with a removable 5" base for secure and reliable mounting
- Bottom suction design
- Robust thermoplastic discharge head design resists breakage during installation and operation
- Single shell housing design provides a compact unit while ensuring cool and quiet operation
- Hydraulic components molded from high quality engineered thermoplastics
- Optimized hydraulic design allows for increased performance and decreased power usage
- All metal components are made of high grade stainless steel for corrosion resistance
- Available with a high quality 115 V or 230 V, ½ hp motor
- Fluid flows of 10, 20, and 30 gpm, with a max shut-off pressure of over 100 psi
- Heavy duty 600 V 10 foot SJ00W jacketed lead

APPLICATIONS

- Gray water pumping
- Filtered effluent service water pumping
- Water reclamation projects such as pumping from rain catchment basins
- Aeration and other foundation or pond applications
- Agriculture and livestock water pumping

ORDERING INFORMATION

				C1 Serie	es Pumps		
GPM	HP	Volts	Stage	Model No.	Order No.	Length (in)	Weight (lbs)
10		115	7	10C1-05P4-2W115	90301005	26	17
10		230	7	10C1-05P4-2W230	90301010	26	17
20	1/2	115	5	20C1-05P4-2W115	90302005	25	16
20		230	5	20C1-05P4-2W230	90302010	25	16
20X		115	6	20XC1-05P4-2W115	90302015	26	17
201		230		20XC1-05P4-2W230	90302020	26	17
20		115	4	30C1-05P4-2W115	90303005	25	16
30		230	4	30C1-05P4-2W230	90303010	25	16

Note: All units have 10 foot long SJOOW leads.





1" SUPER/LONG MANUAL DISC FILTER

INSTALLATION, OPERATION & MAINTENANCE INSTRUCTIONS

FEATURES

- A "T' shaped reinforced plastic filter with two 1" male connections.
- Filter element consists of grooved discs, mounted on a spine, forming a cylindrical filter element. The discs are compressed together by a spring located at the bottom of the filter cover.
- · Screw-on filter cover.
- · Resistant to chemicals and liquid fertilizers.
- Available filtration grades: 040, 080, 120, 140 and 200.

TECHNICAL DATA	
FLOW RANGE	10 - 35 GPM
MAXIMUM PRESSURE	140 psi
FILTERING SURFACE AREA	78 sq. in.
FILTERING VOLUME	36 cu. in.
LENGTH	13 13/32"
WIDTH	6 7/32"
WEIGHT	3.11 lbs.
DISTANCE BETWEEN ENDS	6 7/32"
INLET/OUTLET DIAMETER	1" Male
MAXIMUM TEMPERATURE	158° F
pH	5 - 11



MESH/MICRON									
MESH	MICRON	DISC COLOR							
040	400	Blue							
080	200	Yellow							
120	130	Red							
140	115	Black							
200	55	Green							

INSTALLATION

- 1. Filter can be installed either vertically or horizontally.
- 2. Use Teflon tape on filter threads Do Not Use Pipe Dope.
- 3. Ensure correct inlet/outlet direction.
- 4. When connecting filter to pipe, do not overtighten.
- 5. Never use spanners for tighening the filter cover.


MAINTENANCE AND CLEANING


DISMANTLING

- 1. Ensure system is turned off and no pressure remains in the pipeline.
- 2. Unscrew cover from the filter body.
- 3. Pull out entire filter element.

CLEANING

- 1. Move tightening ring to end of spine and flush discs with pressurized water.
- 2. If discs are not clean after flushing with water:
 - a. If the discs have an accumulation of algae in the grooves, soak the discs and spine in a small bucket of Clorox bleach for one hour and then reflush with fresh water.
 - b. If the discs have an accumulation of iron in the grooves, soak the discs and spine in a small bucket of 10% Muriatic Acid for one hour and then reflush with fresh water.
 Muriatic Acid can be purchased at any pool supply store.







MAINTENANCE AND CLEANING

ASSEMBLY

- 1. Verify that spring is in place inside the filter cover.
- 2. Insert filter element and make sure it is seated correctly.
- 3. Replace cover.
- 4. Tighten filter cover securely by turning the fixing nut clockwise and do not overtighten.


WINTERIZATION

Drain all the water from the filter to avoid cracking due to freezing.

PART	S BREAKDOW	N - 1" SUPER/LONG F	ILTER
KEY	MODEL NUMBER	DESCRIPTION	MATERIALS
1	SEE # 11	GAUGE PORT NUT	R.PP
2	SEE # 11	GAUGE PORT SEAL	EPDM
3	-	FILTER ADAPTER RING	R.PA
4	25AP531140	COVER O RING	NR
5	25AP50440011	COMPRESSION SPRING	SS
6	25AP23113	FILTER COVER	R.PA
7	-	1/4" TAP (OPTIONAL)	BRASS
8	25AP231131	FIXING NUT	R.PA
9	25AP131199	FILTER WRENCH	R.PA
10	25AP21121-***	RING SET WITH SPINE	PP
11	25AP25000101	FILTER BODY COMPLETE	-

Substitute *** for proper mesh size.

MATERIALS KEY									
CODE	MATERIAL								
SS	STAINLESS STEEL								
PP	POLYPROPYLENE								
NR	NITRILE RUBBER								
R.PP	REINFORCED POLYPROPYLENE								
R.PA	REINFORCED POLYAMIDE								
EPDM	ETH. PROPY. RUBBER								





5470 E. Home Ave. Fresno, CA 93727 888.638.2346 • 559.453.6800 FAX 800.695.4753 www.netafimusa.com



BIOLINE® DRIPLINE

THE WORLD'S MOST ADVANCED CONTINUOUS SELF-CLEANING, PRESSURE COMPENSATING DRIPLINE SPECIFICALLY DESIGNED FOR WASTEWATER

CROSS SECTION OF BIOLINE DRIPLINE

Bioline dripper inlets are positioned in the center of flow where water is the cleanest





PRODUCT ADVANTAGES

- Pressure compensation all drippers deliver equal flow, even on sloped or rolling terrain.
- Unique flow path Turbonet technology provides more control of water and a high resistance to clogging.
- Continuous self-flushing dripper design flushes debris, as it is detected - throughout operation, not just at the beginning or end of a cycle. Ensures uninterrupted dripper operation.
- · Single hole dripper outlet from tubing:
 - Better protection against root intrusion
 - Allows the dripline to be used in subsurface applications without need for chemical protection
- Drippers capture water flow from the center of the tubing ensures that only the cleanest flow enters the dripper.
- Built-in physical root barrier drippers are protected from root intrusion without the need for chemical protection. Water exits dripper in one location while exiting the tubing in another.
- Three dripper flow rates provides the broadest range of flow rates available. Allows the designer to match the dripline to any soil or slope condition.
- Bioline tubing is completely wrapped in purple easily identifying it for non-potable use, regardless of how the tubing is installed.
- Anti-bacterial-impregnated drippers prevents buildup of microbial slime.
- Can be used subsurface Bioline can be installed on-surface, under cover or subsurface.
- No special storage requirements does not degrade if stored outdoors.
- Techfilter compatible an optional level of protection, provides a limited lifetime warranty against root intrusion.

APPLICATIONS

- Typically installed following a treatment process
- Can be used with domestic septic tank effluent with proper design, filtration and operation
- Reuse applications including municipally treated effluent designated for irrigation and other disinfected and non-disinfected water sources.

SPECIFICATIONS

- Dripper flow rates: 0.4, 0.6 or 0.9 GPH
- Dripper spacings: 12", 18" or 24" dripper spacings and blank tubing
- Pressure compensation range: 7 to 58 psi (stainless steel clamps recommended above 50 psi)
- Maximum recommended system pressure: 50 psi
- Tubing diameter: 0.66" OD, 0.57" ID
- Tubing color: Purple color indicates nonnotable
- Coil lengths: 500' or 1,000' (Blank tubing in 250')
- · Recommended filtration: 120 mesh
- Bending radius: 7"
- UV resistant
- Tubing material: Linear low-density polyethylene

Additional spacing and pipe sizes available by special order. Please contact Netafim USA Customer Service for details.

BIOLINE DRIPLINE

MAXIMUM LENGTH OF A SINGLE LATERAL WITH 3.0 fps Flush velocity ADDITIONAL FLOW OF 2.3 GPM REQUIRED PER LATERAL TO ACHIEVE 3 fps DRIPPER SPACING DRIPPER FLOW RATE (GPH) | 0.4 GPH | 0.6 GPH | 0.9 GPH | 0.4 GPH | 0.6 GPH | 0.9 GPH | 0.4 GPH | 0.6 GPH | Flow per 100' (GPM / GPH) 1.53/92 0.77/46 0.67/40 1.02/61 0.44/26.67 0.68/41 1.02/61 0.51/31

Lateral lengths are based on flows allowing for a 3 fps flushing/scouring velocity

MAX	MAXIMUM LENGTH OF A SINGLE LATERAL WITH 2.5 fps FLUSH VELOCITY									
ADD	ADDITIONAL FLOW OF 2.0 GPM REQUIRED PER LATERAL TO ACHIEVE 2.5 fps									
I	DRIPPER SPACING 12" 18" 24"									
DRIP	PER FLOW RATE (GPH)	0.4 GPH	0.6 GPH	0.9 GPH	0.4 GPH	0.6 GPH	0.9 GPH	0.4 GPH	0.6 GPH	0.9 GPH
щ	15	128	115	100	172	155	136	205	187	165
SE	25	183	161	137	248	220	188	301	268	231
PRESSURE	35	228	198	166	310	272	229	379	333	283
INLET	40	248	214	178	338	295	247	413	362	305
Z	45	266	229	190	364	316	263	447	389	327
Flow	per 100' (GPM / GPH)	0.67/40	1.02/61	1.53/92	0.44/26.67	0.68/41	1.02/61	0.34/20	0.51/31	0.77/46

Lateral lengths are based on flows allowing for a 2.5 fps flushing/scouring velocity

MAX	MAXIMUM LENGTH OF A SINGLE LATERAL WITH 2.0 fps Flush velocity										
ADD	ADDITIONAL FLOW OF 1.6 GPM REQUIRED PER LATERAL TO ACHIEVE 2.0 fps										
I	DRIPPER SPACING 12" 18" 24"										
DRIP	PER FLOW RATE (GPH)	0.4 GPH	0.6 GPH	0.9 GPH	0.4 GPH	0.6 GPH	0.9 GPH	0.4 GPH	0.6 GPH	0.9 GPH	
ш	15	161	141	119	217	191	164	263	233	201	
PRESSURE	25	221	190	157	302	261	218	369	321	270	
PRES	35	269	229	187	370	316	260	455	391	324	
INLET	40	290	246	200	399	340	278	493	421	347	
2	45 310 261 212 427 362 296 527 449 369										
Flow	per 100' (GPM / GPH)	0.67/40	1.02/61	1.53/92	0.44/26.67	0.68/41	1.02/61	0.34/20	0.51/31	0.77/46	

Lateral lengths are based on flows allowing for a 2 fps flushing/scouring velocity

MAX	MAXIMUM LENGTH OF A SINGLE LATERAL WITH 1.5 fps FLUSH VELOCITY										
ADD	ADDITIONAL FLOW OF 1.2 GPM REQUIRED PER LATERAL TO ACHIEVE 1.5 fps										
I	DRIPPER SPACING 12" 18" 24"										
DRIP	PER FLOW RATE (GPH)	0.4 GPH	0.6 GPH	0.9 GPH	0.4 GPH	0.6 GPH	0.9 GPH	0.4 GPH	0.6 GPH	0.9 GPH	
щ	15	201	171	140	275	235	194	337	289	241	
PRESSURE	25	266	222	179	366	308	251	453	383	313	
RES	35	316	262	210	437	365	295	543	455	369	
INLET	40	337	280	223	469	391	313	583	487	393	
2	2 45 358 296 235 497 413 331 619 517 415										
Flow	per 100' (GPM / GPH)	0.67/40	1.02/61	1.53/92	0.44/26.67	0.68/41	1.02/61	0.34/20	0.51/31	0.77/46	

Lateral lengths are based on flows allowing for a 1.5 fps flushing/scouring velocity

	MAXIMUM LENGTH OF A SINGLE LATERAL WITH 1.0 fps FLUSH VELOCITY ADDITIONAL FLOW OF 0.8 GPM REQUIRED PER LATERAL TO ACHIEVE 1.0 fps										
- 1	DRIPPER SPACING 12" 18" 24"										
DRIP	PER FLOW RATE (GPH)	0.4 GPH	0.6 GPH	0.9 GPH	0.4 GPH	0.6 GPH	0.9 GPH	0.4 GPH	0.6 GPH	0.9 GPH	
ш	15	248	205	163	344	285	228	427	355	285	
PRESSURE	25	315	258	203	440	361	286	549	453	359	
PRES	35	367	299	234	513	419	331	643	527	417	
INLET	40	389	316	248	545	445	350	683	559	441	
Z	4 5										
Flow	per 100' (GPM / GPH)	0.67/40	1.02/61	1.53/92	0.44/26.67	0.68/41	1.02/61	0.34/20	0.51/31	0.77/46	

Lateral lengths are based on flows allowing for a 1 fps flushing/scouring velocity

MAX	MAXIMUM LENGTH OF A SINGLE LATERAL WITH 0.5 fps FLUSH VELOCITY									
ADDITIONAL FLOW OF 0.4 GPM REQUIRED PER LATERAL TO ACHIEVE 0.5 fps										
	DRIPPER SPACING 12" 18" 24"									
DRIP	PER FLOW RATE (GPH)	0.4 GPH	0.6 GPH	0.9 GPH	0.4 GPH	0.6 GPH	0.9 GPH	0.4 GPH	0.6 GPH	0.9 GPH
ш	15	301	242	188	422	341	265	531	429	335
PRESSURE	25	369	296	228	520	418	323	655	527	409
PRES	35	421	337	260	595	476	368	749	603	467
INLET	40	443	354	273	626	501	387	790	635	491
2	45	464	371	285	656	524	404	829	665	513
Flow	per 100' (GPM / GPH)	0.67/40	1.02/61	1.53/92	0.44/26.67	0.68/41	1.02/61	0.34/20	0.51/31	0.77/46

Lateral lengths are based on flows allowing for a 0.5 fps flushing/scouring velocity

Netafim recommends flushing velocities capable of breaking free any accumulated bioslimes and debris in the piping network.

- Notes: 1. Refer to local regulations for information on flushing velocities that may be written into codes.
 - 2. Netafim does not endorse a specific flushing velocity.
 - 3. Flushing velocities should be determined based on regulations, quality of effluent, and type of flushing control.
 - Using a flushing velocity less than 1 fps does not provide turbulent flow as defined by Reynolds Number.
 - Higher flushing velocities provide more aggressive flushing.

Olvera, Brandon

From: Olvera, Brandon

Sent: Friday, May 3, 2024 8:38 AM

To: jhaagpe@gmail.com; jmartin6107@gmail.com

Subject: 117376

Property wner/Agent,

Tur office will be conducting a site visit on 05-06-2024. No other deficiencies.

Thank You,

| Brandon Olvera | Designated Representative OS0034792 | Comal County | www.cceo.org | 195 David Jonas Dr, New Braunfels, TX-78132 | t: 830-608-2090 | f: 830-608-2078 | e: olverb@co.comal.tx.us |

195 David Jonas Dr, New Braunfels, Texas 78132 (830)608-2090

Address:	·	 	
Legal Description:			

Dear Property Owner & Agent,

Thank you for your submission. We have reviewed the planning materials for the referenced permit application, and unfortunately, they are insufficient. To proceed with processing this permit, we require the following:

119024.pdf Markup Summary 10-14-2025

Brandon Mark Olvera (1)



Subject: Text Box Page Label: 1

Checkmark: Unchecked Author: Brandon Mark Olvera Date: 10/14/2025 3:44:17 PM



Please provide a current maintenance contract. The maintenance provider on this contract has an expired license.

WASTEWATER TREATMENT FACILITY MAINTENANCE AGREEMENT

Regulatory Authority Comal

Tyler Mason A&R Construction LLC & Cisco Septic Service (830) 837-0050 (210) 598-9090 Permit/License Number

Customer LJ Quality Homes, LLC

Site Address 5862 Hopper Court

City New Braunfels Zip 78132

Mailing Address 5862 Hopper Court, New Braunfels

County Comal

Map#

Phone 210-367-9249

Email jmartin6107@gmail.com

I. General: This Work for Hire Agreement (hereinafter referred to as "Agreement") is entered into by and between

& Cisco Septic Service. By this agreement, A&R Construction, LLC & Cisco Septic Service and its employees (hereinafter inclusively referred to as "Contractor") agree to render services at the site address stated above, as described herein, and the Customer agrees to fulfill his/her/their responsibilities, as described herein.

II. Effective Date:

This Agreement commences on County issue of License to Operate (LTO) and ends on (two (2) years to er). The Cy shall not busine to within the busine to establish the data ommencem into not yet of completion of installation or with the data of completion of installation or within the property of the period of installation or within the period

III. Termination reen

This Ag at terminal either party for ason ling from the party to perform the with the party to perform the with the party to perform the party that the party the party t

Please provide a current maintenance contract. The maintenance provider on this contract has an expired license.

Services:

- a. Inspect and perform routine upkeep on the On-Site Sewage Facility (hereinafter referred to as OSSF) as recommended by the treatment system manufacturer, and required by state and/or local regulation, for a total of three visits to site per year. The list of items checked at each visit shall be comprised of items required as per the manufacturer, the controlling regulatory board, and deemed by the Contractor as necessary for proper OSSF operation.
- b. Provide a written record of visits to the site.
- c. Repair or replace, if Contractor has the necessary materials at site, any component of the OSSF found to be failing or inoperative during the course of a routine monitoring visit. If such services are not covered by warranty, and the service(s) cost less than \$100.00, Customer hereby authorizes Contractor to perform the service(s) and bill Customer for said service(s). When service costs are greater than \$100.00, or if contractor does not have the necessary supplies at the site, Contractor will notify Customer of the required service(s) and the associated cost(s). Customer must notify Contractor of arrangements to affect repair of system within two (2) business days after said notification.
- d. Provide sample collection and laboratory testing of TSS and BOD on a yearly basis (commercial systems only).
- e. Forward copies of this Agreement and all reports to the regulatory agency and the Customer.
- f. Visit site in response to Customer's request for unscheduled services within forty-eight (48) hours of the date of notification (weekends and holidays excluded) of said request. Unless otherwise covered by warranty, costs for such unscheduled responses will be billed to Customer.

V. Disinfection:

Customer Responsible. The responsibility to maintain the disinfection device(s) and provide any necessary chemicals is that of the Customer.

Customer's Initials

7 111

Contractor's Initials

Co	ontractor Responsible. The re	sponsibility to maintai	n the disinfection device(s) and provide any necessary
chemicals	s is that of the Contractor.			
No	ot Required. The installed ser	otic system does not re-	quire disinfection.	

VI. Electronic Monitoring:

Electronic Monitoring is not included in this Agreement.

VII. Performance of Agreement:

Commencement of performance by Contractor under this Agreement is contingent on the following conditions:

a. Contractor's receipt of a fully executed original copy or facsimile of this agreement and all documentation requested by Contractor.

If the above conditions are not met, Contractor is not obligated to perform any portion of this Agreement.

VIII. Customer's Responsibilities:

The customer is responsible for all the following:

a. Provide all necessary yard or lawn maintenance and removal of all obstacles, including but not limited to dogs and other animals, vehicles, trees, brush, trash, or debris, as needed to allow the OSSF to function properly, and to allow Contractor safe and easy access to all parts of the OSSF.

c Maintain a current license to operate abide by the conditions and limitations of that license at

requirements for an OSSF from the State and/or local regulatory agency, whichever requirements are most stringent, as well as the proprietary system's manufacturer recommendations.

d. Notify Contactor immediately of any and all alarms, and/or any and all problems with, including failure of, the OSSF

e. Provide, upon request by Contractor, water usage records for the OSSF so that the Contractor can perform a

proper evaluation of the performant the OSSF.

f. Allow ples at the purpose of the

h. It the c ation from air bring frigers hits, or the d icemakers, from his leafly over the description of t

vide for pum Cleani As and ent uni mand and ded by Contactor, at tomer's expense

Maintain site diamage adverse effect the OSE

k. Pay promptly and fully, all Contractor's fees, bills, or invoices as described herein.

IX. Access by Contractor:

Contractor is hereby granted an easement to the OSSF for the purpose of performing services described herein. Contractor may enter the property during Contractor's normal business hours and/or other reasonable hours without pripotice to Customer to perform the Services and/or repairs described herein. Contractor shall have access to the OSSF elected and physical components. Tanks and treatment units shall be accessible by means of man ways, or risers and removable covers, for the purpose of evaluation as required by State and/or local rules and the proprietary system manufacturer. It is Customer's responsibility to keep lids exposed and accessible at all times.

X. Limit of Liability:

Contractor shall not be held liable for any incidental, consequential, or special damages, or for economic loss due to expense, or for loss of profits or income, or loss of use to Customer, whether in contract tort or any other theory. In no event shall Contractor be liable in an amount exceeding the total Fee for Services amount paid by Customer under this Agreement.

XI. Indemnification:

Customer (whether one or more) shall and does hereby agree to indemnify, hold harmless and defend Contractor and each of its successors, assigns, heirs, legal representatives, devisees, employees, agents and/or counsel (collectively "Indemnitees") from and against any and all liabilities, claims, damages, losses, liens, causes of action, suits, fines, judgments and other expenses (including, but not limited to, attorneys' fees and expenses and costs of investigation), of any kind, nature or description, (hereinafter collectively referred to as "Liabilities") arising out of, caused by, or resulting, in whole or in part, from this Agreement.

Customer's Initials

1111

Contractor's Initials

THIS INDEMNITIFCATION APPLIES EVEN IF SUCH LIABILITIES ARE CAUSED BY THE CONCURRENT OR CONTRIBUTORY NEGLIGENCE OR BY THE STRICT LIABILITY OF ANY INDEMNITEE.

Customer hereby waives its right of recourse as to any Indemnitee when Indemnification applies, and Customer shall require its insurer(s) to waive its/their right of subrogation to the extent such action is required to render such waiver of subrogation effective. Customer shall be subrogated to Indemnitees with respect to all rights Indemnitees may have against third parties with respect to matters as to which Customer provides indemnity and/or defense to Indemnitees. No Indemnification is provided to Indemnitees when the liability or loss results from (1) the sole responsibility of such Indemnitee; or (2) the willful misconduct of such Indemnitee. Upon irrevocable acceptance of this Indemnification obligation, Customer, in its sole discretion, shall select and pay counsel to defend Indemnitees of and from any action that is subject to this Indemnification provision. Indemnitees hereby covenant not to compromise or settle any claim or cause of action for which Customer has provided Indemnification without the consent of Customer.

11. Severability:

If any provision of the "Proposal and Contract" shall be held to be invalid or unenforceable for any reason, the remaining provisions shall continue to be valid and enforceable. If a court finds that any provision of the "Agreement" is invalid or unenforceable, but that by limiting such provision it would become valid and enforceable, then such provision shall be deemed to be written, construed, and enforced as so limited.

XIII. Fee for Services:

The r Services definition of the services described with t

XIV. Payment:

Full p to is du execu his Agreement ny of vice(s air(s) provid ontractor the invoices day voice. I ments not recei from the invoice day day voice. I ments not recei from the invoice day day doing charge, as any able at sees, and doing costs incurred by the invoice day doing charge, as any able at sees, and doing costs incurred by the invoice day doing charge, as any able at sees, and doing contractor the invoice day day doing charge, as any able at sees, and doing contractor the invoice day day doing charge, as any able at sees, and doing contractor the invoice day day doing charge, as any able at sees, and doing charge charge.

XV. Application (fer of payment:

The fees paid for this agreement may be transferred to subsequent property owner(s); however, this Agreement is not transferable. Customer shall advise the subsequent property owner(s) of the State requirement that they sign a replacement agreement authorizing Contractor to perform the herein described Services and accepting Customer's Responsibilities. This replacement Agreement must be signed and received in Contractor's offices within ten (10) business days of date of transfer of property ownership. Contractor will apply all funds received from Customer first to any past due obligation arising from this acceptance to the replacement agreement. The consumption of funds in this manner may cause a reduction in the termination date of effective coverage per this Agreement. See Section III.

XVI. Entire Agreement:

This agreement contains the entire Agreement of the parties, and there are no other conditions in any other agreement, oral or written.

Customer Signature

04-11-2021 Date

A&R Construction LLC / Cisco Septic Service

Tyler Mason Contractor MP#0002228

Customer's Initials

Contractor's Initials

AEROBIC TREATMENT DRIP TUBING SYSTEM FOR: LOT 889, BONNEYVIEW DR. CANYON LAKE FOREST, UNIT 2

SITE DESCRIPTION:

situated with soils per the Site Evaluation report. An aerobic treatment plant utilizing drip irrigation was chosen as the most appropriate system to serve the conditions on this lot.

PROPOSED SYSTEM:

A 3 or 4 inch SCI 1 40 pipe displayers from the published into a NuMeter B-550 (costs) at aerobic treatment plant contain 353 gallo directory. 768 gallo dipp of the pump chamber contains a 0 frankli Serie 21-05F 15 subsible dimp. It pump is activated by a control lowing distribution limes and with the float setting a 240 s. A level audible visu rm w vate should pump fail. Distribution is gift flushi 0 micron Ark k fill an through a 1" SCH-1 mifold to a minimum 1200 tipp of field vetifim Bioling lines oximit wo feet ap in 0.61 gph emitters set ever a specific distribution is installed in the local control with the fluoristic distribution is installed and distribution is local properties. A sure litter Mode 35MF 35psi installed in the local control with the fluoristic distribution is installed and distribution in the disk filter are flushed each back to the pump and cultural Points, Indiana and the disk filter are flushed each back to the pump and cultural Points, Indiana and the local control of Type II or III soil is above any bedrock or type IV soils then the drip tubing shall be laid and capped with a minimum of 6" of Type II or Type III soil (NOT SAND). The field area shall be sodded with grass prior to solve the startup. The tank must have risers 2-inches minimum above finished grade on each opening with

watertight caps that must be 65# or have a padlock or can only be removed with tools – all risers shall meet the minimum requirements of 30 TAC 285 effective July 6, 2023. A secondary plug, cap or suitable restraint must be provided below riser cap to prevent tank entry should the cap be damaged or removed.

DESIGN SPECIFICATIONS:

Daily flow = Q=240 gpd

Pretreatment tank size: 353 gal

Plant size: NuWater B-550; 600 gpd (TCEQ approved)

Pump tank size: 768 gal

Min. Reserve capacity after high level: 80 gal (1/3 day req'd)

Application rate: Ra=0.2 gal/sf

Total absorption area: Q/Ra = min. 1200 sf (1,472 sf actual)

Total linear feet of drip tubing: 736' Netifim Bioline drip tubing 0.61 gph Pump requirement: 0.5 HP Franklin C1-Series-20XC1-05P4-2W115

	Calculation Outputs
1,472 736 368	Total System Information Application Area Required (square feet) Total Amount of Bioline® Required (feet) Total Number of Emitters in the Dripfield
1 736	Zone Information Number of Zones Amount of Bioline [®] Per Zone (feet)
1 11 2 391 3.7	Muniber of Emitters Per Zone Minimum Number of Laterals Per Zone Maximum Number of Laterals Per Zone Number of Laterals That Will be Used Maximum Length of Bioline® Laterals Based on Inlet Pressure Figure 12
9.8	dition Require Accordate FI Velocity ding Capa
9.8 26.0	ding C / (Gallons) of Line pply 8 Manifolds Holdin acity ns pe) of Bioline Holding C / (Gallons) Ply Li anifold Dripperline Dripperline Ply Li anifold Ply Li anifold Dripperline Ply Li anifold Ply
1.2 2.6 4.4 10.1 1.2	Head Lo Finding Loss per 100' (psr) in Supply Line & Warffolds Velocity (fps) Friction Loss in Supply Line & Supply Manifolds (psi) Friction Loss in Supply Line & Supply Manifolds (Feet of Head) Additional Pressure Required for Return Manifold and Piping to Tank (psi)
110.9 64 64 10 6 2.3	TDH (Total Dynamic Head) in Feet of Head Control Settings Information Total System Runtime Per Day (Minutes) Total Runtime Per Zone Per Day (Minutes) Total System Dosing Events Per Day Runtime For Each Dose (Minutes) Off Time Between Doses in the Same Zone (Hours to nearest 0.1)
0.07 1.83 26.2	Miscellaneous Information Dosing Volume Per Emitter Per Dose (gallons) Inches Per Week of Dosing Volume of a Single Dose (gallons)
6.9 110.9 Franklin	Pump Selection Pump Flow Rating (GPM) TDH (Total Dynamic Head in Feet of Head) Pump Manufacturer Pump Model 20)

PIPE AND FITTINGS:

All pipes and fittings in this drip tubing system shall be 1" schedule 40 pvc. All joints shall be sealed with approved solvent type pvc cement. Clipper type cutters are recommended to prevent pvc burrs during cutting of pipes causing people le plugging.

Designe accordar th C' 200, apter I 85 at 60.45 Commission on Environt I Quality rised (12013).




04/04/2024


Haag Engineering Consultants, LLC

Firm No.: F-5786

GENERAL NOTES:

- 1. NO VEHICULAR TRAFFIC IS ALLOWED ON ANY PORTION OF THE DISPOSAL SYSTEM, UNLESS THE DESIGN SPECIFIES OTHERWISE.
- 2. PIPE ALIGNMENT TO THE DISPOSAL BEDS MAY BE ALTERED AS REQUIRED. ANY CHANGE FROM THE PLANS MUST BE APPROVED BY THE ENGINEER AND THE APPROPRIATE GOVERNMENTAL AGENCY(IES).
- 3. CONTRACTOR SHALL PROTECT TREES WHICH ARE NOT IN THE EXCAVATED CONSTRUCTION AREAS. CONTRACTOR SHALL MINIMIZE ROOT DAMAGE AND REASONABLY ADHERE TO THE DESIGN.
- 4. CONTRACTOR IS RESPONSIBLE FOR VERIFYING A MINIMUM OF 1/4" PER FOOT OF FALL FROM THE BUILDING TO THE SEPTIC TANK.
- 5. NOT AUTOMATIC SPRINKLER SYSTEM SHALL BE INSTALLED OVER THE DISPOSAL AREAS. ANY WATERING IN THESE AREAS SHALL BE DONE BY HAND AND ONLY WHEN REQUIRED TO MAINTAIN GRASS COVER.
- 6. ALL CONSTRUCTION SHALL CONFORM TO THE RULES AND REGULATIONS OF THE APPROPRIATE AUTHORITY TEXAS COMMISSION ON ENVIRONMENTAL QUALITY (TCEQ) AND ANY APPLICABLE LOCAL BUILDING AND SAFETY CODES.
- 7. CONTRACTOR SHALL BE RESPONSIBLE FOR LOCATING AND VERIFYING THE LOCATION OF ALL EXISTING UNDERGROUND UTILITIES THAT MAY BE AFFECTED BY THE CONSTRUCTION OF THIS SYSTEM.
- 8. THE DRIP FIELD SHALL BE VEGETATED WITH EITHER ST. AUGUSTINE OR BERMUDA SOD.
- 9. FIELDS MUST BE MOWED AT REGULAR INTERVALS. FAILURE TO PROPERLY MAINTAIN VEGETATIVE COVER MAY RESULT IN SYSTEM FAILURE AND SHALL BE THE RESPONSIBILITY OF THE OWNER.
- 10. ALL PIPES SHALL BE SCHEDULE 40 PVC OR APPROVED EQUAL, UNLESS NOTED OTHERWISE. ALL JOINTS SHALL BE CLEANED WITH THE APPROPRIATE SOLVENT AND GLUED IN ACCORDANCE WITH THE MANUFACTURER'S RECOMMENDATION.
- 11. ALL POTABLE WATER LINES SHALL BE A MINIMUM OF 10 FEET FROM ANY DISPOSAL SYSTEM OR SEWERAGE PIPE. THE CONTRACTOR SHALL NOTIFY THE ENGINEER OF WATER LINES LESS THAN 10 FEET FROM THE DISPOSAL AREA.
- 12. HIGH WATER ALARM SHALL BE LOCATED IN A NOTICEABLE LOCATION. THE ALARM SHALL BE A VISUAL AND AUDIBLE ALARM AND WIRED ON A SEPARATE CIRCUIT FROM THE PUMPS. ALL EXTERIOR CONTROLS AND CONNECTIONS SHALL BE ENCLOSED IN A WEATHER-PROOF HOUSING. ELECTRICAL CONSTRUCTION SHALL COMPLY WITH ALL LOCAL ELECTRICAL AND BUILDING CODES.
- 13. NO EXCAVATION IS PERMITTED NEAR THE DISPOSAL FIELDS THAT WILL RESULT IN THE NONCOMPLIANCE OF APPLICABLE SETBACKS STATED IN THE RULES AND REGULATIONS OF THE APPROPRIATE AUTHORITY.
- 14. ONLY GOOD QUALITY SANDY LOAM SHALL BE APPLIED OVER THE DISPOSAL FIELDS. CLAY LOAM IS UNACCEPTABLE AND WILL CAUSE SYSTEM FAILURE. SANDY LOAM SHALL BE DEFINED AS SHOWN IN TABLE VI (USDA SOIL TEXTURAL CLASSIFICATIONS) OF THE RULES AND REGULATIONS OF THE TCEQ. THE INSTALLER IS RESPONSIBLE FOR VERIFYING THE QUALITY OF EACH LOAD OF LOAM PLACED ON THE SYSTEM.
- 15. STORM WATER (RAINFALL RUNOFF) SHOULD NOT BE ALLOWED TO FLOW OVER THE DISPOSAL FIELDS OR THE TANKS. DIVERSION BERMS, SWALES AND/OR RAIN GUTTERS SHOULD BE INSTALLED AS NECESSARY TO PREVENT SUCH RUNOFF.
- 16. THE CONTRACTOR IS RESPONSIBLE FOR STAKING AND VERIFYING THE GRADES PRIOR TO EXCAVATION. ANY DISCREPANCIES OF MORE THAN 6 INCHES SHALL BE REPORTED TO THE ENGINEER PRIOR TO EXCAVATION. THE CONTRACTOR SHALL NOT DEVIATE FROM THESE PLANS WITHOUT THE WRITTEN CONSENT OF THE APPROPRIATE AUTHORITY AND THE ENGINEER.
- 17. THIS DISPOSAL SYSTEM HAS BEEN DESIGNED TO OPERATE PROPERLY AT SPECIFICATIONS NOTED IN THESE PLANS. ALTERATIONS TO THE SYSTEM BY THE OWNER, INCLUDING BUT NOT LIMITED TO LANDSCAPING, DRAINAGE, BUILDING AND/OR WATER USAGE, MAY CAUSE PREMATURE FAILURE AND SHALL BE THE SOLE RESPONSIBILITY OF THE OWNER.
- 18. CONTRACTOR SHALL BE RESPONSIBLE FOR VERIFYING ALL PLUMBING FIXTURES ARE CONNECTED TO THE DESIGNATED SEPTIC TANK(S). LOW FLOW TOILETS (1.6 GAL), SHOWERHEADS AND FAUCETS SHALL BE USED IN THE STRUCTURES.
- 19. CONTRACTOR SHALL BE RESPONSIBLE FOR JOBSITE SAFETY AND PROTECTION OF THE PUBLIC FROM INJURY DURING CONSTRUCTION. THE OWNER SHALL BE RESPONSIBLE FOR THE PREVENTION OF PERSONAL INJURY TO ANYONE ON OR NEAR THE DISPOSAL SYSTEM.
- 20. CONTRACTOR SHALL BE RESPONSIBLE TO ENSURE THAT ALL TANKS HAVE ADEQUATE STRENGTH AND INTEGRITY TO PERFORM SATISFACTORILY AS SHOWN ON THESE PLANS
- 21. THE WASTEWATER FLOW TO THE SEPTIC SYSTEM SHALL NOT EXCEED THE DESIGN FLOW SHOWN ON THIS PLAN.





OSSF LAYOUT LOT 889, BONNYVIEW DR. CANYON LAKE FOREST, UNIT 2 CANYON LAKE, TEXAS

DD'L. NOTES:

- DESIGN DAILY WASTEWATER FLOW = 240 GPD (WATER SAVING DEVICES WERE ASSUMED FOR SEPTIC SYSTEM DESIGN).
- 2. TOPOGRAPHIC DATA SOURCE: FEMA 2011 DATA
- 3. INSTALLER SHALL VERIFY ALL EASEMENTS, SETBACKS AND PROPERTY LINE BEARINGS AND DISTANCES PRIOR TO CONSTRUCTION.
- ALL RISERS SHALL MEET THE MINIMUM REQUIREMENST OF 30 TAC 285 EFFECTIVE 07/06/2023

NOTE: OSSF IS NOT WITHIN THE EDWARDS AQUIFER RECHARGE ZONE OR FEMA 100 YEAR FLOODPLAIN. SITE EVALUATION BY JOHN J. HAAG, P.E. ON 04/03/2024 DRAWN BY: JJH

CHECKED BY: JJH

DATE: 04/11/24

JOB NO. LJQUALITY24001

SHEET 1 OF 1

H EC HAAG ENGINEERING CONSULTANTS

15831 SECRET TRAILS SAN ANTONIO, TEXAS 78247 FIRM: F-5789 TEL: (210) 705-4268

©COPYRIGHT 2024 HAAG ENGINEERING CONSULTANTS: ALL RIGHTS RESERVED

Assembly Details

OSSF

Pump float settings for 240 gpd design flow and min. 80 gal reserve:

Pump off position: 12 inches above

Pump on position: 29 inche dove tank bottom (409.90 gal) Alarm on position: 36 ing es above tank bottom (512.22 gal)

254.04 gal reserve capacity at approx. 53 inches above tank bottom









(tablet & liquid) available. Bio-Robix B-550 Control C er w/ Timer for night o Dose (min/sec)timer ctrical Requirement to be available for drip applications. E AMP, Grounded Receptacle. Optional extension

Plant structure material to be precast concrete and steel. Maximum burial depth is 30" from slab top to grade.

Treatment capacity is 600 GPD. Pump compartment set-up for a 360 GPD Flow Rate (4 beedroom, < 4,000 sq/ft living aera). Please specify for additional set-up requirements.

Standard tablet chlorinator or Optional Liquid chlorinator.


GENERAL NOTES:

Weight = 14,900 lbs.

BOD Loading = 1.62 lbs. per day.

pump. 20 GPM 1/2 HP, high head effluen te housing. Lft from Plant). pipe to distribution system provided by

ed sand or gravel and by Contractor



ight: 67" dth: 63" ngth: 164"

CAVATION DIMENSIONS:

Length: 176"

See Note 12.

NuWater B-550 (600 GPD) **Aerobic Treatment Plant (Assembled)**

Model: B-550-PC-400PT

March, 2012 - Rev 1 By: A.S.

* All Dimensions subject to allowable specification

Dwg. #: ADV-B550-3



Advantage Wastewater Solutions IIc. 444 A Old Hwy No 9 Comfort, TX 78013 830-995-3189 fax 830-995-4051

NOTICE OF CONFIDENTIALITY RIGHTS: IF YOU ARE A NATURAL PERSON, YOU MAY REMOVE OR STRIKE ANY OR ALL OF THE FOLLOWING INFORMATION FROM ANY INSTRUMENT THAT TRANSFERS AN INTEREST IN REAL PROPERTY BEFORE IT IS FILED FOR RECORD IN THE PUBLIC RECORDS: YOUR SOCIAL SECURITY NUMBER OR YOUR DRIVER'S LICENSE NUMBER.

GENERAL WARRANTY DEED WITH VENDOR'S LIEN

Date: November 18, 2023

Grantor: Aroble Management, LLC, a Texas limited liability company

Grantor's Mailing Address (including county):

7319 Washita Way San Antonio, Texas 78676 Bexar County

Grantee: LJ Quality Homes, LLC, a Texas limited liability company

Grantee's Mailing Address (including County):

5862 Hopper Court New Braunfels, Texas 78132 Comal County

Consideration: TEN AND NO/100 DOLLARS and other good and valuable consideration and the further consideration of a note of even date that is in the principal amount of FIFTY-THREE THOUSAND (\$53,000.00) DOLLARS and is executed by Grantee, payable to the order of AROBLE INVESTMENTS, LLC, A TEXAS LIMITED LIABILITY COMPANY. The note is secured by a veridor's lien retained in favor of AROBLE INVESTMENTS, LLC, A TEXAS LIMITED LIABILITY COMPANY in this deed and by a deed of trust of even date, from Grantee to Joseph J. Malone, Trustee.

Property (including any improvements):

Lot 889, CANYON LAKE FOREST, UNIT 2, situated in Comal County, Texas, according to the map or plat thereof, recorded in Volume 1, Page 73, Map and Plat Records, Comal County, Texas

Reservations From and Exceptions to Conveyance and Warranty:

This conveyance is made and accepted subject to any and all restrictions, covenants, reservations, and easements, if any, relating to the hereinabove described property, but only to the extent they are still in effect, shown of record in the hereinabove mentioned County and State.

Grantor, for the consideration, receipt of which is acknowledged, and subject to the reservations from and exceptions to conveyance and warranty, grants, sells and conveys to Grantee the property, together with all and singular the rights and appurtenances thereto in any wise belonging, to have and hold it to Grantee, Grantee's heirs, executor, administrators, successors or assigns forever. Grantor binds Grantor and Grantor's heirs, executors, administrators and successors are hereby bound to warrant and forever defend all and singular the property to Grantee and Grantee's heirs, executors, administrators, successors and assigns against every person whomsoever lawfully claiming or to claim the same or any part thereof, except as to the reservations from and exceptions to conveyance and warranty.

AROBLE INVESTMENTS, LLC, A TEXAS LIMITED LIABILITY COMPANY at Grantee's request, having paid in cash to Grantor that portion of the purchase price of the property that is evidenced by the Note described, the Vendor's Lien and Superior Title to the Property are retained for the benefit of AROBLE INVESTMENTS, LLC, A TEXAS LIMITED LIABILITY COMPANY and are transferred and assigned AROBLE INVESTMENTS, LLC, A TEXAS LIMITED LIABILITY COMPANY and its successors and assigns, without recourse on Grantor.

The Vendor's Lien against and Superior Title to the Property are retained until each Note described is fully paid according to its terms, at which time this Deed shall become absolute.

When the context requires, singular nouns and pronouns include the plural.

Aroble Management, LLC, a Texas limited liability company

By:

Jude S. Garcia, Managing Member

ACKNOWLEDGMENT

STATE OF TEXAS

COUNTY OF COMAL

This instrument was acknowledged before me on this <u>18</u> day of November 2023 by Jude S. Garcia, Managing Member of Aroble Management, LLC, a Texas limited liability company, on its behalf.

BRITTANY PHILLIPS
My Notary ID # 126000272
Expires May 6, 2027

Notary Public, State of Texas

PREPARED IN THE OFFICES OF: Stevens & Malone, PLLC P.O. Box 1744 Canyon Lake, Texas 78133 830.964.4426 – tel. 830.964.4426 – fax

> Filed and Recorded Official Public Records Bobbie Koepp, County Clerk Comal County, Texas 11/22/2023 10:03:55 AM LAURA 3 Pages(s) 202306036885

