

Postcard  
9/19/74

Permit No. 34088

APPLICATION FOR SEPTIC SYSTEM PERMIT

( To be submitted in Duplicates Only)

NAME and LOCATION of PROPERTY where Septic System is to be installed: \_\_\_\_\_

Preiss Heights

Mary Preiss Drive (North)

UNIT NO. \_\_\_\_\_ BLOCK NO. 3 LOT NO. 4

Dimension of Property 1.43

Description of Structure

No. Bedrooms 3 No. Bathrooms 2 Disposal x W, Machine x

Size of Septic System 1000 gal. NO. Feet Laterals 219' X 36"

Date 9/19/74

Krause

Sanitary Facility Contractor

Mike Kilgore , Contractor

Address

OWNER Mike Otten

Address

All recommendations are minimum requirements as prescribed by the  
"GUIDE TO THE DISPOSAL OF HOUSEHOLD SEWAGE" published by the  
TEXAS HEALTH DEPARTMENT  
Austin, Texas

NOTE: For the information to be submitted in connection with this application,  
see the requirements outlined in the current TEXAS WATER QUALITY  
BOARD ORDER.

Comal County Sanitation Department  
Room 114, Courthouse  
New Braunfels, Texas 78130

Ronald N. Dalrymple, P.E.  
Reg. Nr# 29896  
Test data: 14 SEPT 1974

Job# 740902  
Contractor: MIKE KILGORE  
Owner: MIKE OTTEN

# PERCOLATION TEST REPORT

Property: Lot# \_\_\_\_\_, Block# \_\_\_\_\_, Unit# \_\_\_\_\_, "PREISS HEIGHTS"  
Subdivision, COMAL County, Texas.  
1.43 ± acres as described PP 49-30, Vol. 156, Deed Records.  
Other: \_\_\_\_\_

Zone: RECHARGE  
Slope: 3' IN 10.0'  
Soil: BLACK CLAY TOP SOIL MIXED WITH ROCK (1" TO 40")

Hole Nr.	Depth inches	Rate min/in.
1	18	24
2	16	20
3	18	27
4	15	20
5	16	23
6	16	24
Sum	=	133
Avg	=	22

MARY PREISS DR.

PROPERTY LINE

